

P001\_樹林焚化廠CEMS系統月報表

報表日期: 2023年8月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	7.76	10.10	54.05	1.53	17.24	11.76	1.06	77275.00
2	8.62	10.25	55.98	1.40	17.59	11.72	1.06	77798.00
3	8.26	10.75	56.85	1.61	16.85	11.76	1.08	77369.00
4	7.73	10.59	57.52	1.18	17.72	11.42	1.10	77930.00
5	4.83	12.11	59.24	0.84	18.84	11.43	1.07	78486.00
6	7.06	12.47	55.89	1.01	18.85	11.40	1.06	77739.00
7	5.43	8.51	54.85	1.10	17.44	11.59	1.07	75994.00
8	6.38	9.71	54.72	1.33	17.54	11.68	1.08	77151.00
9	8.76	9.82	55.23	1.75	17.96	11.57	1.08	77125.00
10	7.61	8.27	54.03	1.76	16.89	11.63	1.08	74814.00
11	6.59	9.59	53.98	1.41	17.33	11.43	1.07	75968.00
12	6.44	10.54	52.72	1.65	17.05	11.46	1.05	76122.00
13	7.95	10.83	54.80	1.29	17.98	11.39	1.03	76225.00
14	7.22	9.19	50.18	1.56	17.06	11.50	1.04	75448.00
15	5.63	8.49	53.60	1.84	16.46	11.65	1.04	74164.00
16	5.45	8.30	55.26	2.64	15.78	12.00	1.09	73305.00
17	8.73	6.68	57.90	2.87	16.58	11.74	1.06	75511.00
18	9.49	6.85	56.83	2.52	16.42	11.73	1.04	75754.00
19	8.76	8.60	56.06	2.22	17.29	11.61	1.03	76980.00
20	4.95	8.84	54.61	2.20	16.85	11.68	1.02	86817.00
21	5.92	9.15	56.19	2.25	17.26	11.53	1.00	86734.00
22	7.05	9.07	56.32	2.21	16.80	11.86	1.02	84227.00
23	6.83	7.73	56.52	2.94	15.75	11.98	1.04	80249.00
24	8.32	7.77	58.22	2.47	17.25	11.63	1.04	77629.00
25	9.03	6.84	56.74	2.05	17.50	11.52	1.03	77634.00
26	8.20	8.53	50.99	1.84	17.99	11.55	0.99	76619.00
27	6.35	8.75	50.72	1.74	17.94	11.60	0.98	76474.00
28	5.99	11.41	49.99	1.25	18.90	11.35	0.98	77625.00
29	7.92	10.40	54.08	1.92	17.24	11.67	0.99	75791.00
30	7.89	9.81	52.13	1.94	17.49	11.56	1.02	77752.00
31	5.72	8.18	52.65	1.38	17.88	11.48	1.02	76930.00
平均值	7.19	9.29	54.80	1.80	17.35	11.61	1.04	77601.26
最大值	9.49	12.47	59.24	2.94	18.90	12.00	1.10	86817.00
最小值	4.83	6.68	49.99	0.84	15.75	11.35	0.98	73305.00

備註： 1.\*:儀器保養維護中。

2.\*\*:停爐中。

P002\_樹林焚化廠CEMS系統月報表

報表日期: 2023年8月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	8.15	8.59	52.26	1.76	18.27	10.09	1.15	83536.00
2	9.06	8.48	52.53	1.26	20.21	9.74	1.14	83995.00
3	8.96	9.50	53.38	1.43	19.02	9.88	1.15	83634.00
4	8.34	7.77	53.95	1.35	17.88	10.07	1.16	82582.00
5	4.80	9.75	55.16	1.53	17.98	10.58	1.16	80417.00
6	6.18	7.69	52.87	1.68	18.93	10.17	1.12	82318.00
7	6.39	6.40	51.15	1.54	18.54	10.00	1.10	82988.00
8	6.50	5.65	52.07	1.63	18.29	10.13	1.10	83336.00
9	9.23	6.39	55.70	1.89	17.80	10.22	1.08	82567.00
10	7.10	5.75	49.12	1.99	17.82	10.03	1.06	81021.00
11	8.60	7.71	55.24	1.84	17.57	10.38	1.06	82156.00
12	8.23	7.77	51.95	1.61	18.04	10.19	1.07	83055.00
13	7.66	6.48	53.61	2.07	18.16	10.07	1.06	84116.00
14	7.95	6.03	51.98	1.59	17.85	9.96	1.07	83103.00
15	5.68	7.09	56.37	2.20	17.08	10.52	1.11	81706.00
16	5.62	7.25	53.98	2.14	17.11	10.57	1.11	81187.00
17	7.39	7.48	55.86	2.81	17.36	10.40	1.11	82553.00
18	6.58	8.16	57.88	2.83	16.26	10.75	1.07	80592.00
19	3.78	10.06	56.47	2.19	16.37	10.69	1.09	79824.00
20	2.94	6.22	54.45	2.34	17.07	10.54	1.10	83858.00
21	4.21	5.69	53.86	2.06	17.29	10.43	1.11	86365.00
22	7.39	5.90	53.75	3.14	16.98	10.87	1.10	82261.00
23	9.47	5.94	53.60	3.34	16.71	11.11	1.02	82780.00
24	7.78	5.17	55.61	2.13	16.95	10.41	0.99	84370.00
25	8.05	5.44	52.35	2.04	17.46	10.34	1.01	84538.00
26	8.34	6.75	54.18	2.08	17.43	10.34	0.99	84090.00
27	3.69	7.05	51.22	2.05	17.67	10.47	1.00	83074.00
28	3.43	6.37	51.43	1.82	17.61	10.27	1.03	84389.00
29	6.23	6.51	52.48	2.22	17.55	10.41	1.02	84323.00
30	5.88	7.07	50.71	2.37	16.59	10.40	1.01	82650.00
31	5.64	5.54	55.70	1.84	16.89	10.54	0.99	82408.00
平均值	6.75	7.02	53.58	2.02	17.64	10.34	1.08	82896.52
最大值	9.47	10.06	57.88	3.34	20.21	11.11	1.16	86365.00
最小值	2.94	5.17	49.12	1.26	16.26	9.74	0.99	79824.00

備註： 1.\*:儀器保養維護中。

2.\*\*:停爐中。

P003\_樹林焚化廠CEMS系統月報表

報表日期: 2023年8月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	5.68	8.99	57.60	1.79	15.98	11.17	1.02	79227.00
2	4.38	10.30	55.37	1.40	16.54	11.03	1.01	78977.00
3	3.97	9.66	54.90	1.34	16.26	10.53	1.03	77372.00
4	3.84	8.23	57.12	1.30	15.65	11.08	1.03	79173.00
5	1.62	9.48	53.24	0.91	16.52	10.86	1.04	80317.00
6	3.37	9.71	53.94	0.99	16.48	10.96	1.06	80209.00
7	2.75	7.12	51.86	1.00	16.25	10.63	1.07	78213.00
8	4.54	8.46	52.23	1.65	16.01	10.96	1.09	78658.00
9	7.02	8.02	50.83	1.65	16.44	10.81	1.08	79652.00
10	6.72	7.35	45.71	1.53	16.65	10.48	1.04	77343.00
11	8.45	7.77	46.12	1.61	16.44	10.83	1.08	79196.00
12	9.11	8.17	50.34	1.41	16.05	10.61	1.04	77563.00
13	7.88	7.20	51.79	1.34	16.87	10.35	1.02	79334.00
14	6.97	7.82	52.35	1.84	16.04	10.74	0.99	76223.00
15	5.46	7.40	55.52	2.12	15.08	11.35	1.02	76423.00
16	4.06	7.20	56.88	2.31	15.28	11.09	1.03	72975.00
17	8.95	6.20	56.39	2.98	15.59	10.95	1.01	75757.00
18	10.04	5.18	50.33	3.04	15.67	10.92	1.00	75136.00
19	7.23	7.55	53.35	2.14	15.17	11.01	1.01	76004.00
20	7.57	7.05	59.63	2.13	15.45	11.24	1.01	76998.00
21	7.72	8.30	52.37	1.82	15.80	11.09	1.01	75557.00
22	6.47	7.44	52.93	2.65	15.25	11.32	0.98	73872.00
23	4.32	7.00	49.68	3.49	14.77	11.24	0.98	72263.00
24	7.84	5.89	54.85	2.90	15.85	10.63	0.98	76643.00
25	8.05	6.04	55.30	2.43	16.02	10.81	0.96	76069.00
26	8.09	7.37	54.98	3.13	15.31	10.86	0.94	75316.00
27	5.74	7.10	54.42	2.51	15.36	10.99	0.96	75223.00
28	5.28	7.01	47.65	2.29	16.38	10.44	0.97	76727.00
29	6.73	7.50	52.28	2.28	15.75	10.84	0.95	76797.00
30	6.38	7.83	50.67	2.58	15.17	10.73	0.94	74856.00
31	3.89	7.15	53.62	2.42	15.85	10.47	0.96	83878.00
平均值	6.13	7.66	53.04	2.03	15.87	10.87	1.01	77159.71
最大值	10.04	10.30	59.63	3.49	16.87	11.35	1.09	83878.00
最小值	1.62	5.18	45.71	0.91	14.77	10.35	0.94	72263.00

備註： 1.\*:儀器保養維護中。

2.\*\*:停爐中。