

P001_樹林焚化廠CEMS系統月報表

報表日期: 2022年02月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	15.11	12.83	38.39	0.47	17.24	10.86	1.46	72364.00
2	15.65	9.29	64.61	1.40	15.57	11.58	1.49	69940.00
3	16.61	15.76	71.35	2.22	13.94	12.03	1.49	66261.00
4	14.27	21.34	59.53	1.92	14.48	12.31	1.47	65454.00
5	14.07	36.22	41.22	1.00	16.32	11.40	1.44	70209.00
6	14.51	13.83	36.48	0.77	16.88	11.22	1.33	74507.00
7	13.35	7.93	48.00	0.77	16.64	11.56	1.35	69393.00
8	14.99	11.04	51.01	1.17	15.99	11.51	1.36	71327.00
9	14.38	8.19	52.09	1.01	16.03	11.81	1.38	67683.00
10	14.40	7.33	48.43	0.85	17.50	11.40	1.36	69611.00
11	15.51	11.74	45.66	0.93	17.80	10.99	1.37	72087.00
12	14.74	6.27	49.87	1.40	16.73	11.32	1.37	70857.00
13	14.66	4.39	51.32	1.24	17.31	11.26	1.38	70750.00
14	16.30	5.42	74.34	1.87	14.82	11.94	1.35	69569.00
15	14.84	5.76	53.38	1.20	16.24	11.74	1.40	70460.00
16	14.47	8.78	52.38	1.27	16.29	11.81	1.47	68264.00
17	14.55	10.14	56.58	1.06	16.58	11.73	1.47	68809.00
18	14.49	10.54	50.95	1.05	16.34	11.76	1.50	69596.00
19	14.66	9.56	51.08	1.15	16.33	11.60	1.50	71092.00
20	15.91	5.18	59.79	0.82	16.63	11.44	1.49	72400.00
21	14.51	8.03	55.08	0.92	16.03	11.85	1.53	70715.00
22	14.41	8.37	44.99	0.72	17.39	11.35	1.52	71808.00
23	14.61	8.75	48.17	1.11	16.45	11.48	1.53	70265.00
24	14.94	5.38	55.22	1.23	15.72	11.82	1.56	68176.00
25	14.22	4.86	48.62	0.57	17.31	11.32	1.56	70834.00
26	14.63	7.13	50.01	1.13	16.52	11.53	1.58	68928.00
27	14.44	4.96	62.60	0.63	17.63	11.44	1.54	69127.00
28	14.43	6.71	55.47	0.58	17.43	11.33	1.52	68740.00
平均值	14.77	9.85	52.74	1.09	16.43	11.55	1.46	69972.36
最大值	16.61	36.22	74.34	2.22	17.80	12.31	1.58	74507.00
最小值	13.35	4.39	36.48	0.47	13.94	10.86	1.33	65454.00

備註： 1.*:儀器保養維護中。
 2.**:停爐中。

P002_樹林焚化廠CEMS系統月報表

報表日期: 2022年02月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	14.25	7.15	49.76	0.27	16.09	10.89	1.48	62240.00
2	14.29	4.00	60.81	0.27	15.80	10.95	1.46	62448.00
3	15.09	8.18	58.93	0.26	15.76	10.95	1.48	61802.00
4	13.88	7.71	62.26	0.26	16.44	10.98	1.49	60767.00
5	13.17	6.07	53.48	0.14	18.10	10.47	1.48	63378.00
6	13.53	7.29	46.26	0.22	18.17	10.26	1.49	64015.00
7	13.34	7.01	48.62	0.17	18.05	10.49	1.48	62664.00
8	13.80	9.45	48.47	0.23	18.10	10.35	1.48	62831.00
9	14.05	9.30	48.32	0.30	18.21	10.50	1.43	63766.00
10	13.88	7.10	53.68	0.22	18.18	10.38	1.45	63216.00
11	14.18	9.84	50.97	0.36	17.91	10.39	1.48	63473.00
12	14.13	6.70	50.22	0.25	17.67	10.50	1.52	63039.00
13	13.98	9.10	50.72	0.29	17.88	10.63	1.52	62097.00
14	13.58	8.08	57.97	0.48	16.83	11.17	1.52	62561.00
15	13.62	8.39	55.72	0.35	18.60	11.12	1.50	64676.00
16	14.11	8.14	54.79	0.27	17.59	10.67	1.60	62377.00
17	13.80	7.65	57.61	0.16	17.46	10.87	1.59	60726.00
18	14.39	12.69	54.05	0.34	16.99	10.96	1.54	61151.00
19	13.80	6.76	54.41	0.24	17.42	10.84	1.51	61691.00
20	14.10	3.69	51.53	0.15	17.31	10.77	1.50	62460.00
21	13.82	4.14	52.26	0.22	16.78	11.11	1.52	60645.00
22	13.76	11.77	53.56	0.25	17.30	10.92	1.49	61215.00
23	13.99	6.42	56.51	0.17	17.61	10.82	1.48	61008.00
24	13.91	13.24	56.93	0.20	16.90	10.84	1.50	61409.00
25	13.59	11.84	51.74	0.22	17.61	10.83	1.53	61205.00
26	13.87	11.44	51.69	0.34	17.39	10.68	1.54	61699.00
27	14.03	11.54	47.68	0.13	19.13	10.34	1.51	62889.00
28	14.04	10.82	47.75	0.14	18.50	10.39	1.50	62489.00
平均值	13.93	8.41	53.10	0.25	17.49	10.72	1.50	62283.46
最大值	15.09	13.24	62.26	0.48	19.13	11.17	1.60	64676.00
最小值	13.17	3.69	46.26	0.13	15.76	10.26	1.43	60645.00

備註： 1.*:儀器保養維護中。
 2.**:停爐中。

P003_樹林焚化廠CEMS系統月報表

報表日期: 2022年02月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	14.37	39.76	45.44	2.03	14.31	10.81	1.46	72726.00
2	14.65	27.75	49.61	2.34	14.68	10.19	1.43	71969.00
3	15.15	25.12	57.01	2.86	13.78	10.41	1.44	71013.00
4	14.48	11.75	59.55	2.44	15.12	10.48	1.49	72354.00
5	13.41	4.86	49.75	1.75	16.99	10.23	1.47	77790.00
6	13.04	3.14	50.11	1.60	16.25	10.49	1.45	76579.00
7	13.61	3.55	48.75	1.65	16.48	10.44	1.48	74126.00
8	13.74	7.34	47.68	1.96	16.19	10.17	1.46	74812.00
9	14.02	4.60	50.01	1.91	15.86	10.36	1.47	73992.00
10	13.86	3.52	53.69	2.27	15.92	10.65	1.46	75374.00
11	14.92	6.84	47.29	2.16	16.59	10.00	1.47	75713.00
12	14.35	4.27	54.38	2.41	16.24	10.20	1.46	75298.00
13	14.14	3.64	54.49	2.43	16.63	10.45	1.44	76491.00
14	14.97	5.10	54.24	2.50	15.74	10.69	1.42	76291.00
15	14.15	3.42	52.85	2.14	16.47	10.57	1.44	76624.00
16	14.89	4.11	52.58	2.19	16.60	10.56	1.43	74619.00
17	13.95	4.69	58.49	2.36	15.52	10.80	1.42	72139.00
18	14.12	4.62	55.08	2.38	15.61	10.83	1.43	73497.00
19	14.22	3.97	55.20	2.47	15.87	10.60	1.40	74356.00
20	14.02	3.62	55.13	2.15	15.58	10.62	1.37	74644.00
21	13.90	5.01	53.19	1.79	15.47	10.68	1.39	73573.00
22	13.76	5.45	51.56	2.26	15.98	10.72	1.40	74423.00
23	14.01	4.88	52.90	2.19	16.54	10.56	1.40	74789.00
24	13.99	4.83	54.35	2.01	15.87	10.53	1.41	74459.00
25	13.58	7.13	50.41	1.99	16.38	10.49	1.47	74297.00
26	14.54	3.53	58.38	2.31	16.32	10.51	1.47	74431.00
27	14.01	3.98	59.67	2.10	16.71	10.67	1.45	73021.00
28	14.09	4.81	55.60	2.00	16.50	10.22	1.47	73364.00
平均值	14.14	7.69	53.12	2.17	15.94	10.50	1.44	74384.43
最大值	15.15	39.76	59.67	2.86	16.99	10.83	1.49	77790.00
最小值	13.04	3.14	45.44	1.60	13.78	10.00	1.37	71013.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。