

P001_樹林焚化廠CEMS系統月報表

報表日期: 2020年03月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	5.54	1.95	92.47	8.86	15.89	11.59	1.14	88905.00
2	4.64	1.83	93.12	8.91	15.68	11.63	1.13	89487.00
3	5.05	4.24	71.50	8.84	15.34	11.63	1.18	89231.00
4	3.00	4.08	64.35	8.58	15.58	11.41	1.26	87676.00
5	3.49	3.80	85.34	8.48	14.48	11.43	1.47	82904.00
6	5.71	3.92	91.39	9.23	14.71	11.91	1.17	85880.00
7	9.99	2.71	93.13	9.43	14.48	11.73	1.10	89305.00
8	4.06	2.79	91.05	9.17	15.19	11.60	1.11	89218.00
9	5.24	4.03	88.00	9.11	15.13	11.54	1.12	89550.00
10	5.59	4.63	91.51	9.23	14.97	11.56	1.08	89851.00
11	6.75	4.67	90.09	8.94	14.13	11.59	1.09	89742.00
12	10.14	2.86	87.91	8.88	14.84	11.50	1.09	90568.00
13	10.13	3.77	88.57	8.98	14.62	11.65	1.05	88848.00
14	6.90	2.07	87.20	8.76	14.80	11.52	0.86	91246.00
15	4.84	2.40	85.72	8.61	14.57	11.46	0.05	91985.00
16	5.74	2.12	88.78	8.46	14.48	11.39	0.20	91464.00
17	3.80	5.10	88.64	8.42	14.78	11.23	0.65	82632.00
18	3.25	6.87	79.30	8.30	15.45	11.11	1.03	77772.00
19	6.72	3.65	85.39	8.85	14.94	11.46	0.94	87195.00
20	6.59	2.77	84.77	9.05	15.32	11.41	0.93	89794.00
21	5.01	5.36	82.19	9.05	14.85	11.39	1.01	86334.00
22	2.99	2.92	82.93	8.94	16.17	11.27	0.97	89780.00
23	6.24	4.05	86.70	9.26	15.18	11.34	0.99	90791.00
24	6.66	8.58	89.43	9.50	15.44	11.33	0.97	91062.00
25	5.25	4.16	83.64	9.04	15.37	11.48	0.98	89237.00
26	8.19	7.30	83.90	9.15	15.33	11.42	1.00	88901.00
27	4.46	5.86	83.08	8.94	15.60	11.37	0.95	87673.00
28	4.37	5.78	83.37	9.09	15.35	11.55	0.85	89959.00
29	2.86	5.43	82.39	8.83	15.30	11.48	0.86	90617.00
30	2.52	5.46	88.45	9.28	15.35	11.77	0.87	87318.00
31	3.08	6.42	85.49	9.20	15.23	11.60	0.87	89734.00
平均值	5.45	4.24	85.80	8.95	15.11	11.50	0.97	88537.39
最大值	10.14	8.58	93.13	9.50	16.17	11.91	1.47	91985.00
最小值	2.52	1.83	64.35	8.30	14.13	11.11	0.05	77772.00

備註: **停爐

P002_樹林焚化廠CEMS系統月報表

報表日期: 2020年03月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	2.83	3.95	81.60	5.05	14.66	12.10	0.51	71917.00
2	2.52	19.00	73.80	4.85	17.04	11.74	0.53	73339.00
3	2.02	26.23	86.77	5.07	16.83	12.23	0.55	69649.00
4	**	**	**	**	**	**	**	**
5	7.14	10.90	82.52	5.57	12.63	12.33	0.40	77403.00
6	2.85	3.91	84.89	5.14	13.02	12.40	0.44	73805.00
7	2.57	4.38	83.03	5.12	13.27	12.13	0.47	75259.00
8	1.78	7.21	80.23	5.03	13.80	11.99	0.45	75423.00
9	2.08	8.34	76.54	5.06	13.96	11.87	0.46	76012.00
10	2.29	9.41	80.12	5.28	13.62	12.03	0.42	75042.00
11	2.11	9.07	77.78	5.10	12.73	12.07	0.43	74775.00
12	2.98	7.27	75.36	4.91	13.80	11.91	0.44	74963.00
13	3.83	9.44	76.74	5.12	13.70	12.00	0.47	74718.00
14	2.46	7.02	75.98	5.01	13.38	12.01	0.47	75740.00
15	2.16	10.85	72.80	4.93	13.27	11.85	0.51	76555.00
16	2.97	9.37	72.31	4.87	13.10	11.85	0.52	76402.00
17	2.68	10.75	72.92	4.88	13.36	11.91	0.52	75538.00
18	2.63	15.04	72.47	4.93	14.11	11.88	0.50	74910.00
19	4.18	13.03	69.81	5.03	14.16	11.80	0.47	75224.00
20	3.06	17.25	79.86	5.14	14.53	11.76	0.49	76288.00
21	2.83	12.21	72.58	4.92	14.63	11.73	0.49	75791.00
22	2.09	21.45	69.56	5.04	15.30	11.58	0.46	75798.00
23	2.98	16.44	76.05	5.20	14.43	11.75	0.46	76160.00
24	2.37	16.33	78.06	5.01	14.89	11.74	0.46	75409.00
25	2.07	12.99	74.67	4.91	14.59	11.92	0.46	74242.00
26	5.82	22.14	78.41	4.95	14.63	11.59	0.49	75924.00
27	2.96	18.04	72.66	4.81	15.19	11.62	0.51	74638.00
28	3.91	15.87	78.15	4.87	14.29	11.78	0.52	74811.00
29	2.51	16.17	71.39	4.83	14.67	11.72	0.54	76666.00
30	2.14	19.97	67.87	4.91	15.53	11.61	0.53	76353.00
31	2.50	34.21	70.48	5.38	15.15	11.70	0.53	75650.00
平均值	2.91	13.61	76.18	5.03	14.28	11.89	0.48	75146.80
最大值	7.14	34.21	86.77	5.57	17.04	12.40	0.55	77403.00
最小值	1.78	3.91	67.87	4.81	12.63	11.58	0.40	69649.00

備註: **停爐

P003_樹林焚化廠CEMS系統月報表

報表日期: 2020年03月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	1.93	3.81	75.04	8.13	14.14	12.12	1.49	88905.00
2	1.97	4.10	81.55	8.41	13.72	12.11	1.46	89487.00
3	1.98	12.00	73.32	8.60	12.79	12.44	1.52	89231.00
4	2.10	14.96	62.56	7.92	13.30	11.97	1.51	87676.00
5	2.66	8.52	76.28	8.47	12.78	12.01	1.47	82904.00
6	2.37	21.25	66.68	8.40	12.75	11.92	1.54	85880.00
7	2.92	22.07	64.83	8.18	12.88	11.79	1.58	89305.00
8	1.97	13.81	62.90	7.81	13.66	11.62	1.56	89218.00
9	1.98	15.62	64.96	7.79	13.61	11.67	1.54	89550.00
10	1.82	12.38	73.01	8.16	13.24	11.93	1.47	89851.00
11	1.71	17.16	70.38	8.13	12.36	11.98	1.48	89742.00
12	2.19	33.48	69.29	8.03	12.87	11.84	1.50	90568.00
13	2.56	19.54	66.70	7.82	13.24	11.80	1.50	88848.00
14	2.11	22.14	62.76	7.93	12.92	11.80	1.47	91246.00
15	1.85	15.48	63.13	7.73	13.07	11.70	1.48	91985.00
16	2.35	20.26	67.39	7.66	12.77	11.69	1.51	91464.00
17	2.83	24.43	72.44	8.25	11.97	12.17	1.52	82632.00
18	2.95	16.39	68.02	8.02	12.98	12.04	1.50	77772.00
19	2.62	20.06	68.10	8.25	12.71	12.11	1.48	87195.00
20	3.22	18.55	70.49	7.98	13.43	11.86	1.51	89794.00
21	3.23	17.41	66.36	8.08	12.96	11.84	1.50	86334.00
22	2.28	15.54	69.12	8.16	13.51	11.81	1.48	89780.00
23	3.20	21.09	68.18	8.29	12.67	11.82	1.41	90791.00
24	3.23	20.97	77.82	8.50	13.05	11.92	1.42	91062.00
25	3.16	9.49	71.11	8.14	13.21	11.88	1.41	89237.00
26	3.81	24.14	77.73	9.25	12.85	12.11	1.45	88901.00
27	3.39	17.11	74.25	8.70	12.99	12.28	1.42	87673.00
28	3.73	12.14	72.60	8.60	12.34	12.14	1.36	89959.00
29	2.63	13.49	73.86	8.73	12.58	12.25	1.40	90617.00
30	2.21	16.78	74.51	8.68	12.79	12.09	1.46	87318.00
31	2.29	19.52	65.73	8.63	12.73	11.72	1.47	89734.00
平均值	2.56	16.89	70.04	8.24	13.00	11.95	1.48	88537.39
最大值	3.81	33.48	81.55	9.25	14.14	12.44	1.58	91985.00
最小值	1.71	3.81	62.56	7.66	11.97	11.62	1.36	77772.00

備註: **停爐