

P001_樹林焚化廠CEMS系統月報表

報表日期: 2021年10月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	13.29	8.96	79.88	1.24	17.09	11.05	1.39	68378.00
2	14.80	10.49	82.42	1.58	16.80	11.05	1.39	68377.00
3	15.36	9.22	85.85	1.73	16.24	11.15	1.37	68515.00
4	16.01	11.40	88.16	1.63	16.86	11.22	1.36	67219.00
5	14.43	7.84	93.81	1.66	16.67	11.34	1.37	66185.00
6	15.16	14.14	83.51	0.98	17.42	11.18	1.32	66885.00
7	14.16	12.05	95.03	1.36	15.96	11.81	1.33	63996.00
8	14.48	16.85	72.52	1.43	16.91	11.14	1.32	66548.00
9	14.12	11.50	81.17	1.34	17.57	11.08	1.29	67168.00
10	15.28	11.99	92.08	1.26	17.67	11.00	1.27	68503.00
11	14.44	5.54	100.86	1.25	18.22	11.10	1.26	67835.00
12	10.73	11.27	84.05	0.69	19.08	11.25	1.27	69234.00
13	14.39	9.65	86.89	1.06	18.17	11.02	1.29	69120.00
14	16.40	7.17	92.48	0.99	18.49	10.99	1.29	69861.00
15	13.59	8.38	80.42	0.91	19.26	10.98	1.28	69634.00
16	15.87	16.30	81.93	1.43	16.69	11.36	1.24	67616.00
17	15.65	20.10	82.57	2.85	16.21	11.59	1.23	65751.00
18	15.72	8.38	95.05	1.02	17.59	10.96	1.22	69898.00
19	12.51	17.31	79.39	2.05	17.07	11.25	1.24	68186.00
20	14.32	24.97	77.45	4.32	16.95	11.20	1.25	68934.00
21	14.86	12.85	77.97	3.00	17.35	10.99	1.33	69814.00
22	13.16	16.52	76.92	2.50	17.69	10.87	1.32	70094.00
23	13.75	8.74	78.75	3.71	16.54	11.26	1.35	69112.00
24	15.09	13.48	72.94	3.59	16.32	11.23	1.35	69126.00
25	15.53	6.27	85.63	3.02	16.94	11.04	1.42	69882.00
26	12.83	7.23	80.51	2.70	17.64	10.97	1.37	70505.00
27	17.91	17.98	89.24	4.07	17.47	11.18	1.39	68620.00
28	18.62	16.01	75.07	1.43	18.19	11.00	1.41	69795.00
29	17.16	20.36	77.59	1.43	17.01	11.31	1.11	68687.00
30	15.73	14.41	77.29	1.55	16.31	11.60	1.18	68094.00
31	15.60	5.82	82.36	1.45	16.51	11.44	1.14	69408.00
平均值	14.87	12.36	83.54	1.91	17.25	11.18	1.30	68418.71
最大值	18.62	24.97	100.86	4.32	19.26	11.81	1.42	70505.00
最小值	10.73	5.54	72.52	0.69	15.96	10.87	1.11	63996.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P002_樹林焚化廠CEMS系統月報表

報表日期: 2021年10月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	13.82	4.73	91.05	0.18	17.73	10.88	1.39	62005.00
2	14.06	8.78	89.62	0.36	16.55	10.99	1.41	60574.00
3	13.72	3.07	93.93	0.35	16.89	10.83	1.42	61206.00
4	16.76	4.12	95.42	0.36	16.94	11.12	1.46	60776.00
5	17.85	6.47	90.92	1.13	16.64	11.41	1.40	65307.00
6	15.77	8.04	90.64	1.20	17.06	11.23	1.38	59348.00
7	12.46	4.85	91.44	0.43	16.74	11.03	1.39	60684.00
8	12.68	10.90	89.78	0.69	16.97	10.80	1.39	60102.00
9	10.03	7.27	88.43	0.85	16.99	10.85	1.38	60550.00
10	11.02	4.97	86.57	0.48	17.59	10.82	1.35	61459.00
11	14.58	5.13	96.50	0.71	18.48	11.56	1.29	59294.00
12	15.42	9.69	78.17	0.77	19.59	11.44	1.32	60883.00
13	14.36	4.91	97.91	0.63	18.79	11.61	1.33	60547.00
14	13.95	2.65	91.85	0.34	19.29	11.19	1.33	62640.00
15	12.99	7.41	87.03	0.26	18.39	10.67	1.38	62917.00
16	11.22	8.22	92.71	0.38	16.79	11.21	1.39	60630.00
17	16.88	15.73	92.20	2.48	15.88	11.53	1.44	59596.00
18	15.98	4.62	96.15	0.59	17.50	10.93	1.39	63413.00
19	11.12	3.77	93.87	0.18	17.94	11.13	1.36	61651.00
20	15.32	11.06	91.32	0.69	17.00	11.31	1.34	61196.00
21	14.83	5.03	90.83	0.21	17.92	10.80	1.36	63277.00
22	12.72	11.46	93.62	0.59	17.82	10.61	1.39	64489.00
23	15.32	8.36	88.05	1.50	16.93	10.96	1.42	62475.00
24	15.18	8.63	83.28	0.73	16.46	10.93	1.44	62760.00
25	14.29	7.55	75.50	0.29	17.84	10.24	1.43	64485.00
26	13.18	3.46	78.67	0.14	19.19	10.38	1.42	64633.00
27	15.03	9.28	86.76	0.99	17.91	10.84	1.40	62153.00
28	17.52	9.33	84.33	0.25	18.35	10.67	1.44	63681.00
29	16.02	10.49	84.58	0.35	17.29	10.95	1.41	63185.00
30	16.83	7.03	80.22	0.35	17.02	11.14	1.41	61851.00
31	15.19	8.27	82.41	0.19	18.32	10.29	1.42	64430.00
平均值	14.39	7.27	88.83	0.60	17.57	10.98	1.39	62006.35
最大值	17.85	15.73	97.91	2.48	19.59	11.61	1.46	65307.00
最小值	10.03	2.65	75.50	0.14	15.88	10.24	1.29	59294.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P003_樹林焚化廠CEMS系統月報表

報表日期: 2021年10月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	15.24	14.26	71.04	2.50	18.32	10.26	1.34	81035.00
2	15.57	19.07	72.55	2.94	17.81	10.33	1.34	79118.00
3	14.11	14.87	68.72	3.05	18.00	10.16	1.31	78507.00
4	15.27	15.79	65.20	2.82	18.07	10.16	1.30	77959.00
5	14.69	18.47	72.95	3.38	17.95	10.32	1.29	77270.00
6	13.96	25.74	67.61	2.67	18.63	10.78	1.26	75965.00
7	15.11	17.84	63.37	2.43	18.03	10.32	1.23	78652.00
8	12.82	21.45	62.30	3.09	18.80	10.21	1.24	78889.00
9	12.98	12.77	65.88	3.34	18.05	10.41	1.24	78826.00
10	13.01	19.69	64.51	3.78	18.43	10.28	1.24	80696.00
11	12.61	13.50	67.63	2.90	18.93	10.32	1.26	80497.00
12	13.66	17.83	73.32	2.59	19.29	10.59	1.30	83963.00
13	16.65	20.80	59.89	6.24	19.05	10.00	1.34	81466.00
14	12.49	11.72	73.03	2.45	19.07	10.05	1.34	80887.00
15	12.91	20.29	67.74	3.05	18.26	10.16	1.34	79767.00
16	17.08	24.88	72.75	4.23	17.62	10.03	1.34	79984.00
17	15.77	20.48	67.93	3.87	7.97	10.18	1.37	79681.00
18	15.62	16.71	68.79	3.89	19.35	9.26	1.42	79225.00
19	12.63	17.51	67.99	2.48	19.06	9.71	1.40	79488.00
20	15.65	15.36	75.16	4.06	16.92	10.48	1.39	77806.00
21	15.91	8.17	73.61	2.76	18.26	10.13	1.39	81617.00
22	14.00	11.93	66.52	2.52	18.06	10.24	1.36	81127.00
23	13.68	10.56	60.87	2.65	18.61	9.99	1.38	79999.00
24	14.96	10.39	62.81	2.67	17.97	10.33	1.53	80357.00
25	**	**	**	**	**	**	**	**
26	14.25	16.01	96.13	4.21	16.47	10.61	1.37	76628.00
27	14.43	16.76	95.37	4.14	16.20	10.97	1.44	75587.00
28	15.94	9.71	93.08	3.10	15.82	10.98	1.40	76242.00
29	15.73	12.03	94.58	3.21	15.93	10.90	1.40	77894.00
30	14.34	8.12	93.89	3.40	15.55	11.16	1.39	76705.00
31	15.05	7.41	87.71	3.33	15.41	10.78	1.34	81035.00
平均值	14.54	15.67	73.10	3.26	17.53	10.34	1.34	79229.07
最大值	17.08	25.74	96.13	6.24	19.35	11.16	1.53	83963.00
最小值	12.49	7.41	59.89	2.43	7.97	9.26	1.23	75587.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。