

P001_樹林焚化廠CEMS系統月報表

報表日期: 2020年07月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm ³ /Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	13.73	8.46	98.00	12.27	14.98	11.42	0.55	98317.00
2	10.25	11.98	86.81	11.45	15.00	11.29	0.54	99812.00
3	11.22	10.75	85.05	11.87	14.98	11.20	0.53	99883.00
4	12.26	10.88	89.34	11.76	14.32	11.55	0.51	98654.00
5	12.59	6.63	84.34	11.17	15.31	11.15	0.48	103273.00
6	7.86	5.12	88.98	10.37	15.62	11.22	0.48	101431.00
7	12.56	12.97	80.19	10.64	15.37	11.24	0.47	100854.00
8	9.92	7.82	83.08	10.40	15.67	11.10	0.46	101969.00
9	15.54	18.70	94.35	10.36	14.12	12.95	0.46	81587.00
10	7.15	10.00	83.25	10.37	15.20	11.34	0.43	102292.00
11	6.89	15.16	81.18	10.42	15.00	11.33	0.47	101026.00
12	9.19	7.89	80.72	10.58	15.09	11.28	0.52	101045.00
13	7.40	8.77	80.40	10.40	15.56	11.08	0.53	102389.00
14	8.67	13.57	83.67	10.70	14.96	11.33	0.50	101828.00
15	11.52	15.33	81.43	10.76	14.97	11.27	0.50	102139.00
16	12.96	12.83	81.45	10.83	14.54	11.14	0.50	102011.00
17	7.85	10.60	82.97	10.53	14.76	11.29	0.51	102651.00
18	7.31	19.48	80.57	11.15	14.74	11.14	0.52	101144.00
19	9.34	12.95	84.21	11.00	14.47	11.30	0.46	101386.00
20	8.23	4.50	81.92	10.82	14.30	11.37	0.47	102034.00
21	9.53	9.26	81.27	10.43	14.25	11.17	0.49	102787.00
22	9.81	13.72	81.78	10.77	15.12	11.00	0.48	104638.00
23	8.87	10.50	80.46	10.59	15.30	10.89	0.48	106352.00
24	10.06	9.87	79.48	11.03	15.14	10.91	0.48	106674.00
25	10.39	14.73	81.35	11.23	14.54	10.93	0.47	104898.00
26	9.15	11.44	78.91	10.73	14.94	10.82	0.48	105565.00
27	5.79	7.27	77.74	8.69	15.02	11.18	0.63	102822.00
28	8.04	7.15	62.34	6.21	15.08	11.39	0.82	103186.00
29	11.09	9.76	59.23	6.19	15.25	11.22	0.83	104788.00
30	12.30	10.15	64.81	6.68	14.08	11.15	0.88	107307.00
31	11.05	9.28	67.68	6.82	14.02	11.44	0.86	105339.00
平均值	9.95	10.89	80.87	10.23	14.89	11.26	0.54	101938.10
最大值	15.54	19.48	98.00	12.27	15.67	12.95	0.88	107307.00
最小值	5.79	4.50	59.23	6.19	14.02	10.82	0.43	81587.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P002_樹林焚化廠CEMS系統月報表

報表日期: 2020年07月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	4.14	14.47	94.48	5.16	14.25	11.91	0.49	75836.00
2	3.86	11.01	83.64	5.01	14.22	11.80	0.46	77420.00
3	4.45	11.03	85.07	5.27	13.96	11.89	0.43	77053.00
4	5.18	14.34	85.78	5.35	13.65	12.06	0.45	75289.00
5	5.79	9.75	81.00	5.18	14.18	11.71	0.44	77413.00
6	4.45	7.18	79.63	4.83	14.45	11.69	0.44	77665.00
7	4.01	10.62	78.04	5.13	14.59	11.78	0.42	76271.00
8	9.57	15.39	84.35	5.34	14.06	11.78	0.39	76970.00
9	6.55	10.31	88.24	5.11	13.31	11.94	0.38	76560.00
10	7.23	21.42	76.88	4.42	14.26	13.43	0.39	62726.00
11	5.31	17.47	73.21	4.46	14.21	12.58	0.42	69079.00
12	4.80	16.12	82.25	5.11	14.05	11.79	0.43	76920.00
13	3.95	9.00	77.13	4.90	14.36	11.64	0.43	76897.00
14	4.88	10.73	81.08	5.04	14.20	11.77	0.38	77731.00
15	6.82	14.72	84.43	5.32	13.33	11.91	0.44	76681.00
16	7.82	9.25	78.69	5.15	13.63	11.69	0.43	77849.00
17	5.75	10.80	80.37	5.12	13.42	11.91	0.43	76805.00
18	7.13	10.84	85.79	5.20	13.40	11.77	0.43	77668.00
19	10.07	12.25	85.07	5.51	13.25	11.79	0.40	77509.00
20	8.57	7.00	83.92	5.13	13.34	11.70	0.40	77771.00
21	2.95	9.67	83.52	4.95	13.24	11.95	0.40	76470.00
22	3.24	16.64	76.29	4.94	13.84	11.59	0.50	76349.00
23	3.01	10.80	82.88	5.11	13.96	11.75	0.37	79714.00
24	4.48	15.39	80.18	5.18	13.61	11.79	0.39	79537.00
25	5.77	20.69	83.64	5.20	13.36	11.63	0.40	80263.00
26	3.89	12.72	84.70	5.06	13.38	11.81	0.37	79545.00
27	2.69	4.24	83.57	5.02	13.54	11.83	0.53	78939.00
28	2.59	8.18	82.78	4.91	14.29	11.78	0.70	79031.00
29	4.72	11.88	74.65	4.84	14.64	11.47	0.73	80734.00
30	4.63	13.69	85.24	5.14	13.31	11.55	0.77	82020.00
31	3.08	9.58	86.10	4.76	13.43	11.72	0.64	80561.00
平均值	5.21	12.17	82.34	5.06	13.83	11.85	0.46	77137.94
最大值	10.07	21.42	94.48	5.51	14.64	13.43	0.77	82020.00
最小值	2.59	4.24	73.21	4.42	13.24	11.47	0.37	62726.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P003_樹林焚化廠CEMS系統月報表

報表日期: 2020年07月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	23.94	23.39	104.56	9.98	17.97	10.04	1.49	92404.00
2	22.75	21.48	104.26	9.98	17.33	10.29	1.49	93560.00
3	16.31	20.04	96.30	9.82	18.64	9.39	1.47	88512.00
4	17.72	25.29	92.20	9.42	18.36	9.32	1.43	81938.00
5	14.54	13.70	85.25	8.48	19.07	9.03	1.41	86013.00
6	11.41	12.01	81.44	8.18	19.74	8.77	1.40	84309.00
7	13.96	17.82	82.22	8.15	19.17	9.04	1.44	82096.00
8	15.28	39.37	75.95	8.83	18.90	8.88	1.41	80494.00
9	16.65	15.94	78.38	8.60	18.26	8.91	1.40	80753.00
10	12.66	18.23	84.80	7.90	19.30	9.07	1.50	86174.00
11	8.02	26.33	73.02	7.44	19.09	8.68	1.68	83891.00
12	15.03	25.38	77.01	9.02	18.80	8.80	1.38	84416.00
13	14.04	22.69	75.52	10.44	19.10	8.68	1.38	85940.00
14	18.29	25.98	89.86	8.75	18.53	9.37	1.39	88025.00
15	20.89	28.04	95.00	9.73	17.88	9.55	1.38	87280.00
16	15.51	15.24	90.13	8.45	18.62	9.05	1.37	87647.00
17	14.35	26.97	89.63	8.70	18.12	9.17	1.38	86763.00
18	14.46	26.80	90.03	8.85	18.03	9.15	1.40	88266.00
19	15.23	25.00	88.35	9.93	18.15	9.17	1.39	87221.00
20	14.37	16.81	83.93	8.95	17.86	9.14	1.37	85204.00
21	19.07	25.16	92.31	8.60	16.84	10.03	1.43	86765.00
22	19.51	24.10	85.76	9.36	18.19	8.90	1.44	88654.00
23	16.13	14.31	90.80	9.65	19.09	8.96	1.41	91880.00
24	17.96	18.50	90.59	10.29	18.28	9.17	1.43	89063.00
25	15.08	22.07	93.85	10.42	17.56	9.18	1.43	87644.00
26	17.13	10.42	87.75	10.16	18.31	8.86	1.41	86980.00
27	12.23	18.00	83.38	9.24	18.57	8.64	1.28	84814.00
28	12.96	16.88	85.70	8.19	18.92	9.09	1.19	88899.00
29	16.35	19.16	75.02	8.12	19.41	8.41	1.22	87910.00
30	20.22	12.79	85.40	9.02	17.99	8.70	1.24	91774.00
31	23.31	14.13	87.90	9.23	18.16	8.97	1.26	92311.00
平均值	16.30	20.71	86.98	9.09	18.46	9.11	1.40	87019.35
最大值	23.94	39.37	104.56	10.44	19.74	10.29	1.68	93560.00
最小值	8.02	10.42	73.02	7.44	16.84	8.41	1.19	80494.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。