

P001_樹林焚化廠CEMS系統月報表

報表日期: 2025年8月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	7.92	9.99	59.88	2.18	15.62	11.73	1.28	75905.00
2	6.73	9.13	60.54	2.79	15.48	11.86	1.26	69696.00
3	6.06	9.04	60.57	3.08	15.11	11.99	1.26	69347.00
4	4.19	9.12	57.73	3.29	14.38	11.98	1.26	68943.00
5	7.18	7.63	54.54	2.89	14.72	11.97	1.24	70255.00
6	7.72	7.50	56.24	2.49	14.87	12.08	1.24	69386.00
7	8.18	9.81	55.49	2.54	14.54	11.98	1.25	68739.00
8	6.68	8.95	60.04	2.70	15.06	11.96	1.26	69647.00
9	7.49	9.04	58.01	2.62	14.88	11.94	1.26	69935.00
10	7.99	9.97	59.30	2.43	15.59	11.72	1.26	70815.00
11	8.03	9.22	55.76	2.64	14.78	11.98	1.24	70053.00
12	6.92	9.21	56.97	2.28	15.41	11.77	1.25	70696.00
13	7.85	8.44	57.64	2.80	14.63	11.86	1.22	71553.00
14	6.84	11.09	62.04	2.77	14.11	12.03	1.23	70359.00
15	5.92	10.43	58.04	3.01	14.31	12.12	1.25	69463.00
16	6.00	9.63	60.02	3.10	13.27	12.47	1.24	67134.00
17	4.11	9.88	59.58	3.10	14.33	12.18	1.24	68904.00
18	6.45	9.78	57.83	2.78	14.19	12.14	1.24	68744.00
19	6.83	8.99	59.00	2.65	14.89	11.88	1.25	69791.00
20	6.04	9.80	59.54	2.91	13.70	12.13	1.25	67735.00
21	7.73	9.45	56.77	2.79	14.00	12.12	1.27	68661.00
22	7.47	8.18	57.90	2.82	14.50	11.97	1.26	69854.00
23	7.30	10.30	57.81	2.89	14.19	12.10	1.27	69264.00
24	7.26	9.97	58.89	3.05	14.26	12.01	1.26	69294.00
25	4.93	9.50	59.76	2.99	13.93	11.89	1.25	70663.00
26	6.63	9.57	58.94	3.22	14.11	11.94	1.23	70620.00
27	9.33	9.34	56.58	2.84	14.00	12.05	1.22	70086.00
28	8.75	9.48	57.49	2.54	13.62	12.20	1.21	68543.00
29	9.13	9.66	57.50	2.43	14.44	11.93	1.20	70086.00
30	8.26	10.86	55.75	2.59	14.12	12.06	1.20	69068.00
31	7.33	10.22	55.34	2.37	14.83	11.97	1.21	68507.00
平均 值	7.07	9.46	58.11	2.76	14.51	12.00	1.24	69733.74
最 大 值	9.33	11.09	62.04	3.29	15.62	12.47	1.28	75905.00
最 小 值	4.11	7.50	54.54	2.18	13.27	11.72	1.20	67134.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P002_樹林焚化廠CEMS系統月報表

報表日期: 2025年8月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	7.77	8.91	58.34	2.35	17.06	10.73	0.99	81029.00
2	8.12	8.77	59.07	2.40	17.16	10.86	1.00	81393.00
3	7.98	8.57	54.70	2.57	17.72	10.70	0.99	82289.00
4	4.96	8.41	49.59	2.35	17.21	10.56	0.96	80441.00
5	6.74	7.83	55.73	2.37	17.03	10.89	0.97	81038.00
6	8.28	7.65	55.91	2.72	16.76	10.96	0.96	80003.00
7	8.98	8.26	52.34	2.38	17.12	10.71	0.99	81117.00
8	8.21	9.48	55.67	2.81	16.98	10.80	1.00	79746.00
9	8.85	8.98	55.75	2.68	16.64	11.11	1.03	79989.00
10	8.76	8.90	56.26	2.52	16.78	11.03	1.02	80643.00
11	8.86	7.98	55.25	2.17	16.87	10.78	1.00	80590.00
12	8.51	8.91	57.49	2.37	17.06	10.86	1.01	81143.00
13	8.88	8.00	54.30	2.18	16.18	10.97	1.03	81796.00
14	8.94	9.39	57.99	2.84	15.78	10.83	1.04	80502.00
15	7.47	9.57	56.60	3.16	15.68	11.10	1.02	80526.00
16	3.78	10.09	59.08	2.65	15.05	11.26	1.03	78455.00
17	4.04	9.83	59.48	2.86	15.47	11.22	1.04	79006.00
18	5.28	9.08	58.86	2.45	15.84	11.15	1.06	80013.00
19	6.83	8.59	58.71	2.30	15.78	11.29	1.06	78716.00
20	8.05	9.94	58.59	2.40	15.06	11.32	1.03	78515.00
21	5.47	9.62	53.99	2.09	15.79	11.08	1.01	77940.00
22	2.67	7.62	52.83	2.12	16.01	11.02	0.96	78566.00
23	2.16	8.84	56.75	2.31	16.13	10.93	0.98	78638.00
24	3.51	9.28	52.65	1.76	16.72	10.66	0.97	78798.00
25	0.34	9.67	57.22	2.28	15.74	10.72	0.97	79576.00
26	0.27	8.77	56.34	2.54	15.54	10.98	0.95	78344.00
27	1.72	9.44	57.43	2.77	15.40	11.31	0.94	77813.00
28	2.67	8.90	56.35	2.47	15.69	11.15	0.96	78929.00
29	2.17	8.68	53.74	2.68	16.35	11.01	0.96	79194.00
30	2.32	9.98	59.22	2.82	14.80	11.52	0.93	77207.00
31	1.77	11.19	55.10	2.89	15.26	11.54	0.94	77691.00
平均值	5.62	9.00	56.17	2.49	16.21	11.00	0.99	79666.00
最大值	8.98	11.19	59.48	3.16	17.72	11.54	1.06	82289.00
最小值	0.27	7.62	49.59	1.76	14.80	10.56	0.93	77207.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P003_樹林焚化廠CEMS系統月報表

報表日期: 2025年8月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	4.27	8.56	58.37	2.23	17.88	9.43	1.46	77266.00
2	8.04	8.03	60.22	2.59	17.58	9.68	1.46	77801.00
3	5.11	8.12	57.31	2.45	17.64	9.40	1.48	77871.00
4	3.41	8.01	57.94	1.80	17.62	9.71	1.45	77635.00
5	5.39	8.12	55.17	2.00	18.10	9.58	1.42	77619.00
6	5.44	8.18	56.63	2.60	17.04	9.72	1.41	74234.00
7	5.26	9.49	55.17	2.15	17.58	9.23	1.42	74978.00
8	5.24	9.47	53.90	1.81	17.67	9.39	1.45	76065.00
9	8.50	8.55	58.53	2.28	16.53	9.83	1.45	74234.00
10	8.28	8.86	56.12	2.30	16.94	9.74	1.43	75508.00
11	8.98	8.07	54.46	2.18	17.11	9.69	1.44	76878.00
12	8.15	8.59	56.67	2.09	16.78	9.91	1.40	76619.00
13	7.55	7.99	58.99	2.29	16.03	9.94	1.40	76885.00
14	6.81	9.79	62.42	2.15	15.36	9.78	1.42	75100.00
15	3.45	9.56	58.70	3.38	15.58	9.97	1.40	75711.00
16	4.00	8.46	52.83	2.64	15.46	9.86	1.40	73150.00
17	4.42	8.94	57.52	2.95	16.12	9.69	1.42	76029.00
18	2.39	8.96	59.52	3.01	16.52	9.45	1.45	76650.00
19	2.62	8.65	59.72	3.04	16.09	9.92	1.47	76177.00
20	2.52	8.27	56.44	3.18	15.66	9.65	1.45	73200.00
21	6.25	6.71	57.62	2.62	16.17	9.56	1.46	74118.00
22	6.08	8.68	58.12	2.94	16.28	9.68	1.43	75566.00
23	6.54	9.00	57.07	2.89	15.88	9.84	1.39	74564.00
24	5.48	9.11	54.75	2.85	17.21	9.16	1.38	74976.00
25	2.45	8.84	58.27	2.92	16.42	9.11	1.36	76591.00
26	1.57	9.02	60.14	3.45	16.62	9.22	1.38	77118.00
27	3.99	9.04	57.77	3.35	15.61	9.79	1.41	75287.00
28	5.50	9.17	58.03	2.75	15.16	9.81	1.41	73402.00
29	5.31	7.92	57.94	3.48	15.64	9.88	1.39	76177.00
30	7.32	9.17	58.80	2.56	15.33	9.95	1.37	74823.00
31	6.46	9.43	58.42	2.71	15.61	10.31	1.37	77266.00
平均 值	5.38	8.67	57.53	2.63	16.49	9.67	1.42	75790.26
最 大 值	8.98	9.79	62.42	3.48	18.10	10.31	1.48	77871.00
最 小 值	1.57	6.71	52.83	1.80	15.16	9.11	1.36	73150.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。