

P001_樹林焚化廠CEMS系統月報表

報表日期: 2026年6月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	9.25	11.99	54.43	2.35	15.86	11.45	1.23	81012.00
2	8.98	12.38	53.16	2.03	17.26	11.01	1.22	83266.00
3	7.61	12.38	54.91	2.64	16.31	11.20	1.23	82838.00
4	9.08	11.65	55.72	2.31	16.61	11.39	1.22	81048.00
5	8.95	12.36	55.89	2.18	17.46	11.25	1.20	81505.00
6	9.18	11.58	55.78	2.19	18.73	10.71	1.21	85145.00
7	8.31	12.79	49.51	2.67	17.99	11.17	1.20	80929.00
8	9.28	13.63	55.51	2.50	17.56	11.28	1.21	81180.00
9	8.48	12.40	56.84	2.02	18.09	11.08	1.19	82263.00
10	7.93	12.38	52.03	1.98	18.41	10.91	1.21	83528.00
11	8.62	12.79	54.78	2.52	17.83	11.04	1.25	83778.00
12	9.19	12.56	52.84	2.05	17.82	11.07	1.21	83349.00
13	8.53	12.66	53.58	1.91	18.75	10.92	1.23	83459.00
14	9.05	12.41	53.77	1.84	18.99	10.64	1.25	85257.00
15	8.92	13.06	56.09	2.03	17.84	11.09	1.23	82604.00
16	9.27	12.82	55.85	2.44	17.70	11.14	1.24	82437.00
17	9.50	12.06	58.02	1.94	16.97	11.29	1.24	81840.00
18	9.32	12.44	57.33	2.19	17.18	11.30	1.25	81452.00
19	9.50	12.61	55.70	1.99	18.31	11.03	1.21	82495.00
20	9.12	12.41	55.56	1.90	18.24	10.99	1.24	82598.00
21	10.31	12.00	52.70	2.19	17.52	11.23	1.25	81622.00
22	9.39	13.03	49.64	1.99	17.48	11.15	1.25	82221.00
23	9.45	12.73	52.36	2.91	17.84	11.08	1.24	82284.00
24	9.32	13.02	55.40	2.50	17.27	11.35	1.21	81266.00
25	8.78	12.61	55.48	2.05	17.87	11.17	1.19	81826.00
26	9.31	13.01	52.74	2.26	17.93	11.09	1.21	82570.00
27	9.42	12.55	52.47	2.23	18.13	11.07	1.21	82499.00
28	8.71	13.07	53.16	2.19	18.23	11.29	1.18	80117.00
29	8.35	12.66	53.37	2.34	18.85	10.91	1.20	83007.00
30	9.22	12.59	49.66	2.49	17.85	11.17	1.20	81994.00
平 均 值	9.01	12.55	54.14	2.23	17.76	11.12	1.22	82379.63
最 大 值	10.31	13.63	58.02	2.91	18.99	11.45	1.25	85257.00
最 小 值	7.61	11.58	49.51	1.84	15.86	10.64	1.18	80117.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P002_樹林焚化廠CEMS系統月報表

報表日期: 2026年6月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	7.29	12.24	52.59	1.30	17.24	10.44	0.98	78359.00
2	2.51	12.36	51.88	1.38	18.00	10.45	0.98	79919.00
3	0.35	12.53	55.56	1.89	17.06	10.69	1.00	80307.00
4	0.32	12.15	51.97	1.19	18.00	10.59	1.01	79766.00
5	1.65	12.58	54.14	1.48	18.42	10.67	0.99	82438.00
6	0.62	12.40	55.49	1.56	18.82	10.83	1.00	81794.00
7	0.99	12.20	55.15	1.33	18.79	10.76	0.98	82353.00
8	0.95	12.25	53.61	1.01	18.51	10.68	0.97	82046.00
9	1.83	12.62	52.33	1.24	18.84	10.58	0.95	83484.00
10	6.32	12.42	52.93	1.48	18.49	10.69	0.97	83021.00
11	7.20	12.65	50.14	1.13	17.99	10.88	0.97	82444.00
12	5.48	12.61	56.77	1.30	18.35	10.90	0.99	83332.00
13	9.80	12.71	51.06	1.31	18.58	10.88	1.00	83009.00
14	7.94	12.61	51.17	1.36	19.05	10.73	0.98	83503.00
15	9.91	12.28	50.70	1.72	18.28	10.76	0.97	83576.00
16	9.18	12.30	50.48	1.65	18.79	10.57	0.93	84921.00
17	7.71	12.37	53.58	1.83	18.27	10.77	0.93	83956.00
18	8.68	12.50	49.52	1.26	18.57	10.86	0.94	83003.00
19	9.61	12.87	48.76	1.27	19.99	10.55	0.98	84117.00
20	10.06	12.45	49.06	1.50	19.34	10.57	1.00	83773.00
21	9.88	12.48	49.77	1.82	19.33	10.57	1.02	83738.00
22	7.63	12.40	49.68	1.40	18.90	10.63	1.03	83861.00
23	8.27	12.50	52.26	1.62	18.78	10.79	1.03	82618.00
24	7.52	12.80	50.41	2.17	18.32	10.90	1.01	81850.00
25	7.90	12.71	53.65	1.15	18.67	10.84	0.97	81937.00
26	5.61	12.67	50.72	1.29	18.91	10.85	0.96	82100.00
27	1.24	12.72	51.85	1.08	18.68	10.80	0.97	82789.00
28	3.35	13.37	50.77	1.32	19.06	11.12	0.97	80337.00
29	2.07	12.47	49.76	0.61	19.52	10.76	0.94	82806.00
30	4.48	12.84	51.51	1.34	18.39	11.15	0.96	81355.00
平 均 值	5.55	12.54	51.91	1.40	18.60	10.74	0.98	82417.07
最 大 值	10.06	13.37	56.77	2.17	19.99	11.15	1.03	84921.00
最 小 值	0.32	12.15	48.76	0.61	17.06	10.44	0.93	78359.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P003_樹林焚化廠CEMS系統月報表

報表日期: 2026年6月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	9.37	11.22	52.37	2.00	17.94	8.86	1.35	74962.00
2	7.74	11.54	47.78	2.73	18.66	9.62	1.33	75508.00
3	8.68	10.75	47.33	2.88	18.08	9.38	1.32	74158.00
4	5.37	11.47	47.75	2.64	18.48	9.32	1.34	73701.00
5	5.64	11.47	50.89	2.35	19.41	9.19	1.40	76877.00
6	5.22	11.55	54.30	2.76	18.98	9.65	1.38	75928.00
7	4.88	13.01	52.38	2.79	19.60	9.55	1.38	74925.00
8	3.97	12.08	52.09	2.88	19.35	9.39	1.36	74186.00
9	6.68	11.96	50.03	2.52	19.59	9.27	1.34	76182.00
10	5.22	11.80	48.56	2.27	19.81	8.97	1.31	75962.00
11	5.12	11.38	49.28	2.59	19.15	9.01	1.34	75227.00
12	6.62	11.81	51.58	2.19	19.34	9.11	1.34	75364.00
13	5.63	11.46	54.37	2.62	19.81	9.00	1.34	75673.00
14	5.46	12.02	52.51	2.26	19.67	9.58	1.33	76833.00
15	6.39	10.64	51.21	3.09	19.27	9.20	1.29	76339.00
16	5.81	11.18	51.26	2.48	19.10	9.24	1.28	74303.00
17	7.29	11.19	54.99	2.66	18.35	9.37	1.29	74485.00
18	6.38	11.13	50.30	2.62	18.71	9.09	1.29	74315.00
19	7.77	11.11	50.40	2.59	19.71	9.06	1.32	73267.00
20	9.28	11.29	49.94	2.55	19.03	9.04	1.32	73974.00
21	6.05	11.25	51.13	2.23	18.89	9.13	1.31	74674.00
22	6.10	11.67	49.83	2.17	19.43	9.04	1.30	75094.00
23	6.71	11.38	55.24	1.86	18.92	9.49	1.31	76327.00
24	6.90	11.61	58.32	2.75	18.09	9.82	1.29	74874.00
25	5.84	11.76	58.31	2.57	18.62	9.73	1.29	75041.00
26	6.05	11.71	57.27	2.57	19.33	9.43	1.29	74116.00
27	7.03	11.73	57.54	2.64	18.84	9.61	1.29	74537.00
28	6.69	11.84	52.68	1.86	18.80	9.92	1.32	71047.00
29	5.95	11.76	50.31	2.76	19.77	9.02	1.33	74624.00
30	8.01	11.09	53.99	2.86	19.11	9.35	1.31	74294.00
平 均 值	6.46	11.53	52.13	2.52	19.06	9.31	1.32	74893.23
最 大 值	9.37	13.01	58.32	3.09	19.81	9.92	1.40	76877.00
最 小 值	3.97	10.64	47.33	1.86	17.94	8.86	1.28	71047.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。