

P001_樹林焚化廠CEMS系統月報表

報表日期: 2026年8月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	9.17	12.76	49.78	2.41	17.34	11.26	1.25	81973.00
2	7.00	12.61	48.98	2.24	17.86	10.69	1.22	84404.00
3	6.96	12.41	49.17	3.88	17.50	11.28	1.20	81162.00
4	9.14	12.67	54.11	2.59	17.16	11.33	1.19	77865.00
5	9.82	12.98	53.37	2.42	16.38	11.44	1.17	73376.00
6	8.76	12.25	52.62	2.29	17.39	11.24	1.18	73361.00
7	9.20	11.70	53.04	2.63	17.54	11.35	1.18	72477.00
8	9.36	12.35	55.74	2.34	16.85	11.59	1.17	71505.00
9	7.70	12.30	52.23	1.69	17.16	11.80	1.15	73418.00
10	5.79	12.33	55.33	1.78	17.87	11.54	1.14	73560.00
11	8.87	12.89	51.87	1.58	18.34	11.25	1.13	73615.00
12	9.47	12.13	55.46	2.29	18.18	11.27	1.16	73410.00
13	9.19	12.06	55.66	2.43	17.82	11.35	1.18	72316.00
14	9.31	12.04	51.63	2.14	18.11	11.22	1.23	72709.00
15	9.52	12.92	50.15	2.70	17.85	11.28	1.25	72167.00
16	8.46	12.81	58.10	2.76	17.91	11.38	1.22	72890.00
17	8.15	12.67	53.35	2.65	17.76	11.54	1.23	71160.00
18	9.09	12.91	56.43	2.51	18.25	11.28	1.21	73271.00
19	9.95	12.85	56.63	2.69	17.71	11.32	1.19	72858.00
20	9.38	12.46	53.77	2.31	17.84	11.43	1.20	71635.00
21	9.39	11.66	55.10	1.95	18.66	11.00	1.19	73909.00
22	8.44	12.43	53.07	2.07	17.90	11.46	1.22	71260.00
23	7.24	12.74	55.36	1.66	19.46	10.86	1.20	73846.00
24	8.86	11.75	56.12	1.72	18.92	10.90	1.19	74350.00
25	9.03	12.16	55.59	1.96	18.92	11.09	1.18	73042.00
26	9.18	12.60	56.71	2.21	18.53	11.08	1.17	73423.00
27	8.95	13.16	57.92	2.10	18.67	10.87	1.17	75135.00
28	9.12	12.60	58.88	2.34	19.08	10.90	1.16	74108.00
29	9.76	12.71	56.31	2.80	18.54	11.18	1.17	72631.00
30	9.00	12.99	56.48	2.18	18.64	11.17	1.17	72743.00
31	9.46	11.82	58.97	2.71	17.49	11.35	1.14	72546.00
平均 值	8.80	12.47	54.45	2.32	17.99	11.25	1.19	74068.55
最 大 值	9.95	13.16	58.97	3.88	19.46	11.80	1.25	84404.00
最 小 值	5.79	11.66	48.98	1.58	16.38	10.69	1.13	71160.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P002_樹林焚化廠CEMS系統月報表

報表日期: 2026年8月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	8.71	13.01	53.23	1.38	17.60	11.18	0.93	80500.00
2	8.04	13.26	53.20	2.14	17.61	11.12	0.92	81490.00
3	5.00	12.56	54.87	2.21	17.49	11.12	0.89	81123.00
4	6.98	12.83	52.49	2.56	17.52	11.11	0.85	81280.00
5	8.29	12.69	53.89	1.83	17.34	11.17	0.88	80162.00
6	3.99	12.86	50.28	1.20	17.25	11.38	0.90	79238.00
7	3.07	13.56	49.76	1.99	16.61	11.59	0.90	78624.00
8	4.08	13.29	54.68	1.68	17.08	11.48	0.90	79614.00
9	5.77	13.72	51.70	1.41	17.76	11.74	0.90	80679.00
10	8.62	13.33	54.49	1.56	18.11	11.54	0.91	81961.00
11	8.32	12.82	52.21	1.89	18.61	11.02	0.94	81693.00
12	10.65	12.80	52.37	1.86	18.50	10.99	0.94	81692.00
13	8.56	12.80	54.67	1.23	17.97	11.21	0.94	80282.00
14	4.26	13.24	52.93	1.50	17.70	11.20	0.94	80554.00
15	6.93	11.92	53.43	1.66	17.79	11.29	0.94	79840.00
16	5.12	12.77	55.47	1.96	17.97	11.20	0.93	80511.00
17	4.84	12.52	52.04	1.73	18.53	11.12	0.94	80327.00
18	6.96	12.90	49.95	2.10	17.64	11.23	0.92	80828.00
19	5.35	12.78	51.39	1.65	17.27	11.43	0.93	80625.00
20	3.44	12.84	57.84	0.94	17.51	11.36	0.97	80428.00
21	1.89	12.85	57.20	1.27	17.93	11.17	1.00	81143.00
22	4.63	12.90	54.19	1.44	17.75	11.32	1.03	80478.00
23	3.63	13.19	55.71	1.10	19.40	10.96	1.03	81232.00
24	2.33	12.27	56.03	1.29	18.27	11.22	1.02	80454.00
25	4.40	12.85	54.97	1.37	18.18	11.19	1.02	80637.00
26	7.38	12.79	56.06	1.64	18.08	11.15	0.99	80914.00
27	8.69	12.56	56.56	1.41	18.24	10.86	0.99	83127.00
28	7.39	12.63	56.56	1.53	18.22	10.79	0.96	83546.00
29	9.12	13.09	54.52	1.45	18.64	10.76	0.92	83506.00
30	6.48	12.63	51.55	1.54	18.66	10.80	0.93	83104.00
31	3.47	12.78	55.34	1.42	17.55	11.02	0.92	82749.00
平 均 值	6.01	12.87	53.86	1.61	17.90	11.18	0.94	81043.26
最 大 值	10.65	13.72	57.84	2.56	19.40	11.74	1.03	83546.00
最 小 值	1.89	11.92	49.76	0.94	16.61	10.76	0.85	78624.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P003_樹林焚化廠CEMS系統月報表

報表日期: 2026年8月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	4.87	11.32	56.99	2.18	18.36	10.10	1.30	77303.00
2	1.84	11.33	52.99	2.08	18.74	9.89	1.36	77937.00
3	1.77	10.57	47.11	0.93	18.63	9.43	1.43	76690.00
4	2.30	11.93	58.09	2.09	17.98	9.91	1.41	75938.00
5	5.47	11.50	53.40	2.31	18.04	9.75	1.38	75185.00
6	4.27	12.56	53.70	2.25	17.48	10.32	1.37	75110.00
7	4.00	12.37	56.67	2.02	16.89	10.62	1.35	73598.00
8	5.39	11.99	51.21	1.95	17.91	9.94	1.32	73901.00
9	5.47	11.96	48.31	2.10	18.68	10.04	1.29	75772.00
10	6.66	12.36	50.00	1.99	19.08	10.38	1.29	75665.00
11	7.80	11.79	48.01	2.34	19.82	9.70	1.29	75464.00
12	8.86	12.01	51.70	2.59	19.60	9.75	1.30	76225.00
13	7.34	11.94	50.17	2.31	18.99	9.61	1.29	74188.00
14	4.99	12.16	50.09	2.35	18.77	9.74	1.28	74332.00
15	4.29	11.35	50.84	2.37	17.64	9.89	1.28	72993.00
16	4.14	12.25	54.92	2.80	17.20	10.42	1.27	73196.00
17	7.38	11.51	52.57	2.47	17.77	10.10	1.26	73503.00
18	7.51	12.20	53.59	2.67	19.54	9.93	1.28	75963.00
19	8.08	11.47	52.98	2.26	18.93	9.69	1.26	74176.00
20	7.08	11.61	56.33	2.12	18.99	9.91	1.26	74824.00
21	8.28	12.10	56.94	2.21	19.03	10.12	1.28	76072.00
22	7.31	12.72	53.13	2.15	19.10	9.97	1.26	74051.00
23	2.78	12.66	52.92	1.80	20.30	9.90	1.26	76922.00
24	2.47	11.50	51.43	1.86	19.91	9.46	1.25	75790.00
25	4.97	11.35	52.07	1.91	20.09	9.34	1.25	74817.00
26	4.73	12.03	55.32	2.04	19.29	9.47	1.26	73917.00
27	3.37	12.24	56.70	2.46	19.43	9.30	1.26	75607.00
28	3.16	11.35	52.06	1.74	19.49	9.05	1.27	75482.00
29	9.05	11.86	54.75	2.39	19.00	9.82	1.28	76513.00
30	9.00	11.80	48.62	2.21	19.37	9.22	1.28	75309.00
31	5.58	11.44	49.97	2.29	19.21	9.03	1.27	77303.00
平均 值	5.49	11.85	52.70	2.17	18.81	9.80	1.30	75282.13
最 大 值	9.05	12.72	58.09	2.80	20.30	10.62	1.43	77937.00
最 小 值	1.77	10.57	47.11	0.93	16.89	9.03	1.25	72993.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。