

P001\_樹林焚化廠CEMS系統月報表

報表日期: 2022年03月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	14.27	6.62	47.41	0.68	18.00	11.15	1.52	69986.00
2	14.32	4.22	52.37	1.01	17.52	11.22	1.51	70446.00
3	14.41	7.50	59.33	1.33	16.27	11.76	1.49	67051.00
4	16.19	11.91	55.56	1.22	17.31	11.35	1.51	69521.00
5	15.79	9.91	58.17	1.47	16.93	11.65	1.50	68439.00
6	15.46	11.73	51.96	1.19	16.59	11.60	1.47	69547.00
7	15.67	8.69	57.44	1.42	15.86	11.67	1.44	69487.00
8	15.52	10.65	46.52	0.73	17.78	11.05	1.46	72975.00
9	15.32	14.86	42.63	0.54	17.48	11.15	1.46	71844.00
10	15.47	12.64	50.52	1.52	15.63	11.80	1.46	67982.00
11	15.48	10.86	51.77	1.18	16.84	11.50	1.46	69528.00
12	15.33	6.12	54.76	1.16	17.11	11.52	1.43	68766.00
13	14.66	7.96	63.10	1.34	16.49	11.95	1.40	66192.00
14	15.15	9.08	51.61	1.19	16.54	11.66	1.37	67853.00
15	14.90	8.01	47.28	0.95	17.32	11.49	1.36	69001.00
16	14.67	15.60	47.97	1.05	16.72	11.45	1.40	68756.00
17	13.84	8.48	51.46	0.99	16.90	11.62	1.40	69624.00
18	14.20	10.63	52.11	1.09	17.34	11.41	1.39	71248.00
19	15.04	11.13	45.96	0.66	17.70	11.16	1.41	72245.00
20	14.87	9.98	49.61	1.12	16.96	11.40	1.44	70166.00
21	15.04	5.33	52.90	1.27	17.46	11.15	1.45	71520.00
22	15.14	7.35	50.61	1.40	16.80	11.37	1.45	71386.00
23	14.99	18.96	49.95	1.40	16.55	11.44	1.44	71207.00
24	15.18	9.08	49.73	0.92	18.74	11.11	1.45	72651.00
25	14.69	19.11	43.97	0.45	21.22	11.26	1.48	69865.00
26	**	**	**	**	**	**	**	#VALUE!
27	14.91	20.27	42.31	1.89	16.73	11.34	1.42	88015.00
28	14.59	14.87	51.67	1.15	15.92	11.75	1.44	89981.00
29	14.06	11.96	59.87	0.94	16.31	12.04	1.47	80831.00
30	13.98	8.37	57.13	1.02	16.81	11.87	1.51	83101.00
31	14.31	11.38	63.13	1.58	16.12	11.94	1.52	81320.00
平均值	14.92	10.78	51.96	1.13	17.07	11.49	1.45	#VALUE!
最大值	16.19	20.27	63.13	1.89	21.22	12.04	1.52	#VALUE!
最小值	13.84	4.22	42.31	0.45	15.63	11.05	1.36	#VALUE!

備註： 1.\*:儀器保養維護中。

2.\*\*:停爐中。

P002\_樹林焚化廠CEMS系統月報表

報表日期: 2022年03月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	13.83	8.32	49.11	0.21	17.63	10.61	1.49	61469.00
2	13.92	5.20	52.08	0.20	17.36	10.60	1.49	61829.00
3	14.38	7.43	53.67	0.23	16.96	10.71	1.48	61481.00
4	16.21	16.96	56.45	0.41	17.14	10.73	1.47	61346.00
5	15.24	11.06	64.49	0.38	16.28	11.23	1.46	58583.00
6	15.04	12.24	57.47	0.31	16.66	10.79	1.43	60688.00
7	15.03	5.78	59.99	0.25	16.40	10.82	1.45	61076.00
8	14.79	7.87	59.70	0.28	17.14	10.83	1.47	61395.00
9	14.86	12.26	60.31	0.28	16.78	10.93	1.50	60603.00
10	14.61	5.46	62.47	0.28	16.37	11.01	1.51	60169.00
11	15.02	8.65	60.62	0.51	16.79	10.82	1.49	61126.00
12	15.12	10.37	57.54	0.29	17.45	10.74	1.48	60949.00
13	14.72	6.39	57.69	0.37	17.03	10.78	1.47	61058.00
14	14.35	7.99	58.85	0.36	16.67	10.90	1.46	60102.00
15	14.03	6.93	57.48	0.32	17.38	10.85	1.47	60217.00
16	14.70	10.34	61.71	0.54	16.73	10.96	1.48	59864.00
17	14.93	5.07	60.20	0.33	17.06	10.83	1.48	60535.00
18	14.72	6.77	64.92	0.65	17.17	10.84	1.47	60255.00
19	14.97	11.64	54.77	0.52	17.55	10.80	1.47	60291.00
20	14.77	12.56	52.96	0.32	17.86	10.76	1.48	60508.00
21	14.70	9.76	58.09	0.50	17.49	10.68	1.47	61021.00
22	14.00	11.06	59.30	0.64	16.57	10.99	1.49	59444.00
23	14.45	13.61	61.79	0.84	15.88	11.19	1.48	59516.00
24	14.17	15.71	66.94	0.95	15.48	11.57	1.49	56969.00
25	14.36	6.22	64.53	0.36	17.29	11.13	1.48	58867.00
26	14.25	8.19	61.30	0.33	18.07	10.65	1.48	61322.00
27	14.46	9.30	61.30	0.82	16.91	10.98	1.50	60352.00
28	14.11	11.35	61.61	0.69	16.16	11.38	1.53	60114.00
29	13.47	10.81	60.26	0.43	17.03	11.29	1.53	58419.00
30	14.67	5.81	57.16	0.23	18.00	11.12	1.54	59260.00
31	15.81	7.27	63.88	0.84	17.27	11.80	1.47	59901.00
平均值	14.64	9.30	59.31	0.44	16.99	10.95	1.48	60281.58
最大值	16.21	16.96	66.94	0.95	18.07	11.80	1.54	61829.00
最小值	13.47	5.07	49.11	0.20	15.48	10.60	1.43	56969.00

備註： 1.\*:儀器保養維護中。

2.\*\*:停爐中。

P003\_樹林焚化廠CEMS系統月報表

報表日期: 2022年03月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	13.65	4.65	51.74	2.10	16.24	10.51	1.48	72587.00
2	13.68	8.23	52.71	2.36	16.44	10.29	1.50	72855.00
3	14.58	9.97	52.12	2.50	15.57	10.34	1.53	72594.00
4	16.11	8.87	55.86	2.61	16.06	10.29	1.51	74126.00
5	14.68	7.15	61.69	2.79	15.46	10.78	1.51	71242.00
6	14.89	10.29	54.94	2.70	15.03	10.47	1.49	72261.00
7	15.18	8.61	56.85	2.59	14.95	10.61	1.52	73051.00
8	14.32	13.79	45.25	2.15	15.47	10.53	1.47	72726.00
9	15.63	10.16	45.37	1.81	15.88	10.37	1.47	72943.00
10	15.44	10.46	46.07	2.16	15.90	10.12	1.52	73262.00
11	14.74	8.99	48.49	2.45	16.02	10.28	1.52	73336.00
12	14.84	15.97	43.38	2.42	15.76	10.03	1.48	71769.00
13	15.02	10.97	49.92	2.31	16.34	10.31	1.48	73007.00
14	14.77	19.13	43.42	2.47	15.72	10.26	1.46	70790.00
15	14.07	4.34	47.95	1.88	16.63	10.59	1.41	72633.00
16	14.97	28.75	36.77	2.42	16.12	9.85	1.41	69537.00
17	15.06	14.09	47.20	2.13	16.00	10.04	1.41	71078.00
18	14.20	12.84	44.01	2.27	16.67	10.06	1.39	74002.00
19	14.45	8.29	45.91	1.92	15.98	10.30	1.41	73350.00
20	14.86	8.29	46.79	2.01	16.24	10.17	1.43	72344.00
21	14.67	12.38	45.14	2.52	16.49	9.93	1.45	72111.00
22	14.40	12.62	48.60	2.38	16.33	10.33	1.43	72879.00
23	14.71	23.35	42.68	2.77	15.73	10.35	1.41	73535.00
24	14.61	9.98	51.50	2.69	15.31	10.48	1.39	71725.00
25	14.69	14.33	46.55	2.44	16.24	9.90	1.38	74128.00
26	14.85	7.32	54.78	2.39	17.26	9.93	1.34	76916.00
27	15.06	7.40	47.25	2.35	16.56	10.04	1.29	75560.00
28	14.85	8.16	49.40	2.03	15.98	10.45	1.32	75813.00
29	14.69	6.16	46.50	1.76	16.93	10.22	1.36	73273.00
30	14.62	5.36	50.49	1.90	17.10	10.31	1.38	74032.00
31	14.60	11.65	53.43	2.50	16.54	10.28	1.37	72587.00
平均值	14.74	11.05	48.80	2.32	16.10	10.27	1.44	72969.42
最大值	16.11	28.75	61.69	2.79	17.26	10.78	1.53	76916.00
最小值	13.65	4.34	36.77	1.76	14.95	9.85	1.29	69537.00

備註： 1.\*:儀器保養維護中。

2.\*\*:停爐中。