

P001_樹林焚化廠CEMS系統月報表

報表日期: 2021年4月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60	150	220	150	40	20.95	20	999999
1	8.43	11.27	62.06	1.57	13.66	13.50	1.40	73204.00
2	7.47	12.32	56.38	1.18	14.35	13.24	1.39	75441.00
3	6.69	19.90	50.92	1.46	14.31	13.22	1.38	75496.00
4	5.68	10.74	54.19	1.61	13.82	13.26	1.30	76799.00
5	9.47	14.08	66.63	2.14	13.06	13.20	1.33	77511.00
6	7.24	11.12	60.74	1.94	12.89	13.38	1.36	75631.00
7	6.17	20.43	52.63	1.73	13.61	13.15	1.39	76999.00
8	11.31	20.17	54.80	2.32	13.12	13.33	1.40	75032.00
9	10.36	25.39	56.53	2.93	12.77	13.40	1.44	76198.00
10	8.95	13.02	67.98	3.30	13.41	13.87	1.44	71840.00
11	15.62	28.58	51.62	4.21	12.69	13.37	1.45	75443.00
12	11.41	18.47	65.16	2.60	13.29	13.47	1.44	74113.00
13	10.74	23.84	56.23	3.04	12.94	13.48	1.52	74168.00
14	11.52	20.01	62.44	3.62	12.49	13.61	1.51	72822.00
15	18.31	29.96	63.18	4.04	12.17	13.37	1.48	69642.00
16	16.02	37.76	52.90	4.52	11.73	13.25	1.52	67383.00
17	17.66	45.60	52.70	6.42	11.12	13.30	1.51	66624.00
18	14.66	32.34	56.08	5.91	10.94	13.31	1.49	68965.00
19	9.48	35.93	58.42	4.94	11.13	13.42	1.50	68527.00
20	10.43	29.56	54.01	5.13	11.05	13.72	1.57	65320.00
21	20.35	24.47	61.75	6.29	10.80	13.87	1.64	64179.00
22	13.58	24.38	67.08	5.57	11.58	13.89	1.61	62574.00
23	19.04	24.85	69.27	6.83	11.14	14.09	1.56	60559.00
24	17.90	26.52	65.96	6.06	11.12	14.11	1.60	63588.00
25	8.68	14.93	67.35	3.66	12.69	13.80	1.46	73734.00
26	12.25	17.40	77.63	3.85	12.01	14.14	1.39	69967.00
27	6.27	16.20	53.26	2.46	12.75	13.83	1.37	70796.00
28	5.85	13.61	57.39	2.31	13.13	13.72	1.41	74053.00
29	5.99	15.71	63.10	2.07	13.41	13.64	1.42	75100.00
30	6.06	22.82	52.27	2.17	13.41	13.48	1.40	76779.00
平均值	11.12	22.05	59.69	3.53	12.55	13.55	1.46	71616.23
最大值	20.35	45.60	77.63	6.83	14.35	14.14	1.64	77511.00
最小值	5.68	10.74	50.92	1.18	10.80	13.15	1.30	60559.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P002_樹林焚化廠CEMS系統月報表

報表日期: 2021年4月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60	150	220	150	40	20.95	20	999999
1	13.78	9.44	102.69	0.84	16.97	10.72	1.44	63022.00
2	6.43	9.97	93.34	0.27	17.90	10.48	1.42	65054.00
3	6.45	6.49	90.63	0.55	17.11	10.56	1.40	64704.00
4	4.98	4.68	100.76	0.26	17.26	10.54	1.40	65503.00
5	8.10	3.65	98.28	0.45	16.57	10.55	1.42	65909.00
6	3.94	6.84	92.76	0.27	16.67	10.48	1.44	64829.00
7	10.07	8.44	92.00	0.76	16.02	10.55	1.42	64283.00
8	9.54	11.47	92.40	0.90	16.24	10.58	1.43	64149.00
9	10.08	9.01	94.46	1.09	15.87	10.71	1.41	64102.00
10	11.41	10.01	100.72	1.49	15.65	11.01	1.41	60632.00
11	18.71	11.49	95.74	2.49	16.05	10.45	1.43	65196.00
12	12.79	6.77	100.82	0.95	16.35	10.71	1.44	64570.00
13	12.97	10.00	91.71	1.35	16.43	10.79	1.41	63513.00
14	16.62	9.94	101.14	1.43	15.57	10.94	1.43	64430.00
15	18.88	7.04	99.97	3.35	15.62	10.76	1.42	64296.00
16	16.54	8.55	102.07	1.51	15.82	10.73	1.42	65475.00
17	19.96	17.26	103.59	1.92	15.33	10.81	1.47	64487.00
18	22.94	8.41	106.86	2.10	17.97	10.65	1.40	65539.00
19	20.10	9.58	103.37	1.76	18.39	10.55	1.36	65361.00
20	20.30	10.75	109.26	1.55	17.81	10.67	1.35	66572.00
21	16.81	13.22	111.12	1.57	15.42	10.95	1.35	65676.00
22	11.66	8.31	116.29	0.86	16.66	10.91	1.38	67137.00
23	18.13	13.42	113.95	2.00	15.73	11.12	1.36	66113.00
24	22.33	12.66	111.89	1.87	15.87	11.15	1.39	66329.00
25	27.60	8.17	120.12	2.04	18.01	11.23	1.32	66891.00
26	17.66	9.99	114.71	1.00	17.40	11.26	1.33	66228.00
27	10.48	9.49	107.40	1.05	16.18	11.22	1.36	65468.00
28	11.52	12.50	91.85	0.87	17.27	11.04	1.32	66042.00
29	15.28	19.12	70.43	0.59	17.86	11.24	1.31	65356.00
30	10.83	29.49	71.18	1.02	16.52	11.45	1.33	63948.00
平均值	14.23	10.54	100.05	1.27	16.62	10.83	1.39	65027.13
最大值	27.60	29.49	120.12	3.35	18.39	11.45	1.47	67137.00
最小值	3.94	3.65	70.43	0.26	15.33	10.45	1.31	60632.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P003_樹林焚化廠CEMS系統月報表

報表日期: 2021年4月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60	150	220	150	40	20.95	20	999999
1	16.17	4.90	70.44	1.36	16.34	10.34	1.49	80172.00
2	7.80	7.84	66.09	1.21	16.73	10.26	1.44	81728.00
3	5.91	5.44	66.75	1.26	16.82	10.38	1.43	80363.00
4	7.72	4.57	70.86	1.58	16.30	10.55	1.41	81524.00
5	9.28	6.74	71.19	1.60	15.85	10.39	1.43	81383.00
6	4.43	7.07	70.44	1.27	15.75	10.68	1.43	80493.00
7	6.05	6.36	69.08	1.60	15.26	10.63	1.44	80046.00
8	10.14	8.35	66.51	1.67	15.67	10.50	1.46	81002.00
9	12.93	9.83	69.35	2.20	15.46	10.64	1.43	80887.00
10	11.45	8.68	71.01	2.22	15.14	10.81	1.47	74834.00
11	16.95	7.69	73.34	2.65	16.02	10.35	1.48	77936.00
12	14.19	10.64	68.17	1.95	16.27	10.98	1.48	74721.00
13	15.56	15.36	57.39	2.09	15.77	10.51	1.47	76188.00
14	15.46	5.74	69.60	2.42	15.20	10.62	1.44	79551.00
15	18.95	11.16	74.87	3.58	15.62	10.36	1.45	78844.00
16	18.40	12.19	67.97	3.25	16.09	10.24	1.47	80479.00
17	21.11	12.90	73.14	3.80	15.23	10.47	1.49	79019.00
18	15.33	14.81	72.75	3.96	15.07	10.43	1.45	80880.00
19	11.09	5.53	75.02	3.26	15.51	10.36	1.47	80531.00
20	9.71	13.47	78.23	3.19	16.00	10.50	1.50	82406.00
21	17.26	18.83	74.62	4.35	15.49	10.17	1.51	80534.00
22	16.96	19.45	71.46	4.15	16.55	9.98	1.50	77605.00
23	25.40	13.72	73.49	5.65	16.28	10.17	1.48	78726.00
24	21.82	9.38	75.14	3.49	16.73	10.15	1.48	79020.00
25	18.96	7.04	70.95	3.25	18.67	10.02	1.43	79165.00
26	13.62	20.05	69.49	3.29	18.03	9.93	1.42	78407.00
27	12.99	13.56	61.06	3.22	16.76	10.48	1.46	89257.00
28	17.58	17.35	58.86	2.34	17.27	10.17	1.49	78797.00
29	24.01	11.99	58.61	1.91	17.42	10.56	1.45	79590.00
30	13.23	13.61	54.61	1.56	16.85	10.51	1.46	81288.00
平均值	14.35	10.81	69.02	2.64	16.21	10.40	1.46	79845.87
最大值	25.40	20.05	78.23	5.65	18.67	10.98	1.51	89257.00
最小值	4.43	4.57	54.61	1.21	15.07	9.93	1.41	74721.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。