

P001_樹林焚化廠CEMS系統月報表

報表日期: 2023年2月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	5.07	7.18	52.26	1.70	18.84	11.71	1.44	72729.00
2	6.76	4.31	59.26	3.96	13.30	12.62	1.40	67785.00
3	5.25	4.80	60.38	3.87	13.27	12.73	1.43	67882.00
4	4.80	5.09	58.14	3.82	13.55	12.71	1.43	67994.00
5	5.99	3.51	60.61	3.47	14.66	12.38	1.42	69732.00
6	8.30	2.50	59.11	3.51	14.40	12.44	1.43	69013.00
7	5.01	3.06	61.35	2.44	16.71	11.98	1.41	71256.00
8	7.61	5.24	61.85	3.47	14.94	12.44	1.40	69839.00
9	6.65	4.29	60.93	3.56	14.22	12.51	1.39	69119.00
10	7.59	4.97	59.34	3.56	14.63	12.62	1.38	68518.00
11	8.98	6.05	59.12	3.76	14.37	12.52	1.35	69562.00
12	8.66	4.64	57.06	3.49	14.68	12.39	1.38	69457.00
13	9.12	9.31	55.51	3.91	13.85	12.69	1.38	68888.00
14	7.78	6.31	58.45	3.73	13.48	12.61	1.37	69889.00
15	6.91	5.58	57.99	3.16	13.68	12.48	1.38	70812.00
16	8.03	4.99	54.41	3.57	13.23	12.63	1.44	70049.00
17	6.64	5.95	58.50	3.34	13.85	12.52	1.46	69509.00
18	6.86	5.13	58.24	3.42	14.30	12.39	1.44	69640.00
19	8.54	5.16	59.51	3.72	14.05	12.54	1.46	69440.00
20	8.67	5.75	57.49	4.04	13.49	12.52	1.45	71128.00
21	5.60	6.07	55.05	3.66	13.65	12.46	1.45	71150.00
22	8.81	6.44	53.71	3.58	13.62	12.54	1.46	70093.00
23	7.63	6.52	55.55	3.76	13.86	12.59	1.46	68978.00
24	7.74	4.00	55.82	3.37	14.45	12.36	1.44	70352.00
25	8.60	6.17	55.02	3.53	13.65	12.45	1.44	70984.00
26	8.80	3.77	54.68	2.99	14.13	12.10	1.43	73378.00
27	6.49	4.27	54.48	3.19	13.51	12.37	1.46	70898.00
28	5.09	4.00	55.41	3.17	14.08	12.39	1.44	69478.00
平均值	7.21	5.18	57.47	3.46	14.23	12.45	1.42	69912.57
最大值	9.12	9.31	61.85	4.04	18.84	12.73	1.46	73378.00
最小值	4.80	2.50	52.26	1.70	13.23	11.71	1.35	67785.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P002_樹林焚化廠CEMS系統月報表

報表日期: 2023年2月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	3.53	4.90	54.44	1.22	17.59	10.01	1.45	62660.00
2	6.59	2.94	58.11	1.60	16.74	10.72	1.39	61767.00
3	8.55	7.21	54.60	1.69	17.59	10.26	1.42	69190.00
4	5.58	3.92	51.67	1.58	17.71	10.17	1.41	61211.00
5	3.62	2.33	56.33	1.31	18.36	10.16	1.40	63063.00
6	8.82	2.38	58.65	1.62	17.67	10.40	1.42	63222.00
7	7.24	1.88	58.01	1.36	18.03	10.43	1.43	64879.00
8	7.84	5.18	58.72	1.86	18.58	10.00	1.40	64499.00
9	8.09	2.49	57.79	1.72	17.49	10.56	1.39	63495.00
10	9.12	3.89	60.41	1.86	17.70	10.47	1.39	72476.00
11	8.98	5.92	57.06	2.07	17.98	10.30	1.37	84050.00
12	8.87	4.12	54.85	2.05	17.86	10.38	1.39	83260.00
13	8.43	5.36	55.29	1.94	17.31	10.41	1.42	82141.00
14	8.12	4.41	57.78	2.17	16.60	10.80	1.40	84655.00
15	9.10	4.63	54.76	1.79	17.10	10.49	1.39	84960.00
16	9.22	4.23	51.93	2.17	16.00	10.49	1.40	83475.00
17	6.11	4.88	56.18	2.28	16.02	10.91	1.38	81663.00
18	8.72	3.09	59.57	2.12	16.50	10.71	1.42	81967.00
19	10.62	4.38	53.76	2.50	16.85	10.49	1.43	82263.00
20	9.25	5.28	57.54	2.41	15.83	10.81	1.40	81837.00
21	7.47	4.97	54.54	1.82	17.20	10.53	1.42	85103.00
22	9.36	4.76	54.24	1.95	16.90	10.69	1.42	83704.00
23	10.13	6.24	52.73	2.31	17.13	10.54	1.38	83015.00
24	7.90	4.48	54.68	1.86	17.61	10.55	1.38	82839.00
25	9.12	4.16	50.16	2.13	16.65	10.53	1.42	81700.00
26	**	**	**	**	**	**	**	**
27	8.01	5.60	46.73	3.11	15.93	10.49	1.34	81933.00
28	5.53	4.36	54.46	2.14	16.27	10.69	1.38	81367.00
平均值	7.92	4.37	55.37	1.95	17.16	10.48	1.40	76162.74
最大值	10.62	7.21	60.41	3.11	18.58	10.91	1.45	85103.00
最小值	3.53	1.88	46.73	1.22	15.83	10.00	1.34	61211.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P003_樹林焚化廠CEMS系統月報表

報表日期: 2023年2月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	4.33	2.95	58.06	0.98	16.06	10.99	1.86	84284.00
2	4.70	5.49	61.33	1.74	15.36	11.34	1.84	82290.00
3	7.84	3.18	60.76	2.03	14.64	11.64	1.82	81313.00
4	7.66	3.85	59.88	1.89	15.98	10.88	1.78	83355.00
5	6.65	3.30	61.37	1.92	17.09	10.74	1.79	85001.00
6	7.46	7.62	55.13	2.00	16.45	11.02	1.80	80060.00
7	7.10	2.47	60.13	1.70	17.28	10.66	1.81	85401.00
8	4.76	4.63	61.49	1.88	16.84	10.85	1.84	85054.00
9	5.75	6.37	60.97	2.05	16.61	10.82	1.85	84937.00
10	8.89	4.70	62.00	2.41	16.46	10.79	1.82	83796.00
11	9.91	5.96	60.76	2.75	16.18	10.86	1.83	83409.00
12	10.15	3.60	59.10	2.37	16.44	10.76	1.82	83987.00
13	7.81	6.41	58.47	2.49	15.88	10.80	1.77	82591.00
14	8.03	5.03	59.77	2.12	15.56	10.98	1.74	83706.00
15	8.57	5.09	58.47	1.77	15.46	11.22	1.74	83601.00
16	7.86	3.82	60.33	1.90	15.07	11.11	1.74	82164.00
17	5.34	5.76	60.10	2.03	15.31	11.08	1.74	82234.00
18	7.89	3.89	57.66	2.02	15.58	11.00	1.74	81882.00
19	8.36	5.29	59.47	2.38	15.25	11.21	1.70	81110.00
20	6.38	5.29	60.21	2.17	14.63	11.06	1.71	80788.00
21	3.28	5.82	59.77	1.72	15.46	10.96	1.76	83122.00
22	8.20	5.53	58.34	1.96	15.64	10.93	1.77	83530.00
23	6.92	4.94	58.02	2.15	15.63	10.85	1.75	80848.00
24	7.74	2.85	59.99	2.14	16.32	10.84	1.77	82340.00
25	8.77	4.62	59.25	2.22	15.34	10.99	1.76	82657.00
26	9.61	3.41	55.64	1.62	16.12	10.38	1.76	87122.00
27	6.12	4.86	56.81	1.69	14.90	10.73	1.76	82787.00
28	3.78	4.77	60.61	1.93	15.04	11.00	1.78	82062.00
平均值	7.14	4.70	59.42	2.00	15.81	10.95	1.78	83051.11
最大值	10.15	7.62	62.00	2.75	17.28	11.64	1.86	87122.00
最小值	3.28	2.47	55.13	0.98	14.63	10.38	1.70	80060.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。