

P001_樹林焚化廠CEMS系統月報表

報表日期: 2024年1月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	7.65	7.22	49.35	1.84	14.83	11.79	1.06	81339.00
2	7.15	8.33	53.33	1.70	14.98	11.98	1.02	81356.00
3	8.11	9.50	52.56	2.09	14.72	11.88	1.03	81304.00
4	8.59	10.80	51.20	1.98	14.97	11.91	1.05	82312.00
5	9.64	7.27	53.65	2.03	15.40	11.73	1.04	82080.00
6	9.05	7.85	50.79	2.39	14.12	12.19	1.02	79798.00
7	9.14	8.34	51.17	2.05	14.68	11.91	1.01	81573.00
8	9.11	7.16	51.41	1.46	15.43	11.80	1.03	81387.00
9	8.36	9.36	51.25	1.79	15.26	11.94	1.03	80679.00
10	9.17	8.24	50.18	1.80	15.24	11.89	1.00	81082.00
11	9.31	8.60	49.29	1.64	15.47	11.74	1.00	82935.00
12	9.51	7.19	46.84	1.57	15.43	11.78	1.01	82030.00
13	9.48	5.52	46.73	1.45	15.74	11.90	1.03	80712.00
14	8.57	8.27	44.22	1.26	15.90	11.72	1.06	81615.00
15	8.34	6.72	49.39	1.18	16.31	11.75	1.06	81325.00
16	8.45	8.22	48.78	1.26	15.80	11.82	1.09	80542.00
17	8.66	5.18	50.12	2.11	14.02	12.09	1.08	78910.00
18	8.36	6.00	47.90	1.24	15.94	11.61	1.07	81022.00
19	9.22	8.16	48.55	1.27	15.62	11.90	1.07	80416.00
20	9.37	7.10	49.56	1.55	15.68	11.78	1.06	80576.00
21	9.19	8.13	48.32	1.40	15.55	11.89	1.06	81335.00
22	9.14	7.68	52.14	1.74	14.36	11.97	1.05	82048.00
23	8.52	7.41	47.87	1.16	15.42	11.61	1.07	83607.00
24	7.92	5.69	45.11	0.79	16.08	11.51	1.12	84052.00
25	8.06	7.56	46.44	1.14	15.79	11.58	1.14	83379.00
26	8.13	8.43	50.93	1.16	15.30	11.99	1.15	81566.00
27	8.92	8.23	45.76	1.01	16.22	11.73	1.13	81914.00
28	8.98	8.34	46.52	1.06	16.39	11.72	1.14	81999.00
29	9.04	6.71	47.23	1.21	16.09	11.72	1.07	80731.00
30	9.34	6.24	51.47	2.14	14.27	12.29	1.06	77045.00
31	7.90	6.99	48.11	1.84	14.85	12.17	1.07	78641.00
平均值	8.72	7.63	49.23	1.56	15.35	11.85	1.06	81268.06
最大值	9.64	10.80	53.65	2.39	16.39	12.29	1.15	84052.00
最小值	7.15	5.18	44.22	0.79	14.02	11.51	1.00	77045.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P002_樹林焚化廠CEMS系統月報表

報表日期: 2024年1月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	4.57	5.04	46.82	2.08	15.70	10.74	1.08	82839.00
2	3.76	5.60	43.47	2.32	15.93	10.66	1.08	82982.00
3	6.64	5.19	44.95	2.48	15.15	10.54	1.07	81308.00
4	7.11	4.48	46.64	1.94	15.47	10.61	1.03	83367.00
5	5.96	7.49	48.22	2.82	14.57	11.19	1.02	82334.00
6	5.81	5.33	47.24	2.70	14.58	11.03	1.03	81733.00
7	6.54	4.72	44.06	2.61	14.60	10.90	1.03	81946.00
8	7.95	4.58	43.63	2.24	15.29	10.69	1.03	82340.00
9	7.44	5.33	44.50	2.35	15.78	10.86	1.04	82705.00
10	7.06	4.83	44.64	2.28	15.79	10.61	1.04	83141.00
11	8.41	4.68	43.75	2.29	15.66	10.56	1.04	85624.00
12	9.18	5.35	42.86	2.94	15.06	10.93	1.03	82863.00
13	9.47	6.06	41.90	2.35	15.85	10.73	1.03	83484.00
14	**	**	**	**	**	**	**	**
15	5.37	4.97	43.39	2.64	14.39	11.57	0.97	79427.00
16	6.44	4.25	41.78	2.18	14.95	11.11	0.98	81735.00
17	7.36	4.45	43.17	2.03	13.86	11.29	1.02	80953.00
18	7.84	6.41	45.53	2.13	14.85	10.96	1.02	81595.00
19	7.66	5.59	42.84	2.25	15.23	10.90	1.03	82422.00
20	7.94	5.55	42.57	2.23	15.39	10.84	1.01	82745.00
21	8.28	4.84	44.54	2.40	15.05	10.91	1.01	83015.00
22	7.89	4.30	48.35	2.59	14.33	11.09	1.02	82692.00
23	**	**	**	**	**	**	**	**
24	**	**	**	**	**	**	**	**
25	3.53	7.10	53.60	2.02	12.93	12.17	0.93	76535.00
26	3.90	6.52	42.97	2.19	13.76	12.05	0.98	74726.00
27	4.44	5.10	41.62	2.06	13.79	11.72	1.00	76235.00
28	5.76	4.86	41.47	2.07	11.50	11.50	1.05	77762.00
29	5.97	4.34	43.22	2.18	14.38	11.61	1.03	77060.00
30	7.89	4.32	46.17	2.64	14.19	11.68	1.03	77036.00
31	7.58	3.05	46.37	2.57	14.30	11.61	1.05	77536.00
平均值	6.71	5.15	44.65	2.34	14.73	11.11	1.02	81005.00
最大值	9.47	7.49	53.60	2.94	15.93	12.17	1.08	85624.00
最小值	3.53	3.05	41.47	1.94	11.50	10.54	0.93	74726.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P003_樹林焚化廠CEMS系統月報表

報表日期: 2024年1月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	2.51	4.57	48.96	1.12	15.32	10.06	0.92	75595.00
2	4.43	6.51	51.97	1.34	15.35	10.52	0.97	76819.00
3	6.18	5.80	49.77	1.94	15.84	10.27	1.00	77334.00
4	7.05	4.76	55.49	1.69	15.04	10.46	1.04	77436.00
5	7.13	5.11	47.87	1.97	14.83	10.56	1.07	75802.00
6	7.29	6.99	54.97	2.04	14.51	10.74	1.09	76212.00
7	4.84	7.79	51.52	1.84	14.66	10.63	1.09	75055.00
8	5.55	5.79	43.24	1.84	15.58	10.07	1.09	77410.00
9	5.99	5.24	38.92	1.36	16.11	9.62	1.05	75547.00
10	5.43	4.67	48.27	1.84	15.44	10.12	1.04	76794.00
11	5.74	4.55	53.03	1.85	14.43	10.50	1.07	77451.00
12	5.89	5.09	55.54	1.53	14.37	10.81	1.09	78142.00
13	5.61	4.25	49.78	1.79	14.48	10.67	1.10	78125.00
14	2.53	5.81	51.01	1.03	15.11	10.22	1.10	79713.00
15	2.83	4.60	50.10	1.49	14.97	10.49	1.08	76992.00
16	3.04	3.64	45.96	1.03	15.77	10.33	1.09	79157.00
17	5.29	4.52	47.91	2.04	13.80	10.74	1.09	74181.00
18	3.95	4.04	46.50	1.32	15.46	10.31	1.08	76839.00
19	5.95	9.91	48.65	1.82	14.58	11.02	1.08	75265.00
20	6.56	5.68	48.36	1.46	15.61	10.39	1.08	79907.00
21	4.75	5.16	47.36	1.39	15.13	10.42	1.06	77573.00
22	7.38	5.79	42.55	1.65	14.98	10.57	1.07	79350.00
23	2.60	5.19	46.60	0.45	15.46	10.27	1.10	79345.00
24	3.69	4.55	46.06	0.66	15.90	10.25	1.11	79769.00
25	5.49	5.54	43.92	0.74	15.38	10.36	1.11	79241.00
26	3.90	5.57	47.85	0.80	15.64	10.44	1.12	78858.00
27	7.84	5.98	46.23	0.98	15.18	10.87	1.11	78517.00
28	3.25	4.56	46.16	1.01	14.75	10.58	1.13	77920.00
29	4.21	3.94	44.05	0.86	15.00	10.44	1.10	74551.00
30	8.08	5.06	47.77	1.39	15.14	10.61	1.10	76786.00
31	6.18	4.36	47.03	1.27	15.81	10.45	1.12	75595.00
平均值	5.20	5.32	48.17	1.40	15.15	10.44	1.08	77331.65
最大值	8.08	9.91	55.54	2.04	16.11	11.02	1.13	79907.00
最小值	2.51	3.64	38.92	0.45	13.80	9.62	0.92	74181.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。