

P001_樹林焚化廠CEMS系統月報表

報表日期: 2025年7月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	4.79	9.56	56.38	2.09	16.57	11.78	1.27	79174.00
2	6.59	9.17	57.64	2.60	16.48	11.82	1.29	79680.00
3	6.31	9.55	57.13	2.29	15.87	11.90	1.29	78495.00
4	5.72	7.87	57.80	2.32	16.19	11.85	1.28	79081.00
5	6.52	8.98	58.00	2.73	15.69	11.97	1.28	77097.00
6	5.90	9.81	56.56	2.67	15.23	12.00	1.29	75595.00
7	4.39	9.15	53.71	2.17	15.85	12.07	1.28	77958.00
8	4.28	9.55	56.93	2.79	15.91	11.75	1.29	79851.00
9	1.42	10.60	56.96	2.44	16.19	11.59	1.26	80840.00
10	2.45	9.14	56.62	1.90	17.01	11.46	1.26	81317.00
11	1.97	10.34	55.80	1.67	16.92	11.60	1.28	80306.00
12	5.24	8.03	55.51	1.97	16.59	11.64	1.29	79913.00
13	7.18	8.79	55.12	2.57	17.34	11.33	1.29	81865.00
14	4.96	8.19	54.00	2.62	16.33	11.54	1.28	78822.00
15	3.33	8.66	55.62	2.17	16.73	11.63	1.26	80140.00
16	6.81	8.47	53.48	2.89	16.31	11.74	1.25	79614.00
17	4.92	9.17	53.97	2.41	16.68	11.73	1.27	78525.00
18	7.35	9.78	54.73	2.54	16.91	11.69	1.29	79174.00
19	5.58	9.29	52.24	2.44	16.12	12.03	1.32	77542.00
20	5.86	9.41	54.37	2.19	16.75	11.75	1.34	79073.00
21	5.53	8.46	54.37	2.62	15.12	12.25	1.33	76145.00
22	5.19	8.13	58.41	2.89	15.11	12.34	1.35	75350.00
23	8.52	9.16	57.11	2.57	15.98	11.84	1.34	78626.00
24	7.70	9.34	59.19	2.78	15.00	12.00	1.35	77513.00
25	7.69	9.41	59.21	2.88	16.72	11.78	1.36	78896.00
26	6.51	9.55	56.45	3.19	16.30	11.95	1.35	77247.00
27	6.06	8.49	53.62	2.48	16.72	11.77	1.32	78380.00
28	6.75	9.53	54.76	2.25	15.86	12.06	1.31	76978.00
29	6.98	9.50	56.70	2.13	16.69	11.75	1.29	78736.00
30	7.58	9.61	57.04	2.71	16.48	11.80	1.26	78014.00
31	8.17	8.07	58.37	2.65	15.34	12.00	1.28	77468.00
平均 值	5.75	9.12	56.06	2.47	16.23	11.82	1.30	78626.29
最 大 值	8.52	10.60	59.21	3.19	17.34	12.34	1.36	81865.00
最 小 值	1.42	7.87	52.24	1.67	15.00	11.33	1.25	75350.00

備註： 1.*:儀器保養維護中。
2.**:停爐中。

P002_樹林焚化廠CEMS系統月報表

報表日期: 2025年7月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	7.90	7.53	56.52	2.40	16.98	10.80	1.02	79920.00
2	7.19	8.60	56.25	2.47	17.18	10.75	0.98	79073.00
3	7.25	8.77	57.23	2.24	16.84	10.91	0.95	78907.00
4	7.20	7.28	55.07	2.28	17.01	10.90	0.97	79787.00
5	9.02	9.83	60.29	2.93	16.40	11.14	0.99	79933.00
6	8.35	9.09	54.18	2.81	16.04	11.24	1.01	78495.00
7	8.27	8.66	56.48	2.29	17.12	10.81	0.99	80257.00
8	7.37	9.15	57.35	2.48	17.55	11.08	0.97	81205.00
9	8.29	8.99	56.78	2.23	17.16	10.88	0.97	80963.00
10	8.07	8.68	54.98	1.87	18.45	10.63	0.99	82114.00
11	8.69	8.63	51.72	2.41	17.94	10.80	0.99	81089.00
12	8.42	8.29	57.53	2.55	18.19	10.88	0.99	81924.00
13	8.71	7.81	55.83	2.72	18.26	10.85	0.98	81510.00
14	8.10	9.69	52.79	2.23	17.90	10.75	1.01	79501.00
15	8.36	8.42	56.34	2.56	17.80	10.87	1.03	80952.00
16	8.94	8.07	57.23	2.72	17.43	10.87	1.01	81383.00
17	8.86	8.83	55.21	2.30	17.77	10.63	1.01	81763.00
18	9.10	8.91	56.62	2.46	17.47	10.80	1.02	81818.00
19	8.40	8.15	58.41	2.73	16.96	11.01	1.02	80840.00
20	8.17	8.51	57.87	2.35	18.00	10.68	1.03	83370.00
21	8.74	7.96	56.32	1.75	18.30	10.65	1.01	83399.00
22	8.86	8.07	55.62	2.19	17.88	10.78	1.02	82764.00
23	9.05	7.89	58.00	2.42	17.34	10.78	1.02	82537.00
24	9.55	8.65	59.02	2.26	17.25	10.50	1.01	81957.00
25	9.16	8.93	58.10	2.03	18.15	10.70	1.01	81945.00
26	7.31	8.14	58.00	2.34	18.09	10.71	1.02	82445.00
27	7.83	7.62	57.57	2.34	18.54	10.49	1.01	83751.00
28	7.57	8.34	56.52	2.07	17.77	10.63	0.98	82195.00
29	7.96	9.30	55.95	2.05	17.49	10.84	1.02	82177.00
30	7.53	9.07	53.98	3.06	17.57	10.62	1.02	81589.00
31	7.99	8.69	53.02	2.60	17.20	10.60	1.00	81222.00
平 均 值	8.26	8.53	56.35	2.39	17.55	10.79	1.00	81315.65
最 大 值	9.55	9.83	60.29	3.06	18.54	11.24	1.03	83751.00
最 小 值	7.19	7.28	51.72	1.75	16.04	10.49	0.95	78495.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P003_樹林焚化廠CEMS系統月報表

報表日期: 2025年7月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	4.15	8.76	61.20	2.20	17.10	9.76	1.43	76267.00
2	4.44	8.39	58.67	2.11	17.34	9.70	1.41	77480.00
3	3.04	8.57	58.32	1.91	16.85	9.77	1.40	73755.00
4	2.93	7.59	58.88	1.45	17.70	9.79	1.40	75453.00
5	2.97	9.49	58.04	1.40	17.08	10.08	1.40	74361.00
6	3.34	8.97	54.40	0.81	17.15	9.66	1.42	72174.00
7	3.01	8.07	55.49	0.53	17.14	9.76	1.42	74121.00
8	2.14	8.25	57.97	2.01	17.59	9.22	1.41	74213.00
9	2.84	8.02	58.89	2.43	16.94	9.78	1.41	77113.00
10	3.07	9.57	55.04	1.85	18.38	9.22	1.42	77508.00
11	3.07	8.90	55.70	1.74	18.61	9.17	1.41	77220.00
12	4.95	7.72	59.15	2.25	18.31	9.37	1.40	77645.00
13	4.19	7.32	57.12	2.39	18.35	9.24	1.39	75947.00
14	3.04	8.12	52.21	2.46	18.36	8.75	1.42	74490.00
15	2.47	9.63	61.80	2.16	18.02	10.16	1.43	72271.00
16	4.13	8.06	58.91	2.24	17.21	10.15	1.45	71778.00
17	7.34	9.17	53.87	1.83	18.15	9.25	1.46	75448.00
18	6.79	8.86	54.07	1.79	17.90	9.31	1.42	76936.00
19	5.97	7.94	53.09	1.59	17.23	9.80	1.40	78194.00
20	3.96	8.25	50.11	1.01	18.61	9.27	1.41	77303.00
21	6.34	8.47	53.28	2.05	18.23	9.06	1.41	78466.00
22	5.22	7.86	56.73	2.83	17.89	9.17	1.40	77776.00
23	8.00	7.59	59.30	2.41	17.63	9.27	1.39	77514.00
24	6.64	8.48	57.16	2.69	17.96	9.03	1.40	77627.00
25	5.57	8.75	58.44	2.53	18.67	9.56	1.42	79475.00
26	3.56	8.03	61.02	2.07	17.86	10.23	1.42	80553.00
27	4.80	7.71	56.79	2.29	18.17	9.74	1.41	80308.00
28	3.81	9.25	53.94	2.23	18.10	9.28	1.43	78202.00
29	5.86	9.13	56.11	1.96	18.85	8.92	1.45	77789.00
30	4.90	9.17	53.21	2.77	18.55	8.95	1.46	77788.00
31	4.31	9.66	55.64	2.50	18.42	8.96	1.46	76267.00
平 均 值	4.41	8.51	56.60	2.02	17.88	9.46	1.42	76498.13
最 大 值	8.00	9.66	61.80	2.83	18.85	10.23	1.46	80553.00
最 小 值	2.14	7.32	50.11	0.53	16.85	8.75	1.39	71778.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。