

P001_樹林焚化廠CEMS系統月報表

報表日期: 2021年9月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	13.61	22.52	87.37	1.76	14.04	12.30	1.18	59183.00
2	12.91	19.23	91.70	0.89	14.81	12.08	1.24	61843.00
3	14.65	15.58	89.72	0.46	16.05	11.79	1.28	64869.00
4	13.85	15.28	86.95	0.42	15.74	11.75	1.28	65134.00
5	13.20	15.90	89.41	0.25	16.45	11.79	1.37	63446.00
6	13.90	9.45	93.28	0.25	16.46	11.50	1.35	64425.00
7	15.16	13.29	85.95	0.32	16.98	11.83	1.37	65547.00
8	14.14	9.81	83.20	0.61	16.80	11.35	1.36	64784.00
9	14.52	11.05	75.86	0.65	17.30	10.88	1.33	65466.00
10	16.55	15.81	75.38	0.33	17.19	10.88	1.26	64621.00
11	14.98	8.70	76.24	0.51	18.92	10.49	1.26	66012.00
12	18.16	7.38	81.16	0.59	10.92	10.92	1.24	65542.00
13	14.69	7.37	78.05	0.12	18.43	10.51	1.26	66373.00
14	15.15	7.42	78.20	0.12	19.30	10.41	1.29	65752.00
15	16.62	12.35	82.55	2.44	19.42	10.38	1.32	65093.00
16	16.16	8.62	75.40	1.37	19.14	10.47	1.35	64729.00
17	16.18	15.53	72.25	0.66	17.92	10.62	1.36	65297.00
18	16.87	9.41	80.50	0.63	19.33	10.40	1.46	69196.00
19	15.62	8.65	84.79	0.51	18.48	10.65	1.44	73446.00
20	15.65	7.12	82.14	0.60	19.09	10.35	1.40	73515.00
21	15.43	9.10	83.11	0.28	19.06	10.76	1.44	70808.00
22	15.49	5.64	87.23	0.25	19.34	10.55	1.45	70874.00
23	15.50	5.31	86.76	0.30	18.42	10.69	1.40	69978.00
24	16.98	9.76	78.22	1.16	17.94	10.97	1.37	69712.00
25	16.01	12.64	78.47	1.23	17.41	10.83	1.38	70365.00
26	15.82	3.69	92.41	1.11	17.85	10.64	1.37	71135.00
27	15.02	6.12	90.02	1.10	17.52	10.92	1.37	70448.00
28	14.50	4.97	86.22	0.97	18.11	10.72	1.36	71237.00
29	14.46	10.06	82.12	1.30	16.40	11.31	1.31	70134.00
30	14.09	10.92	61.41	1.35	16.41	11.29	1.27	69980.00
平均值	15.20	10.62	82.54	0.75	17.37	11.00	1.34	67298.13
最大值	18.16	22.52	93.28	2.44	19.42	12.30	1.46	73515.00
最小值	12.91	3.69	61.41	0.12	10.92	10.35	1.18	59183.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P002_樹林焚化廠CEMS系統月報表

報表日期: 2021年9月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	9.73	10.49	105.18	0.40	15.15	11.69	1.27	53352.00
2	11.80	11.72	106.02	0.33	16.37	11.40	1.27	57520.00
3	12.10	7.27	102.82	0.33	17.06	11.05	1.30	59573.00
4	12.15	5.84	102.49	0.30	17.56	11.11	1.35	60182.00
5	11.57	3.84	99.59	0.27	17.78	10.97	1.34	60196.00
6	11.73	4.29	101.06	0.35	17.42	11.09	1.34	59401.00
7	14.14	3.58	107.26	0.71	18.29	11.34	1.35	61935.00
8	11.80	7.91	98.87	0.34	18.00	11.04	1.36	58531.00
9	13.07	4.47	97.14	0.53	17.63	10.56	1.38	60908.00
10	15.08	7.02	97.33	1.63	17.26	10.68	1.40	61501.00
11	13.78	10.87	97.89	2.03	17.83	10.68	1.43	62139.00
12	14.88	13.04	96.15	0.96	18.06	10.71	1.41	62715.00
13	14.18	10.09	91.41	0.90	18.17	10.46	1.41	61905.00
14	15.00	6.50	98.49	1.52	17.62	10.71	1.39	60882.00
15	15.94	8.65	91.20	1.16	18.67	10.35	1.37	63510.00
16	15.48	8.35	96.21	0.84	18.06	10.60	1.38	62131.00
17	15.06	10.89	94.77	1.41	16.82	10.84	1.38	60616.00
18	14.83	4.64	91.61	0.43	18.65	10.28	1.37	62180.00
19	14.97	2.75	102.26	0.59	18.21	10.56	1.39	62008.00
20	15.31	1.98	94.83	0.69	18.16	10.40	1.39	62056.00
21	14.74	1.79	96.44	0.31	19.16	10.48	1.41	62200.00
22	15.01	4.51	92.87	0.32	18.81	10.65	1.40	62652.00
23	15.26	3.87	103.37	0.46	18.07	10.72	1.39	61477.00
24	15.07	3.81	105.61	0.37	17.71	10.95	1.41	60197.00
25	15.16	5.92	103.50	0.53	17.72	10.76	1.40	61401.00
26	14.89	2.58	107.00	0.54	18.07	10.71	1.42	62013.00
27	14.24	3.13	106.85	0.69	17.54	10.88	1.40	60963.00
28	14.41	3.96	101.35	0.41	17.96	10.89	1.41	60940.00
29	13.74	3.85	102.59	0.34	17.06	11.03	1.40	60822.00
30	14.11	3.66	89.21	0.28	17.73	10.79	1.41	61568.00
平均值	13.97	6.04	99.38	0.67	17.75	10.81	1.38	60915.80
最大值	15.94	13.04	107.26	2.03	19.16	11.69	1.43	63510.00
最小值	9.73	1.79	89.21	0.27	15.15	10.28	1.27	53352.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P003_樹林焚化廠CEMS系統月報表

報表日期: 2021年9月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	12.52	9.58	67.60	1.26	16.76	10.88	1.21	66838.00
2	12.63	9.83	71.89	1.18	17.50	10.71	1.23	71142.00
3	12.73	17.96	58.20	1.12	18.76	9.93	1.29	75928.00
4	12.76	12.19	62.27	1.65	18.36	9.97	1.30	77557.00
5	12.62	16.56	61.31	2.37	18.08	10.07	1.30	77215.00
6	13.47	13.45	57.85	1.63	18.87	9.70	1.32	76922.00
7	15.35	11.67	65.00	1.69	19.00	10.46	1.36	82880.00
8	15.03	18.82	55.02	3.50	18.25	9.92	1.34	74801.00
9	14.28	15.47	58.73	2.07	18.46	9.82	1.35	77310.00
10	13.41	14.85	57.26	2.19	18.64	9.70	1.34	78031.00
11	14.17	18.27	54.53	3.76	18.81	9.52	1.31	80678.00
12	18.64	18.81	67.47	3.51	18.88	10.08	1.32	85214.00
13	15.72	21.15	57.74	2.57	18.71	9.47	1.33	80896.00
14	15.22	17.00	58.57	1.65	19.11	9.53	1.31	80196.00
15	16.68	19.27	57.00	4.72	18.88	9.66	1.31	81125.00
16	15.68	17.15	55.35	3.25	18.62	9.70	1.31	81002.00
17	16.90	16.05	66.02	3.85	17.80	10.09	1.30	81799.00
18	15.22	11.67	63.42	3.29	18.35	9.83	1.28	81609.00
19	15.19	12.02	61.51	2.57	19.20	9.60	1.30	84809.00
20	15.31	9.53	63.47	2.76	19.53	9.44	1.31	85549.00
21	14.82	10.04	56.30	1.68	19.97	9.42	1.31	86404.00
22	14.89	24.05	61.69	2.27	19.12	9.76	1.29	84714.00
23	15.06	11.28	70.57	2.62	18.60	10.03	1.30	81445.00
24	15.07	11.47	71.15	3.03	18.61	10.28	1.29	80662.00
25	15.31	14.07	71.31	3.92	17.75	10.29	1.29	77930.00
26	15.17	9.60	72.79	3.23	18.31	10.19	1.30	81089.00
27	14.42	8.62	73.87	3.30	18.60	10.11	1.30	81382.00
28	13.92	10.74	77.65	2.77	18.00	10.44	1.30	80932.00
29	15.57	11.55	68.53	2.80	17.50	10.38	1.31	81838.00
30	15.22	15.55	64.30	2.43	17.86	9.91	1.30	80198.00
平均值	14.77	14.28	63.61	2.62	18.50	9.96	1.30	79936.50
最大值	18.64	24.05	77.65	4.72	19.97	10.88	1.36	86404.00
最小值	12.52	8.62	54.53	1.12	16.76	9.42	1.21	66838.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。