

P001_樹林焚化廠CEMS系統月報表

報表日期: 2026年7月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	8.38	12.04	50.83	2.87	17.38	11.26	1.21	81820.00
2	8.47	13.23	56.35	3.15	17.36	11.55	1.21	80233.00
3	8.71	12.47	56.58	2.49	17.83	11.20	1.20	81844.00
4	9.72	11.92	55.09	1.89	18.10	11.01	1.20	83205.00
5	9.17	12.69	54.15	2.61	18.13	11.01	1.18	82883.00
6	8.82	12.56	55.58	1.83	17.67	11.45	1.19	79534.00
7	9.21	12.81	52.57	2.51	18.84	11.04	1.19	83526.00
8	8.63	12.61	52.50	2.57	17.28	11.18	1.23	81882.00
9	9.34	12.68	56.01	2.72	16.94	11.18	1.24	82433.00
10	9.09	13.49	54.84	2.91	17.66	11.03	1.25	83348.00
11	9.42	12.77	55.92	2.62	17.24	11.34	1.24	80890.00
12	6.12	12.94	53.11	2.65	16.95	11.34	1.30	81118.00
13	8.97	12.33	53.97	1.78	19.24	11.06	1.28	82016.00
14	9.22	11.36	55.70	2.86	18.99	10.65	1.27	85170.00
15	9.28	11.42	53.51	1.94	18.18	10.89	1.29	83691.00
16	7.78	11.36	53.65	2.36	18.55	10.85	1.28	84104.00
17	9.25	11.68	54.09	2.08	18.24	10.85	1.25	84325.00
18	9.01	11.97	54.55	1.96	17.98	11.02	1.22	82889.00
19	8.59	11.84	56.42	2.47	18.42	10.79	1.22	83516.00
20	8.64	11.63	54.19	2.08	18.54	10.96	1.24	82992.00
21	8.35	11.84	54.64	1.94	18.61	10.82	1.22	84479.00
22	8.52	11.96	50.78	2.16	17.71	10.99	1.23	83700.00
23	9.07	11.51	49.50	2.69	17.88	10.98	1.21	84033.00
24	9.39	12.53	47.78	2.58	18.12	11.01	1.18	83543.00
25	9.38	12.32	54.53	2.20	18.52	10.88	1.20	83469.00
26	9.01	13.53	53.54	2.31	18.69	10.83	1.23	82156.00
27	9.17	12.62	53.81	1.96	18.41	10.86	1.22	83001.00
28	8.94	12.63	56.42	2.47	17.75	11.00	1.23	83429.00
29	9.35	11.13	51.76	2.23	16.90	11.27	1.25	82077.00
30	9.57	11.81	48.69	1.84	17.53	11.13	1.25	82661.00
31	9.05	11.68	50.33	2.10	17.71	11.18	1.26	82214.00
平均 值	8.89	12.24	53.59	2.35	17.98	11.05	1.23	82780.03
最 大 值	9.72	13.53	56.58	3.15	19.24	11.55	1.30	85170.00
最 小 值	6.12	11.13	47.78	1.78	16.90	10.65	1.18	79534.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P002_樹林焚化廠CEMS系統月報表

報表日期: 2026年7月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	3.20	12.58	47.58	1.10	18.71	10.92	0.96	82175.00
2	2.28	12.88	51.11	0.79	16.68	11.67	0.96	78329.00
3	3.97	12.21	54.24	0.95	17.78	11.27	0.99	81668.00
4	2.78	12.33	55.94	0.75	16.50	10.69	0.97	84683.00
5	3.35	13.42	54.97	1.40	18.60	10.97	0.94	83013.00
6	1.83	12.96	52.41	1.10	19.28	10.76	0.93	83427.00
7	1.41	12.73	54.28	1.45	19.11	10.85	0.94	82902.00
8	3.66	12.88	56.42	1.49	17.68	11.16	0.94	81812.00
9	2.41	12.74	55.79	0.98	17.76	11.25	0.92	83485.00
10	2.84	13.55	56.11	1.19	17.39	11.25	0.91	82120.00
11	1.09	13.25	56.15	1.00	16.86	11.58	0.90	79619.00
12	0.82	12.86	51.66	0.89	18.31	11.08	0.94	81833.00
13	1.03	12.99	52.28	0.65	20.29	10.64	0.93	83258.00
14	1.05	11.89	53.96	0.87	19.42	10.73	0.99	83636.00
15	3.75	12.30	50.71	1.22	18.36	10.78	1.00	84231.00
16	4.26	12.57	55.01	0.95	18.08	11.04	0.99	82680.00
17	5.21	12.76	52.34	1.27	18.00	10.93	0.97	83523.00
18	6.26	12.85	57.74	1.03	18.07	10.98	0.99	82862.00
19	6.31	12.88	56.61	1.12	18.19	11.06	0.97	81625.00
20	6.85	12.61	54.15	1.19	18.67	10.86	0.95	82915.00
21	9.15	12.80	53.47	1.68	17.96	11.11	0.92	81457.00
22	9.41	12.85	53.38	1.92	18.01	10.98	0.94	82626.00
23	8.06	12.39	52.04	1.88	18.46	10.78	0.94	83342.00
24	9.34	12.43	49.91	1.73	18.40	10.75	0.95	83759.00
25	9.19	12.66	51.25	1.73	18.46	10.81	0.93	82847.00
26	10.13	13.36	52.07	1.93	18.01	10.98	0.91	82129.00
27	9.54	12.62	54.56	1.50	18.25	10.88	0.90	82068.00
28	8.89	12.59	53.04	1.69	17.75	10.81	0.90	83243.00
29	8.60	12.91	53.79	1.88	16.66	11.31	0.93	80019.00
30	8.11	12.82	51.39	1.59	17.82	11.04	0.93	81442.00
31	8.75	13.03	52.53	1.40	17.96	11.14	0.92	81592.00
平均 值	5.28	12.76	53.45	1.30	18.11	11.00	0.94	82397.42
最 大 值	10.13	13.55	57.74	1.93	20.29	11.67	1.00	84683.00
最 小 值	0.82	11.89	47.58	0.65	16.50	10.64	0.90	78329.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P003_樹林焚化廠CEMS系統月報表

報表日期: 2026年7月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	6.57	11.17	54.61	2.81	18.82	9.08	1.28	74812.00
2	6.73	11.57	48.49	2.57	18.11	9.31	1.30	73582.00
3	7.17	11.65	55.51	2.77	18.56	9.28	1.31	74405.00
4	8.37	11.67	56.76	2.73	18.51	9.49	1.30	75980.00
5	5.29	11.66	54.19	2.67	18.51	9.59	1.29	74037.00
6	5.30	11.71	49.72	2.57	18.75	9.59	1.28	74268.00
7	6.46	11.78	53.52	2.62	18.59	9.66	1.29	74225.00
8	7.05	11.57	48.87	2.73	18.44	9.50	1.29	75314.00
9	4.92	11.68	53.16	2.77	17.28	9.91	1.30	73147.00
10	6.05	12.67	57.33	2.84	18.46	10.18	1.31	75958.00
11	7.41	11.87	54.32	2.51	17.95	9.98	1.35	76528.00
12	5.23	12.31	50.86	2.34	19.25	9.73	1.31	76377.00
13	6.35	11.62	51.48	2.36	20.36	9.52	1.31	77114.00
14	6.73	12.12	56.78	2.41	18.54	10.26	1.32	77710.00
15	7.31	12.03	53.14	1.79	18.00	10.37	1.30	78123.00
16	8.46	11.86	52.80	1.17	18.22	10.38	1.29	79283.00
17	7.60	11.29	58.75	2.43	18.49	10.25	1.29	78815.00
18	6.62	12.34	57.51	2.61	18.20	10.08	1.29	76046.00
19	5.09	12.10	58.58	2.52	18.41	10.22	1.28	77459.00
20	4.14	11.78	54.23	1.95	19.00	10.21	1.32	78348.00
21	3.91	12.04	55.42	1.90	18.61	10.08	1.32	78788.00
22	7.11	11.88	55.64	2.33	19.23	9.87	1.31	79494.00
23	5.31	11.10	52.75	2.50	20.44	9.49	1.29	81200.00
24	3.60	11.77	51.47	1.80	19.06	10.17	1.28	80087.00
25	6.14	12.08	55.45	2.35	18.61	10.38	1.28	78962.00
26	6.76	12.75	57.98	2.46	18.97	10.36	1.29	78486.00
27	5.89	12.35	59.43	2.35	19.11	10.32	1.30	80729.00
28	4.04	12.26	57.86	2.36	18.40	10.32	1.30	79591.00
29	5.09	11.93	57.91	1.91	18.52	10.01	1.29	79153.00
30	5.33	11.46	53.54	1.99	19.03	9.62	1.29	77649.00
31	3.93	11.67	58.46	2.18	18.41	10.05	1.31	74812.00
平 均 值	6.00	11.86	54.73	2.36	18.67	9.91	1.30	77112.32
最 大 值	8.46	12.75	59.43	2.84	20.44	10.38	1.35	81200.00
最 小 值	3.60	11.10	48.49	1.17	17.28	9.08	1.28	73147.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。