

P001_樹林焚化廠CEMS系統月報表

報表日期: 2026年1月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	7.36	12.39	50.94	2.04	16.01	11.73	1.28	80782.00
2	6.53	12.63	54.88	1.94	15.92	11.87	1.25	81317.00
3	7.40	11.96	51.21	1.94	16.19	11.58	1.27	81723.00
4	9.58	11.88	45.86	2.73	16.79	11.40	1.29	82148.00
5	5.24	12.57	44.29	2.38	15.42	11.91	1.32	79441.00
6	7.09	12.25	53.10	2.07	15.70	11.86	1.36	80356.00
7	6.95	12.15	52.91	2.10	16.02	11.59	1.38	82547.00
8	5.48	13.24	52.11	2.26	14.63	12.15	1.36	78952.00
9	6.61	12.58	54.54	2.21	12.04	12.04	1.35	79534.00
10	7.63	12.74	54.11	1.99	14.47	12.29	1.36	77704.00
11	7.48	12.26	50.24	2.96	14.94	12.00	1.34	79275.00
12	6.07	12.94	55.81	2.17	15.38	11.94	1.35	79055.00
13	6.26	12.85	56.31	2.57	15.99	11.61	1.33	81798.00
14	8.07	13.22	50.01	2.07	15.81	11.87	1.31	79322.00
15	7.09	12.61	53.77	2.64	14.79	12.14	1.33	77435.00
16	8.18	12.97	54.67	2.45	15.79	11.89	1.32	78712.00
17	9.94	12.71	57.07	2.73	15.24	11.92	1.29	78968.00
18	8.97	12.52	50.51	3.10	15.02	12.29	1.30	75693.00
19	10.41	12.34	50.49	2.64	15.43	11.87	1.29	78829.00
20	9.73	12.39	50.31	2.79	15.29	11.92	1.28	78620.00
21	10.09	12.52	52.94	2.60	15.11	11.92	1.28	79354.00
22	**	**	**	**	**	**	**	**
23	10.31	13.67	47.63	2.71	13.70	12.62	1.26	76443.00
24	9.10	12.53	52.61	3.12	14.48	12.12	1.26	78670.00
25	11.53	12.68	48.19	2.46	15.25	11.73	1.29	80263.00
26	10.37	12.64	48.94	1.93	14.68	11.94	1.30	79050.00
27	10.68	12.54	46.58	2.28	14.78	11.77	1.28	80217.00
28	10.72	12.69	52.39	2.50	14.65	11.92	1.04	79197.00
29	10.77	12.81	50.83	2.26	14.51	11.98	0.77	78727.00
30	10.14	12.65	50.18	2.74	15.18	11.76	0.91	79546.00
31	10.86	12.55	50.82	2.82	14.82	11.85	1.01	79125.00
平均 值	8.55	12.62	51.48	2.44	15.13	11.92	1.26	79426.77
最 大 值	11.53	13.67	57.07	3.12	16.79	12.62	1.38	82547.00
最 小 值	5.24	11.88	44.29	1.93	12.04	11.40	0.77	75693.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P002_樹林焚化廠CEMS系統月報表

報表日期: 2026年1月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	7.05	11.83	48.53	1.81	17.03	10.33	1.05	79034.00
2	5.51	12.16	45.66	1.91	16.91	10.64	1.06	80094.00
3	8.22	12.22	45.51	2.15	16.32	10.49	1.06	78094.00
4	9.76	12.14	49.11	2.18	16.43	10.58	1.07	78567.00
5	8.04	12.45	51.37	2.27	16.34	11.09	1.06	79301.00
6	8.59	12.62	47.93	2.45	16.29	10.97	1.07	79880.00
7	11.15	12.46	45.86	2.39	16.49	10.50	1.08	80240.00
8	9.77	12.38	47.69	1.92	15.97	10.76	1.07	77917.00
9	7.92	11.97	50.69	1.98	16.27	10.83	1.06	79883.00
10	9.32	12.10	50.83	2.09	16.34	10.47	1.07	78596.00
11	10.64	11.84	48.20	2.00	16.05	10.49	1.10	77901.00
12	10.53	11.81	45.35	1.99	16.85	10.27	1.12	79640.00
13	10.32	12.44	49.19	2.65	16.38	10.55	1.12	78273.00
14	10.73	12.39	42.91	2.44	16.11	10.50	1.11	77650.00
15	9.78	12.70	54.64	2.48	15.68	11.03	1.12	75688.00
16	11.25	12.45	51.26	2.35	16.48	10.77	1.11	77876.00
17	11.39	12.33	52.02	2.37	15.95	10.75	1.10	77665.00
18	10.34	12.24	46.63	2.52	15.95	10.89	1.10	76037.00
19	11.03	12.69	47.95	2.35	16.13	10.64	1.09	75449.00
20	11.08	12.20	49.81	2.57	15.67	10.97	1.11	76796.00
21	11.19	12.81	51.50	2.39	15.42	10.95	1.13	77289.00
22	11.68	12.51	50.28	2.72	14.80	11.12	1.14	78452.00
23	11.51	12.49	49.48	2.76	15.83	10.77	1.09	78793.00
24	10.05	12.17	53.44	2.27	15.56	11.00	1.07	76519.00
25	8.50	11.85	49.56	1.91	16.44	10.45	1.09	76615.00
26	9.63	11.64	49.99	1.77	16.46	10.42	1.10	77007.00
27	7.64	12.09	51.86	1.79	16.10	10.57	1.09	76706.00
28	8.97	12.17	49.66	1.58	15.25	10.80	1.02	76067.00
29	9.68	12.19	49.83	2.16	15.29	10.95	0.98	75798.00
30	10.58	12.11	50.34	2.59	16.12	10.68	0.99	76237.00
31	10.76	11.94	51.65	2.30	16.22	10.60	0.99	76720.00
平 均 值	9.76	12.24	49.31	2.23	16.10	10.70	1.08	77767.23
最 大 值	11.68	12.81	54.64	2.76	17.03	11.12	1.14	80240.00
最 小 值	5.51	11.64	42.91	1.58	14.80	10.27	0.98	75449.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P003_樹林焚化廠CEMS系統月報表

報表日期: 2026年1月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	11.78	11.32	45.61	2.22	16.93	9.70	1.39	72434.00
2	11.48	12.12	47.98	1.59	16.25	10.00	1.40	73484.00
3	11.29	12.70	54.53	2.58	15.72	10.51	1.38	72424.00
4	10.35	12.71	48.61	2.16	15.79	10.22	1.37	71823.00
5	10.46	11.84	48.23	2.31	16.09	10.02	1.38	73551.00
6	8.14	11.96	47.84	2.21	15.79	10.49	1.36	74001.00
7	10.82	11.70	43.25	2.05	16.93	9.34	1.36	73867.00
8	9.99	11.48	48.95	2.10	15.83	9.89	1.36	74324.00
9	9.44	12.40	51.34	2.52	15.09	10.56	1.40	73980.00
10	9.48	12.27	45.71	2.11	15.89	9.80	1.41	72219.00
11	9.30	12.26	50.53	2.60	15.35	10.18	1.41	72654.00
12	9.05	12.14	46.99	2.30	15.88	10.24	1.42	73997.00
13	8.99	11.69	53.51	2.11	14.88	10.56	1.43	71980.00
14	9.00	11.65	51.99	2.23	15.26	10.44	1.44	71373.00
15	8.78	12.13	46.28	2.15	16.09	9.95	1.43	72081.00
16	9.77	12.16	50.69	2.47	15.88	10.46	1.38	73746.00
17	9.27	12.19	43.50	2.05	16.44	9.39	1.33	72864.00
18	9.40	11.51	39.61	1.81	16.56	9.39	1.34	72218.00
19	9.76	11.07	43.05	2.17	16.29	9.68	1.37	72664.00
20	10.21	11.84	49.03	2.20	15.22	10.21	1.36	73094.00
21	10.30	12.06	47.01	2.57	15.64	10.02	1.35	73096.00
22	9.24	11.93	40.99	2.27	15.56	9.67	1.36	72876.00
23	9.66	11.67	42.40	1.76	16.39	9.62	1.41	73049.00
24	7.77	11.32	37.13	2.18	16.67	9.24	1.40	71667.00
25	8.00	11.94	42.87	1.90	16.59	9.66	1.37	71998.00
26	8.22	11.72	41.17	2.23	16.38	9.43	1.36	71402.00
27	7.53	11.70	43.52	2.17	15.88	9.67	1.36	71751.00
28	8.04	11.80	43.79	2.41	15.74	9.35	1.40	71020.00
29	8.92	11.61	48.28	2.35	15.05	10.00	1.47	71623.00
30	9.11	11.68	42.82	2.32	16.12	9.70	1.45	70779.00
31	10.40	11.97	47.03	2.33	16.12	9.86	1.42	72434.00
平均 值	9.48	11.89	46.27	2.21	15.95	9.91	1.39	72595.90
最 大 值	11.78	12.71	54.53	2.60	16.93	10.56	1.47	74324.00
最 小 值	7.53	11.07	37.13	1.59	14.88	9.24	1.33	70779.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。