

P001_樹林焚化廠CEMS系統月報表

報表日期: 2020年08月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	12.99	9.10	59.29	6.33	14.65	11.27	0.88	104326.00
2	13.59	10.45	59.98	5.50	14.56	11.27	0.90	102577.00
3	11.13	7.89	63.61	5.23	15.19	11.38	0.89	103786.00
4	7.91	13.25	59.59	5.04	15.13	11.50	0.89	103558.00
5	11.42	9.20	56.24	5.21	14.97	11.50	0.85	104499.00
6	11.53	8.19	55.98	5.11	15.48	11.32	0.85	106452.00
7	8.04	6.25	54.03	5.19	15.39	11.21	0.86	105236.00
8	8.12	7.30	59.16	5.40	15.33	11.47	0.85	105767.00
9	11.11	6.79	56.22	5.46	15.16	11.28	0.85	107316.00
10	8.10	4.31	62.74	5.23	15.03	11.34	0.88	104891.00
11	10.27	3.41	63.67	4.90	15.11	11.44	0.86	104080.00
12	15.38	8.47	56.02	5.27	14.91	11.46	0.88	104251.00
13	10.35	3.03	58.03	4.62	15.33	11.59	0.86	104483.00
14	8.28	6.54	54.58	4.46	15.86	11.30	0.84	106199.00
15	8.91	12.36	53.54	4.81	15.40	11.46	0.81	105110.00
16	8.87	9.22	57.00	4.60	15.69	11.49	0.81	105756.00
17	9.87	4.07	56.89	4.56	15.23	11.49	0.82	105518.00
18	6.98	9.43	55.29	4.35	15.61	11.39	0.80	106534.00
19	10.22	15.37	55.79	4.72	15.60	11.37	0.78	105449.00
20	6.17	5.44	56.80	4.35	15.63	11.51	0.79	105547.00
21	5.98	4.30	57.62	4.41	15.70	11.49	0.80	106658.00
22	3.68	4.33	55.84	4.30	15.53	11.65	0.81	104813.00
23	4.86	11.95	54.33	4.55	15.27	11.55	0.81	104981.00
24	4.13	8.18	55.43	4.41	15.66	11.46	0.90	104862.00
25	3.24	9.10	53.58	4.29	15.57	11.31	1.07	107299.00
26	7.62	23.71	53.87	5.32	14.65	11.53	1.05	103722.00
27	6.70	7.14	54.14	4.64	14.68	11.49	1.05	105660.00
28	6.28	13.47	55.86	4.63	14.83	11.57	1.04	104790.00
29	5.89	11.16	57.94	4.61	15.08	11.61	1.03	105272.00
30	3.25	14.04	56.38	4.62	14.82	11.59	1.06	105042.00
31	2.65	7.99	58.83	4.43	15.19	11.58	1.07	104288.00
平均值	8.18	8.89	57.04	4.86	15.23	11.45	0.89	105120.06
最大值	15.38	23.71	63.67	6.33	15.86	11.65	1.07	107316.00
最小值	2.65	3.03	53.54	4.29	14.56	11.21	0.78	102577.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P002_樹林焚化廠CEMS系統月報表

報表日期: 2020年08月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	3.15	11.40	77.82	4.75	13.76	11.64	0.64	80807.00
2	3.47	6.86	77.49	4.68	13.74	11.72	0.68	79467.00
3	2.39	6.44	86.39	4.61	14.22	11.78	0.69	79981.00
4	1.88	12.32	77.26	4.61	14.47	11.79	0.59	79811.00
5	1.91	12.92	74.09	4.76	14.01	11.81	0.63	79770.00
6	1.40	10.81	75.30	4.58	14.67	11.66	0.70	80252.00
7	1.60	13.31	73.75	4.73	14.36	11.66	0.74	80566.00
8	1.33	8.82	74.61	4.71	14.25	11.76	0.81	79871.00
9	1.19	9.05	77.08	4.71	14.47	11.63	0.92	80979.00
10	1.12	3.48	71.77	4.54	14.63	11.53	0.90	81573.00
11	0.85	17.16	68.69	4.39	14.68	11.44	0.85	80195.00
12	2.25	16.44	69.93	4.96	14.43	11.76	0.79	79590.00
13	1.56	5.69	69.82	4.63	14.50	11.73	0.79	79609.00
14	1.17	9.62	68.90	4.44	15.10	11.55	0.77	80486.00
15	1.41	12.51	68.51	4.67	14.72	11.66	0.79	80643.00
16	1.06	9.21	67.43	4.49	15.31	11.52	0.83	81410.00
17	1.14	6.60	74.87	4.61	14.73	11.61	0.87	80758.00
18	1.13	20.73	71.63	4.65	15.11	11.56	0.84	80092.00
19	1.38	12.42	71.73	4.58	14.36	11.76	0.80	80007.00
20	0.92	6.60	76.98	4.59	14.61	11.79	0.81	79230.00
21	0.78	18.92	70.79	4.43	14.79	11.62	0.83	81076.00
22	0.58	7.09	69.89	4.38	14.92	11.74	0.74	80555.00
23	0.75	10.08	72.58	4.54	14.26	11.74	0.74	79621.00
24	1.07	9.72	73.38	4.49	14.64	11.76	0.88	79941.00
25	0.77	18.82	72.63	4.90	14.73	11.84	1.08	78989.00
26	1.85	33.14	67.20	4.75	14.39	11.72	1.06	79554.00
27	1.97	29.48	72.62	4.41	14.56	11.66	1.05	80153.00
28	1.45	18.93	71.69	4.49	14.81	11.61	1.00	80169.00
29	1.42	12.73	72.34	4.55	14.40	11.84	1.06	78532.00
30	1.15	17.20	70.84	4.42	14.53	11.63	1.12	80042.00
31	0.70	7.93	69.16	4.32	14.87	11.65	1.11	79817.00
平均值	1.45	12.79	72.81	4.59	14.55	11.68	0.84	80114.39
最大值	3.47	33.14	86.39	4.96	15.31	11.84	1.12	81573.00
最小值	0.58	3.48	67.20	4.32	13.74	11.44	0.59	78532.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P003_樹林焚化廠CEMS系統月報表

報表日期: 2020年08月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	12.37	19.38	73.86	8.14	18.91	8.53	1.23	87321.00
2	11.45	22.70	68.71	7.19	19.26	8.37	1.19	86620.00
3	13.23	11.17	71.76	8.16	19.85	8.57	1.19	90331.00
4	12.36	14.85	79.69	7.22	19.77	9.01	1.19	90797.00
5	19.78	27.13	75.66	7.82	19.24	9.08	1.22	89641.00
6	20.89	9.26	84.09	7.31	19.60	9.24	1.21	96885.00
7	16.19	11.91	81.60	7.42	19.43	9.06	1.24	91050.00
8	12.12	9.38	80.87	7.34	19.25	9.10	1.26	91697.00
9	11.33	11.08	80.85	6.97	19.54	8.84	1.22	92542.00
10	8.07	4.99	83.42	6.91	19.78	8.82	1.20	92671.00
11	18.71	13.04	81.36	6.88	20.11	9.19	1.26	99173.00
12	19.03	18.69	75.75	7.03	19.49	9.42	1.21	89326.00
13	17.27	10.83	79.03	6.88	19.38	9.63	1.19	88541.00
14	15.41	11.53	81.30	7.10	19.45	9.86	1.19	89992.00
15	**	**	**	**	**	**	**	**
16	18.74	6.11	75.97	6.49	19.46	9.19	1.14	93017.00
17	17.48	7.20	75.30	6.29	19.08	9.16	1.14	90551.00
18	18.10	10.67	77.91	6.40	18.99	9.33	1.16	92699.00
19	16.27	17.27	72.66	6.45	19.24	8.98	1.16	90014.00
20	16.52	10.61	78.80	6.78	18.96	9.17	1.15	89503.00
21	13.64	8.81	77.12	6.75	19.17	9.22	1.14	95355.00
22	16.68	10.30	80.04	6.89	18.97	9.53	1.15	93190.00
23	14.55	10.18	76.42	7.10	19.01	9.30	1.16	93368.00
24	15.89	14.20	75.95	9.23	19.23	8.63	1.17	89631.00
25	**	**	**	**	**	**	**	**
26	20.83	18.65	76.95	6.88	17.92	9.31	1.14	95048.00
27	17.72	12.00	84.69	6.30	19.06	9.36	1.13	99626.00
28	19.56	11.91	81.99	6.94	18.90	9.13	1.12	97619.00
29	20.70	18.82	82.55	6.99	18.69	9.25	1.13	95055.00
30	13.31	14.12	85.66	6.85	19.28	9.09	1.12	96245.00
31	15.48	15.25	83.68	7.88	18.49	9.16	1.14	92501.00
平均值	15.99	13.17	78.75	7.12	19.22	9.12	1.18	92414.10
最大值	20.89	27.13	85.66	9.23	20.11	9.86	1.26	99626.00
最小值	8.07	4.99	68.71	6.29	17.92	8.37	1.12	86620.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。