

P001_樹林焚化廠CEMS系統月報表

報表日期: 2025年12月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	4.82	12.78	50.44	1.55	16.18	11.69	1.32	78715.00
2	5.07	12.15	49.54	1.67	16.68	11.71	1.31	79099.00
3	9.00	14.02	53.93	2.21	15.82	12.04	1.30	76399.00
4	3.20	13.43	54.02	2.22	15.18	12.33	1.27	75711.00
5	4.51	13.80	51.69	2.20	15.26	12.26	1.28	76351.00
6	8.27	13.71	52.24	2.53	15.32	12.28	1.28	75673.00
7	4.74	12.25	55.82	2.48	15.06	12.11	1.27	76715.00
8	6.58	12.81	52.62	2.01	14.91	12.09	1.23	77579.00
9	10.08	13.00	52.22	2.44	15.62	11.94	1.24	78876.00
10	11.78	12.61	53.37	2.61	15.41	12.05	1.24	77405.00
11	11.61	12.30	54.62	2.18	15.27	12.18	1.24	76548.00
12	12.10	12.36	49.60	2.59	16.05	11.91	1.24	78074.00
13	11.47	13.48	54.36	2.95	16.11	11.94	1.26	77691.00
14	11.85	12.99	48.68	2.59	15.82	11.96	1.25	77737.00
15	11.10	13.35	53.08	2.79	14.82	12.23	1.27	76450.00
16	11.99	12.71	52.54	2.37	15.81	11.98	1.29	77188.00
17	12.20	12.86	52.04	2.33	16.23	11.69	1.33	79098.00
18	11.60	13.18	50.88	2.76	16.77	11.46	1.28	77287.00
19	11.75	13.12	52.85	2.81	16.81	11.69	1.27	78776.00
20	11.70	13.05	52.77	2.33	16.38	11.88	1.26	77459.00
21	12.03	13.26	47.85	2.95	16.07	11.81	1.27	78790.00
22	8.53	12.85	52.01	2.46	15.22	12.17	1.27	76719.00
23	9.75	12.99	51.90	2.56	16.65	11.66	1.28	79728.00
24	9.29	12.66	53.23	2.71	16.35	11.50	1.26	82067.00
25	5.85	12.88	48.83	2.02	16.39	11.52	1.23	81991.00
26	5.89	12.44	50.96	2.00	16.36	11.51	1.23	82198.00
27	7.93	12.45	49.36	2.35	16.42	11.47	1.28	82342.00
28	5.84	12.10	49.06	1.64	16.62	11.51	1.29	82468.00
29	5.87	13.23	49.38	1.96	15.93	11.57	1.30	79837.00
30	5.53	13.40	54.67	1.97	16.15	11.73	1.31	80536.00
31	7.54	12.22	51.16	2.06	16.40	11.57	1.33	81662.00
平均 值	8.69	12.92	51.80	2.33	15.94	11.85	1.27	78618.35
最 大 值	12.20	14.02	55.82	2.95	16.81	12.33	1.33	82468.00
最 小 值	3.20	12.10	47.85	1.55	14.82	11.46	1.23	75673.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P002_樹林焚化廠CEMS系統月報表

報表日期: 2025年12月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	5.51	12.00	43.68	1.02	17.46	9.85	1.03	80523.00
2	9.24	12.17	45.59	2.13	18.97	10.31	1.02	80480.00
3	10.83	13.19	50.45	2.50	16.41	10.41	1.02	79149.00
4	6.68	13.29	47.77	2.59	16.56	10.39	0.97	80274.00
5	6.74	12.78	46.47	1.96	16.28	10.35	0.99	79645.00
6	11.85	11.93	43.20	2.28	17.34	9.94	1.02	80743.00
7	10.15	12.55	47.03	2.89	17.06	9.82	1.02	79592.00
8	9.12	11.56	43.36	2.18	17.02	9.62	1.03	79304.00
9	12.48	12.39	46.28	1.80	17.07	10.01	1.03	79845.00
10	13.48	12.22	43.94	2.01	16.77	9.97	1.02	79789.00
11	11.42	12.63	44.85	1.73	16.66	10.28	0.99	79862.00
12	11.57	11.60	48.58	1.81	17.02	10.22	1.02	79647.00
13	13.55	11.60	45.33	2.59	17.61	9.80	0.99	79678.00
14	13.79	12.58	46.72	2.82	16.26	10.25	0.94	79863.00
15	12.60	12.33	43.79	2.51	16.50	9.78	0.93	78514.00
16	12.04	12.30	50.81	1.75	16.28	10.57	0.99	80049.00
17	11.84	12.23	46.84	2.02	16.34	10.26	1.07	79288.00
18	11.84	12.90	44.82	2.21	16.72	10.16	1.06	79255.00
19	12.07	11.89	46.01	1.74	17.03	10.23	1.05	79579.00
20	12.86	12.53	49.45	2.44	16.84	10.42	1.03	78696.00
21	12.46	12.68	37.55	1.95	17.46	10.01	1.02	79917.00
22	11.74	12.19	45.33	1.65	17.29	10.04	1.01	81491.00
23	10.88	12.16	43.03	1.60	17.93	10.19	1.05	79771.00
24	11.50	12.56	48.92	2.06	16.53	10.60	1.04	77777.00
25	7.89	12.44	46.95	1.61	17.07	10.56	1.06	77959.00
26	5.86	12.63	49.93	1.78	16.61	10.90	1.08	77315.40
27	7.04	12.73	49.89	1.94	16.36	11.08	1.10	77623.00
28	3.77	12.64	48.78	1.63	16.78	10.86	1.10	78627.00
29	3.65	12.39	43.19	1.35	17.52	10.25	1.10	78766.00
30	4.91	12.58	44.79	1.65	17.52	10.36	1.08	78003.00
31	7.66	12.19	49.09	1.91	16.92	10.36	1.09	78105.00
平 均 值	9.90	12.38	46.21	2.00	16.97	10.25	1.03	79326.75
最 大 值	13.79	13.29	50.81	2.89	18.97	11.08	1.10	81491.00
最 小 值	3.65	11.56	37.55	1.02	16.26	9.62	0.93	77315.40

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P003_樹林焚化廠CEMS系統月報表

報表日期: 2025年12月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	11.84	12.19	40.72	1.56	17.12	9.64	1.33	75543.00
2	11.93	11.79	45.35	1.99	16.50	10.31	1.31	76002.00
3	11.75	12.43	41.74	2.58	16.87	9.69	1.28	74629.00
4	11.39	12.54	35.44	1.97	17.72	9.42	1.30	75137.00
5	10.96	12.67	45.83	2.35	16.55	10.37	1.34	73764.00
6	11.93	11.77	37.75	2.00	17.44	9.73	1.35	73371.00
7	10.00	13.08	42.87	2.24	18.07	9.39	1.35	72943.00
8	10.57	11.94	41.60	1.83	17.35	9.61	1.37	73593.00
9	12.41	11.87	46.91	1.71	17.39	10.07	1.37	77319.00
10	10.68	11.71	43.30	2.28	17.60	9.57	1.37	75764.00
11	11.24	12.13	42.64	1.88	18.11	9.48	1.36	75836.00
12	11.06	11.81	45.27	2.25	18.28	9.43	1.36	76590.00
13	11.26	12.55	44.08	2.10	18.74	9.33	1.37	76258.00
14	11.30	12.63	50.30	2.25	16.80	10.26	1.38	79086.00
15	11.00	11.92	43.74	3.36	17.12	9.68	1.40	77097.00
16	12.08	12.30	50.62	2.54	16.97	10.13	1.21	76558.00
17	11.96	13.09	45.36	2.09	17.65	9.71	0.90	77030.00
18	11.78	14.09	41.78	2.33	18.06	9.49	1.00	75007.00
19	12.06	11.99	49.49	2.37	17.67	9.97	1.06	76272.00
20	12.35	12.27	54.20	2.36	16.48	10.55	1.12	75388.00
21	12.01	12.14	50.20	2.81	16.06	10.37	1.14	74387.00
22	12.01	13.19	42.01	2.82	17.05	9.54	1.20	75456.00
23	11.42	12.43	46.10	2.24	16.81	9.89	1.23	73183.00
24	11.71	11.89	41.83	2.63	17.16	9.42	1.26	72347.00
25	11.76	12.08	43.60	2.46	16.88	9.63	1.28	73536.00
26	11.71	12.50	49.07	2.40	16.66	10.15	1.30	74778.00
27	11.67	11.74	45.14	2.37	16.68	9.89	1.34	73120.00
28	10.00	11.89	50.03	2.58	16.48	10.29	1.34	72297.00
29	9.07	11.60	48.29	2.46	16.81	9.99	1.32	73629.00
30	11.65	12.17	55.92	2.63	15.74	10.87	1.37	72435.00
31	11.50	11.86	46.33	2.07	16.99	9.80	1.38	75543.00
平均 值	11.42	12.27	45.40	2.31	17.16	9.86	1.28	74964.45
最 大 值	12.41	14.09	55.92	3.36	18.74	10.87	1.40	79086.00
最 小 值	9.07	11.60	35.44	1.56	15.74	9.33	0.90	72297.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。