

P001_樹林焚化廠CEMS系統月報表

報表日期: 2020年10月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	5.62	8.37	60.36	0.75	14.76	11.51	1.09	94450.00
2	3.33	4.39	57.48	0.31	15.56	11.43	1.13	93778.00
3	2.81	3.04	54.64	0.23	15.55	11.39	1.15	93716.00
4	2.59	7.43	57.91	0.29	15.82	11.41	1.15	92894.00
5	5.09	10.98	75.14	1.08	15.06	12.56	1.11	81900.00
6	2.62	5.90	55.02	0.33	14.92	11.59	1.11	92787.00
7	6.17	9.26	54.86	0.56	15.04	11.52	1.11	93258.00
8	5.53	8.32	55.83	0.69	14.98	11.53	1.10	92086.00
9	3.70	3.68	55.96	0.34	15.30	11.50	1.10	93091.00
10	3.13	4.92	54.58	0.30	15.73	11.36	1.12	94371.00
11	3.15	2.95	55.57	0.23	16.03	11.42	1.16	93333.00
12	3.13	7.19	59.61	0.33	15.53	11.46	1.18	92442.00
13	3.71	7.60	56.02	0.52	15.47	11.50	1.19	92882.00
14	4.19	5.51	54.36	0.49	15.46	11.35	1.19	94020.00
15	7.36	7.30	56.27	1.07	14.91	11.41	1.17	93619.00
16	5.37	4.76	58.14	0.81	14.78	11.50	1.19	92950.00
17	5.02	4.61	60.17	0.69	14.78	11.49	1.14	93108.00
18	3.27	4.14	65.00	0.47	15.40	11.51	1.14	92164.00
19	4.03	7.80	58.61	0.73	15.15	11.44	1.16	93293.00
20	2.76	5.03	57.95	0.46	15.46	11.44	1.14	92866.00
21	8.20	8.23	58.19	1.30	15.32	11.35	1.13	93102.00
22	5.58	9.61	62.03	1.53	14.88	11.46	1.11	92570.00
23	8.79	5.63	64.95	2.12	14.15	11.59	1.09	92450.00
24	7.54	4.86	64.88	2.14	14.07	11.58	1.15	92827.00
25	3.60	2.77	66.91	1.22	14.96	11.57	1.15	91748.00
26	3.57	6.13	72.51	1.44	14.78	12.26	1.14	85008.00
27	4.30	4.39	79.19	1.67	14.78	13.06	1.18	76995.00
28	10.49	11.75	76.42	2.69	14.66	13.04	1.20	76937.00
29	3.42	8.24	73.96	1.53	15.24	12.97	1.19	78127.00
30	4.19	9.12	72.89	1.83	14.63	13.01	1.15	78898.00
31	4.45	9.34	73.69	2.38	13.84	13.15	1.16	77897.00
平均值	4.73	6.56	62.23	0.98	15.06	11.79	1.14	89986.03
最大值	10.49	11.75	79.19	2.69	16.03	13.15	1.20	94450.00
最小值	2.59	2.77	54.36	0.23	13.84	11.35	1.09	76937.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P002_樹林焚化廠CEMS系統月報表

報表日期: 2020年10月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	2.35	13.28	69.92	1.15	13.71	11.80	1.14	80820.00
2	1.34	5.58	68.97	0.69	14.00	11.81	1.15	79870.00
3	1.05	9.60	73.02	0.58	14.23	11.65	1.13	80393.00
4	0.85	12.75	66.07	0.70	14.45	11.70	1.08	79561.00
5	0.83	7.44	66.44	0.73	13.99	11.85	1.11	79315.00
6	0.63	10.99	68.60	0.81	13.63	11.98	1.12	78756.00
7	1.27	13.41	68.34	0.97	13.47	11.84	1.10	79628.00
8	2.15	15.65	69.67	1.16	13.79	12.60	1.09	73199.00
9	1.03	10.11	68.84	0.88	13.83	11.83	1.07	81120.00
10	0.79	11.79	73.85	0.81	13.82	11.91	1.10	79241.00
11	0.60	7.46	71.65	0.70	14.34	11.74	1.11	78770.00
12	0.60	3.42	78.94	0.79	13.78	12.00	1.11	77246.00
13	0.75	7.74	66.22	0.80	13.84	11.77	1.11	79979.00
14	1.13	12.56	68.74	0.96	13.72	11.84	1.09	79066.00
15	1.87	14.19	72.65	1.21	13.08	12.00	1.07	78277.00
16	0.94	20.72	68.90	1.06	13.12	12.02	1.09	78152.00
17	1.06	12.98	77.61	1.01	13.26	11.95	1.08	79154.00
18	0.75	4.20	89.04	1.01	13.66	12.10	1.06	78154.00
19	0.56	3.84	74.06	0.92	13.83	11.85	1.08	80253.00
20	0.52	11.29	74.05	1.53	12.45	12.35	1.13	70533.00
21	0.85	7.37	69.75	1.98	11.59	12.84	1.11	59506.00
22	1.42	6.18	81.27	2.67	10.44	13.24	1.06	60540.00
23	2.27	3.72	75.39	3.02	10.06	13.21	1.06	62177.00
24	3.28	3.99	83.42	3.46	9.47	13.57	0.98	71502.00
25	0.97	3.93	76.96	2.35	11.16	13.06	0.96	76559.00
26	0.57	16.91	79.11	2.51	11.50	13.69	1.04	69962.00
27	1.08	22.41	94.72	3.12	11.09	14.81	1.07	58864.00
28	1.95	17.18	93.60	3.77	11.03	14.85	1.08	58338.00
29	1.56	9.20	95.39	3.30	10.83	14.85	1.17	58413.00
30	1.33	10.81	87.03	3.46	10.75	14.67	1.36	59993.00
31	1.21	10.69	82.15	3.30	10.63	14.57	1.41	61160.00
平均值	1.21	10.37	75.95	1.66	12.66	12.64	1.11	73177.45
最大值	3.28	22.41	95.39	3.77	14.45	14.85	1.41	81120.00
最小值	0.52	3.42	66.07	0.58	9.47	11.65	0.96	58338.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P003_樹林焚化廠CEMS系統月報表

報表日期: 2020年10月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	29.06	12.27	89.49	5.31	16.00	10.99	1.29	85967.00
2	21.20	6.34	88.03	4.75	16.20	11.21	1.31	84609.00
3	23.79	4.09	94.27	5.26	11.23	11.23	1.31	84470.00
4	17.97	7.71	93.86	4.70	17.95	10.90	1.32	87720.00
5	21.98	13.20	81.02	4.10	17.58	10.99	1.27	82005.00
6	25.83	11.16	90.01	6.00	16.72	11.00	1.24	86520.00
7	18.79	13.42	88.05	5.55	15.93	11.03	1.28	85424.00
8	18.98	9.83	88.52	5.28	15.59	11.05	1.33	84371.00
9	19.55	8.77	89.83	5.65	16.03	10.91	1.37	86011.00
10	18.90	8.11	92.99	5.58	16.26	10.93	1.37	85046.00
11	16.05	6.51	86.24	5.72	16.89	10.70	1.35	85904.00
12	13.35	4.17	83.91	4.99	16.60	10.63	1.34	85092.00
13	14.12	11.76	82.12	5.15	15.91	10.81	1.35	83087.00
14	16.30	12.02	83.72	5.52	15.92	10.75	1.34	84475.00
15	15.09	10.71	80.78	5.58	15.93	10.59	1.34	83994.00
16	18.61	13.20	81.95	5.98	17.81	10.51	1.33	84090.00
17	15.44	14.27	88.31	5.29	17.74	11.11	1.27	85497.00
18	15.25	21.86	89.57	5.31	18.15	11.16	1.29	85010.00
19	15.33	11.75	86.03	5.50	18.83	10.64	1.23	88749.00
20	6.96	12.45	83.31	5.17	18.39	10.76	1.24	81595.00
21	15.02	7.27	82.91	6.02	16.26	11.59	1.29	63822.00
22	19.29	13.70	87.74	6.21	14.96	11.00	1.24	75027.00
23	14.07	8.49	87.50	5.83	15.03	10.78	1.22	77192.00
24	16.86	12.39	72.27	5.96	15.52	10.60	1.22	85320.00
25	14.00	10.15	58.85	5.34	18.08	9.98	1.28	88488.00
26	13.73	13.34	59.58	3.04	17.44	10.38	1.31	86403.00
27	13.74	15.68	67.33	1.50	16.42	10.90	1.31	82345.00
28	17.54	17.97	55.87	3.84	16.43	10.60	1.31	82736.00
29	18.21	12.72	66.51	3.30	16.68	10.64	1.30	83185.00
30	19.66	14.78	72.15	3.41	16.32	10.81	1.26	82732.00
31	**	**	**	**	**	**	**	**
平均值	17.49	11.34	81.76	5.03	16.49	10.84	1.30	83562.87
最大值	29.06	21.86	94.27	6.21	18.83	11.59	1.37	88749.00
最小值	6.96	4.09	55.87	1.50	11.23	9.98	1.22	63822.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。