

P001_樹林焚化廠CEMS系統月報表

報表日期: 2021年2月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	3.33	13.82	76.99	1.27	13.19	13.57	1.22	75210.00
2	3.26	13.58	70.58	1.34	13.21	13.41	1.22	76312.00
3	6.53	16.80	71.36	1.30	13.34	13.32	1.23	77376.00
4	5.50	14.51	71.29	1.40	12.90	13.52	1.20	76289.00
5	4.27	11.01	71.78	1.08	13.33	13.46	1.22	76210.00
6	3.83	23.03	66.11	1.13	13.25	13.48	1.26	74432.00
7	4.99	15.75	64.80	1.55	12.98	13.31	1.28	73803.00
8	8.28	16.35	68.89	1.56	13.20	13.26	1.24	74531.00
9	8.43	9.72	67.76	2.09	12.29	13.64	1.21	75988.00
10	8.90	13.16	75.66	1.82	12.67	13.76	1.23	74443.00
11	5.53	10.52	66.77	1.65	12.86	13.71	1.16	76212.00
12	6.93	15.94	59.11	1.39	13.60	13.44	1.26	76758.00
13	9.11	11.08	74.00	2.12	12.59	13.91	1.25	73094.00
14	5.26	6.98	68.78	1.82	12.87	13.79	1.27	74744.00
15	5.18	6.91	76.28	2.19	12.38	14.12	1.26	71712.00
16	2.71	12.95	60.93	1.20	13.41	13.61	1.27	75992.00
17	2.97	3.35	78.17	1.58	12.92	13.79	1.22	74992.00
18	3.44	6.41	71.63	1.69	12.37	13.71	1.23	76767.00
19	3.22	6.97	67.16	1.21	12.98	13.66	1.29	76546.00
20	6.64	10.30	63.70	1.50	12.78	13.58	1.29	76690.00
21	12.70	8.19	63.93	2.19	12.12	13.76	1.28	74743.00
22	7.28	4.18	67.71	1.95	12.04	13.89	1.29	73792.00
23	5.75	19.90	63.26	2.05	12.73	13.88	1.36	72698.00
24	9.71	10.15	69.94	2.52	12.90	13.85	1.31	73149.00
25	3.46	8.84	64.65	1.30	13.84	13.69	1.26	74417.00
26	5.65	15.50	64.95	2.11	13.03	13.90	1.27	72563.00
27	3.70	15.03	62.41	1.72	13.22	13.79	1.23	73864.00
28	3.54	11.92	68.21	1.73	13.24	13.80	1.25	73444.00
平均值	5.72	11.89	68.46	1.66	12.94	13.66	1.25	74884.68
最大值	12.70	23.03	78.17	2.52	13.84	14.12	1.36	77376.00
最小值	2.71	3.35	59.11	1.08	12.04	13.26	1.16	71712.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P002_樹林焚化廠CEMS系統月報表

報表日期: 2021年2月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	12.85	13.36	68.57	1.00	14.55	11.41	1.48	59788.00
2	16.01	8.68	70.05	0.95	15.28	10.83	1.44	65487.00
3	15.52	9.21	75.40	1.11	16.21	10.77	1.40	65258.00
4	14.17	8.44	70.99	1.31	15.71	10.93	1.37	63971.00
5	13.67	9.41	69.30	1.08	16.27	10.65	1.37	63432.00
6	15.38	10.26	66.30	1.46	16.43	10.70	1.39	64455.00
7	15.94	8.12	84.51	1.24	16.23	10.99	1.35	63053.00
8	20.80	8.22	65.72	1.65	17.41	10.79	1.31	63476.00
9	24.45	13.77	68.27	1.47	17.62	10.87	1.26	64526.00
10	25.45	15.15	74.57	1.57	18.16	10.83	1.28	64740.00
11	26.01	8.42	71.68	0.81	17.10	10.80	1.31	64767.00
12	21.95	8.30	73.20	0.88	17.26	10.70	1.32	65609.00
13	27.76	13.44	77.57	1.19	17.25	10.82	1.33	65313.00
14	20.13	14.61	67.53	0.93	17.22	10.73	1.34	64621.00
15	14.32	8.86	69.52	0.74	17.78	10.69	1.34	65343.00
16	15.81	11.68	69.34	0.23	21.42	10.18	1.36	67411.00
17	22.30	12.74	68.77	0.57	21.24	10.11	1.31	67923.00
18	17.42	11.02	79.96	0.25	20.91	10.46	1.28	67717.00
19	20.40	13.07	93.06	2.29	21.46	10.21	1.27	68746.00
20	20.25	7.21	86.69	0.54	21.68	10.09	1.29	69312.00
21	23.17	6.40	97.75	1.16	20.72	10.13	1.31	66853.00
22	14.74	7.69	96.18	0.29	20.65	10.40	1.34	65519.00
23	14.99	14.63	94.98	0.52	20.30	10.62	1.31	64634.00
24	16.59	11.54	98.14	0.90	18.94	10.47	1.32	66399.00
25	6.66	14.00	98.91	0.53	19.68	10.04	1.31	66074.00
26	9.74	9.89	91.77	0.22	18.83	10.30	1.31	67970.00
27	14.07	10.21	97.21	0.38	18.17	10.22	1.32	68288.00
28	10.19	4.08	97.42	0.27	19.09	10.34	1.32	68291.00
平均值	17.53	10.44	80.12	0.91	18.34	10.57	1.33	65677.71
最大值	27.76	15.15	98.91	2.29	21.68	11.41	1.48	69312.00
最小值	6.66	4.08	65.72	0.22	14.55	10.04	1.26	59788.00

備註： 1.*:儀器保養維護中。
2.**:停爐中。

P003_樹林焚化廠CEMS系統月報表

報表日期: 2021年2月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	12.01	8.55	59.96	2.41	13.49	11.37	1.47	77719.00
2	15.40	8.88	55.93	2.68	14.17	11.05	1.44	80218.00
3	17.48	18.13	57.56	3.17	14.94	11.02	1.45	81054.00
4	13.10	16.87	55.41	2.42	14.10	10.99	1.44	81211.00
5	10.52	8.71	57.07	2.03	14.20	11.01	1.46	81479.00
6	18.22	12.37	54.91	2.37	14.25	10.98	1.45	82967.00
7	17.80	8.72	66.73	2.59	14.26	11.22	1.43	82486.00
8	19.85	11.92	56.26	2.65	14.16	11.07	1.40	80760.00
9	22.42	16.76	53.69	2.86	13.63	11.19	1.40	79940.00
10	22.99	9.17	60.89	2.24	14.37	11.30	1.40	80516.00
11	22.55	9.06	58.36	2.03	14.43	11.10	1.39	80339.00
12	19.75	10.25	64.39	2.12	14.48	11.34	1.40	81170.00
13	24.96	8.71	57.00	2.21	15.00	10.88	1.40	79818.00
14	18.87	6.82	61.03	2.01	14.64	11.15	1.41	80940.00
15	15.22	12.62	63.50	1.78	15.24	11.03	1.42	80007.00
16	7.58	11.34	62.11	1.19	15.47	11.13	1.44	81707.00
17	8.63	8.49	59.50	1.58	14.83	11.18	1.42	81138.00
18	7.94	9.63	64.42	1.68	14.58	11.08	1.42	82448.00
19	7.64	7.43	74.09	1.32	15.47	10.89	1.46	84484.00
20	6.09	8.59	64.34	1.05	15.78	10.91	1.50	86607.00
21	8.87	9.06	53.52	1.16	15.79	10.74	1.52	85843.00
22	4.25	9.78	56.55	1.08	15.54	11.00	1.57	84271.00
23	4.69	17.40	60.55	1.17	15.51	11.47	1.55	79011.00
24	8.87	25.53	46.27	2.91	16.54	10.55	1.52	78574.00
25	5.37	10.75	55.93	0.93	16.90	10.58	1.50	83922.00
26	9.83	6.05	72.44	1.51	15.87	10.69	1.48	82845.00
27	9.77	3.98	79.61	1.50	15.84	10.65	1.44	85283.00
28	9.94	4.58	83.99	1.48	16.11	10.70	1.45	86689.00
平均值	13.24	10.72	61.29	1.93	14.99	11.01	1.45	81908.79
最大值	24.96	25.53	83.99	3.17	16.90	11.47	1.57	86689.00
最小值	4.25	3.98	46.27	0.93	13.49	10.55	1.39	77719.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。