

P001_樹林焚化廠CEMS系統月報表

報表日期: 2025年3月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	8.70	12.27	54.59	2.46	18.53	10.86	1.32	83009.00
2	8.61	12.43	53.41	2.36	17.52	10.95	1.30	82477.00
3	9.36	13.03	51.09	2.28	17.87	11.08	1.26	83045.00
4	8.08	12.88	54.45	3.17	17.00	11.11	1.26	83748.00
5	9.84	13.24	52.11	2.09	17.59	11.09	1.28	82802.00
6	9.31	13.05	52.52	1.43	17.94	11.17	1.25	81407.00
7	9.67	12.72	52.58	1.65	16.42	11.64	1.29	78392.00
8	9.18	12.38	50.53	2.12	17.19	11.43	1.29	79129.00
9	9.18	12.81	49.23	2.07	16.76	11.48	1.30	79910.00
10	9.33	12.51	53.33	2.08	16.40	11.63	1.30	79557.00
11	9.72	12.76	53.69	2.60	16.52	11.46	1.32	80531.00
12	10.50	13.19	52.37	2.46	16.70	11.40	1.31	80581.00
13	9.77	11.95	53.55	2.60	16.46	11.37	1.31	81196.00
14	9.49	12.74	55.40	2.10	16.53	11.47	1.31	79741.00
15	9.99	12.69	50.67	2.45	16.82	11.29	1.32	80300.00
16	9.68	12.03	48.53	2.21	16.48	11.39	1.32	79876.00
17	9.77	13.27	51.20	2.55	16.43	11.54	1.32	78638.00
18	9.74	12.75	51.21	2.36	16.67	11.55	1.29	79255.00
19	10.16	13.37	49.00	2.74	15.97	11.55	1.30	78719.00
20	10.04	13.02	49.28	2.79	16.61	11.50	1.27	80069.00
21	9.46	13.19	49.95	2.73	16.53	11.47	1.27	79517.00
22	9.30	12.97	51.43	2.06	17.51	11.20	1.27	81388.00
23	8.89	12.68	49.52	2.51	17.71	11.18	1.29	80779.00
24	8.87	11.75	49.26	2.50	17.37	11.22	1.30	81541.00
25	9.84	13.07	48.89	2.53	16.80	11.35	1.30	80257.00
26	9.11	11.65	48.77	1.83	16.76	11.36	1.29	81002.00
27	8.72	12.61	52.29	1.70	17.56	11.10	1.34	80650.00
28	9.52	12.40	52.44	2.33	17.54	11.06	1.34	80062.00
29	9.24	12.31	50.86	2.20	17.34	11.14	1.34	79557.00
30	9.25	11.93	48.29	2.60	17.47	11.00	1.31	81821.00
31	9.31	12.11	46.54	2.24	17.71	10.99	1.29	81971.00
平均值	9.41	12.64	51.19	2.32	17.06	11.29	1.30	80675.06
最大值	10.50	13.37	55.40	3.17	18.53	11.64	1.34	83748.00
最小值	8.08	11.65	46.54	1.43	15.97	10.86	1.25	78392.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P002_樹林焚化廠CEMS系統月報表

報表日期: 2025年3月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	8.64	11.99	49.64	1.62	18.77	9.85	1.02	79294.00
2	9.53	11.75	55.82	1.49	17.63	10.02	1.03	78919.00
3	9.03	12.04	55.22	1.62	17.37	10.59	1.02	80535.00
4	9.04	12.12	54.37	1.85	16.67	10.65	1.01	79731.00
5	9.43	12.32	52.79	1.59	17.65	10.48	1.02	80050.00
6	9.28	12.04	52.83	1.60	18.12	10.44	1.01	80785.00
7	9.34	12.07	51.37	2.17	17.16	10.51	0.99	78679.00
8	9.40	11.93	46.66	1.85	17.53	10.42	1.00	80348.00
9	9.09	11.89	46.81	1.49	16.87	10.41	1.01	78631.00
10	9.66	12.02	46.37	1.80	17.50	10.28	1.00	79451.00
11	9.18	12.06	49.32	2.19	16.28	10.63	1.00	79489.00
12	9.84	12.08	52.38	1.46	16.88	10.65	1.01	80206.00
13	9.68	12.35	52.29	2.13	16.29	10.82	1.02	79703.00
14	9.30	12.81	50.07	2.09	16.67	10.69	1.04	79208.00
15	9.76	11.83	48.97	1.86	17.51	10.27	1.05	79833.00
16	9.59	11.74	51.24	1.70	17.69	10.02	1.05	79734.00
17	9.33	11.05	54.40	1.45	17.86	10.34	1.02	77865.00
18	10.13	12.66	56.90	1.72	17.46	10.50	0.95	77125.00
19	9.71	13.69	54.06	1.40	16.78	11.39	0.81	75765.00
20	9.30	15.09	52.91	1.24	17.10	11.63	0.80	76361.00
21	9.51	9.82	55.01	1.33	17.05	11.30	0.81	78834.00
22	10.17	9.52	55.23	1.13	17.69	11.22	0.80	78363.00
23	10.08	8.42	49.72	1.46	16.54	11.68	0.81	77605.00
24	9.64	9.71	53.78	1.64	16.82	11.80	0.82	76785.00
25	10.07	8.76	51.23	1.37	16.89	11.40	0.82	77538.00
26	9.80	10.46	56.41	1.16	16.80	11.33	0.81	76398.00
27	10.83	10.34	57.94	0.96	17.71	11.08	0.82	77976.00
28	10.74	10.27	56.13	0.97	17.81	10.98	0.83	77955.00
29	9.72	9.83	56.10	1.05	17.80	11.18	0.84	75796.00
30	11.81	9.79	55.85	0.80	18.83	11.09	0.83	76263.00
31	10.21	12.13	53.64	0.83	18.71	11.16	0.83	73565.00
平均值	9.70	11.44	52.76	1.52	17.37	10.80	0.93	78348.06
最大值	11.81	15.09	57.94	2.19	18.83	11.80	1.05	80785.00
最小值	8.64	8.42	46.37	0.80	16.28	9.85	0.80	73565.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P003_樹林焚化廠CEMS系統月報表

報表日期: 2025年3月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	6.61	11.91	53.98	1.94	17.27	10.52	1.42	73243.00
2	7.12	11.85	52.23	2.48	17.99	9.86	1.40	74626.00
3	7.33	11.83	52.57	2.82	16.87	10.04	1.36	75176.00
4	7.15	11.81	52.49	2.73	16.63	9.92	1.40	75248.00
5	9.44	12.07	52.63	2.81	17.80	9.71	1.41	74913.00
6	8.65	11.74	54.75	3.02	17.95	10.08	1.41	77685.00
7	8.08	11.99	54.46	2.64	16.35	10.15	1.38	74950.00
8	8.69	11.99	47.07	2.25	17.51	9.73	1.41	75405.00
9	8.09	11.55	51.64	2.31	17.16	9.91	1.42	76100.00
10	9.32	11.60	48.47	2.03	16.95	9.88	1.40	76421.00
11	7.95	11.60	50.68	3.05	16.42	9.82	1.41	75678.00
12	7.72	11.78	49.75	2.53	17.65	9.38	1.41	75841.00
13	7.04	11.86	57.19	2.48	16.27	9.96	1.39	76105.00
14	8.54	12.04	53.78	3.05	16.63	9.69	1.37	74533.00
15	8.03	12.62	54.33	2.23	15.99	10.06	1.38	72698.00
16	8.76	11.77	48.27	2.19	16.99	9.68	1.38	73636.00
17	6.84	15.42	50.91	3.05	17.58	9.62	1.37	74176.00
18	8.87	12.49	56.13	2.77	16.85	10.42	1.36	76236.00
19	9.00	12.49	51.57	3.07	16.85	10.08	1.35	74835.00
20	8.96	12.41	53.32	2.72	16.74	10.27	1.36	74467.00
21	9.22	12.34	54.85	2.74	17.00	10.35	1.36	76181.00
22	9.04	12.09	55.75	2.59	17.26	10.39	1.33	76157.00
23	9.05	11.36	46.24	2.40	18.29	9.54	1.32	75273.00
24	9.31	11.34	46.77	2.62	18.00	9.76	1.31	75844.00
25	9.40	11.75	47.84	2.80	16.99	10.07	1.33	74733.00
26	9.51	11.41	48.43	2.34	17.20	9.97	1.34	75606.00
27	9.93	11.82	54.02	2.65	18.03	10.10	1.35	75584.00
28	9.60	11.23	53.00	3.10	17.10	10.07	1.33	74620.00
29	9.16	11.31	54.74	2.68	17.90	10.13	1.36	76521.00
30	9.80	11.55	55.87	2.61	17.65	10.19	1.35	75695.00
31	9.05	11.23	52.87	2.32	18.06	9.72	1.37	73243.00
平均值	8.56	11.94	52.15	2.61	17.22	9.97	1.37	75207.39
最大值	9.93	15.42	57.19	3.10	18.29	10.52	1.42	77685.00
最小值	6.61	11.23	46.24	1.94	15.99	9.38	1.31	72698.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。