

P001_樹林焚化廠CEMS系統月報表

報表日期: 2020年01月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
日\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	7.43	2.43	97.65	9.46	14.45	11.60	1.33	104842.00
2	5.83	2.18	96.22	9.32	14.66	11.55	1.36	103607.00
3	8.28	5.00	95.39	9.59	14.49	11.51	1.35	104211.00
4	6.99	5.30	92.87	9.55	14.27	11.43	1.35	101719.00
5	7.22	1.43	97.16	9.85	15.17	11.24	1.35	102773.00
6	7.94	2.54	99.87	10.12	13.93	11.62	1.36	102388.00
7	6.68	4.76	97.61	9.71	14.15	11.54	1.43	100863.00
8	7.18	3.60	95.03	9.75	14.22	11.59	1.42	103277.00
9	15.13	4.39	94.61	10.15	13.79	11.59	1.46	105407.00
10	6.96	4.20	95.27	9.93	14.03	11.52	1.55	103292.00
11	8.36	5.01	97.00	10.37	13.74	11.56	1.53	102925.00
12	4.21	1.66	94.72	9.58	14.18	11.36	1.47	102896.00
13	5.95	1.46	93.75	9.47	13.95	11.54	1.46	104458.00
14	6.28	4.24	90.30	9.88	13.59	11.85	1.42	103411.00
15	9.89	2.53	96.40	9.87	13.29	11.62	1.46	102020.00
16	10.09	1.66	95.65	10.12	13.56	11.78	1.38	102385.00
17	10.73	2.10	100.57	10.33	13.20	11.85	1.33	102285.00
18	11.45	4.92	93.17	9.84	13.42	11.72	1.36	104183.00
19	10.23	1.55	92.25	9.82	13.23	11.84	1.40	102925.00
20	9.76	1.86	97.90	9.69	13.44	11.75	1.42	101552.00
21	12.01	1.89	92.02	9.38	13.37	11.61	1.41	102495.00
22	9.88	1.54	95.78	9.76	13.37	11.71	1.42	102601.00
23	12.98	1.85	96.25	10.19	12.98	11.81	1.42	100607.00
24	4.85	1.58	100.40	10.10	13.31	11.93	1.36	99407.00
25	7.83	3.00	94.84	10.41	12.96	12.01	1.37	98953.00
26	10.07	1.77	103.46	10.44	12.75	12.13	1.32	99596.00
27	11.22	1.41	97.01	9.97	12.81	12.07	1.28	99365.00
28	6.45	3.04	97.26	9.47	13.51	12.04	1.28	99362.00
29	2.46	4.69	97.95	9.16	14.51	11.84	1.28	100161.00
30	5.33	1.46	95.11	8.64	14.13	11.66	1.29	103795.00
31	5.28	2.02	94.60	8.48	13.75	11.84	1.27	102227.00
平均值	8.22	2.81	96.07	9.75	13.75	11.70	1.38	102257.68
最大值	15.13	5.30	103.46	10.44	15.17	12.13	1.55	105407.00
最小值	2.46	1.41	90.30	8.48	12.75	11.24	1.27	98953.00

P002_樹林焚化廠CEMS系統月報表

報表日期: 2020年01月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
日\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	6.37	6.57	80.87	5.79	13.74	11.94	1.33	74431.00
2	5.78	10.36	82.71	5.68	13.96	11.92	1.36	74115.00
3	7.38	10.13	84.23	5.77	13.89	11.82	1.35	74452.00
4	6.05	4.42	82.04	5.61	13.37	12.00	1.35	73450.00
5	5.44	4.61	83.61	5.78	14.29	11.77	1.35	74577.00
6	4.95	7.52	84.28	5.79	13.63	11.91	1.36	74262.00
7	7.20	10.19	84.86	6.06	13.07	11.98	1.43	74327.00
8	11.65	10.12	86.38	6.48	12.69	12.09	1.42	73595.00
9	10.15	5.19	83.52	6.20	12.84	11.97	1.46	74529.00
10	7.65	8.75	86.19	6.12	13.18	11.99	1.55	73664.00
11	7.15	6.07	88.80	5.86	12.82	12.00	1.53	73855.00
12	5.59	5.93	85.31	5.69	13.00	12.00	1.47	75018.00
13	6.04	7.45	82.22	5.65	13.11	12.04	1.46	74115.00
14	4.50	4.65	83.64	5.41	13.11	12.10	1.42	73990.00
15	5.99	3.55	86.91	5.63	12.74	12.22	1.46	72710.00
16	8.67	4.53	87.70	5.76	13.03	12.02	1.38	74282.00
17	7.44	4.43	91.07	5.75	12.85	12.12	1.33	73567.00
18	7.21	4.19	79.59	5.60	12.74	12.02	1.36	75370.00
19	5.66	5.15	87.35	5.32	12.91	12.06	1.40	72722.00
20	5.59	4.73	88.52	5.23	12.55	12.21	1.42	71094.00
21	6.55	7.35	81.34	5.13	12.92	11.95	1.41	73451.00
22	7.75	4.69	86.55	5.31	13.22	12.18	1.42	72835.00
23	8.83	7.96	87.78	5.31	12.23	12.23	1.42	72775.00
24	5.39	3.15	88.94	5.22	13.24	12.22	1.36	72647.00
25	6.70	8.42	92.38	5.52	12.36	12.34	1.37	70735.00
26	6.67	6.19	90.06	5.59	12.36	12.44	1.32	70528.00
27	6.84	3.95	94.07	5.48	12.32	12.44	1.28	70259.00
28	4.51	6.42	86.31	5.49	12.50	12.58	1.28	70298.00
29	2.96	4.75	83.99	5.23	13.54	12.43	1.28	71833.00
30	2.64	5.98	72.78	4.99	13.53	12.01	1.29	74832.00
31	2.51	8.07	77.84	5.09	13.21	12.25	1.27	74036.00
平均值	6.38	6.31	85.22	5.60	13.06	12.10	1.38	73301.74
最大值	11.65	10.36	94.07	6.48	14.29	12.58	1.55	75370.00
最小值	2.51	3.15	72.78	4.99	12.23	11.77	1.27	70259.00

P003_樹林焚化廠CEMS系統月報表

報表日期: 2020年01月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
日\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	4.89	5.75	80.98	8.66	12.84	11.62	1.33	99562.00
2	4.83	11.99	81.64	8.82	12.94	11.69	1.36	97332.00
3	4.45	13.61	79.97	8.82	12.74	11.62	1.35	96918.00
4	5.06	14.39	72.56	8.67	13.08	11.44	1.35	98435.00
5	4.97	6.19	81.46	9.19	13.42	11.44	1.35	97799.00
6	7.51	14.11	78.98	9.18	12.95	11.35	1.36	97562.00
7	7.84	21.43	83.98	9.39	12.31	11.75	1.43	93759.00
8	9.36	20.03	77.64	9.51	11.83	11.76	1.42	95569.00
9	8.68	14.69	76.88	9.09	12.57	11.54	1.46	98888.00
10	6.70	7.45	88.55	9.77	12.02	11.78	1.55	95018.00
11	7.92	11.22	95.04	10.28	11.10	12.23	1.53	90914.00
12	5.40	11.30	82.19	9.16	12.52	11.78	1.47	97597.00
13	6.42	11.60	83.78	8.86	12.27	11.79	1.46	97519.00
14	3.96	8.57	78.13	9.11	12.11	12.00	1.42	93257.00
15	4.76	9.40	87.09	9.51	12.18	11.94	1.46	94532.00
16	5.13	8.28	89.10	9.55	12.43	11.86	1.38	94009.00
17	4.01	4.20	92.20	9.59	11.95	12.07	1.33	95013.00
18	4.78	10.68	84.49	9.24	11.49	12.27	1.36	93752.00
19	3.26	11.49	75.19	8.91	12.09	12.00	1.40	93395.00
20	4.51	6.79	85.64	9.14	11.30	12.22	1.42	92722.00
21	6.06	10.34	88.40	9.48	11.00	12.46	1.41	91387.00
22	6.29	6.49	84.44	9.52	11.48	12.18	1.42	91534.00
23	7.26	10.06	86.67	9.94	11.12	12.36	1.42	89729.00
24	4.74	4.52	92.70	10.20	11.72	12.28	1.36	90361.00
25	5.25	6.78	84.92	10.20	11.21	12.29	1.37	91403.00
26	5.56	12.60	94.10	10.29	10.83	12.50	1.32	89634.00
27	6.16	8.40	91.76	9.69	11.19	12.35	1.28	91465.00
28	4.25	10.02	85.57	9.33	11.89	12.29	1.28	92831.00
29	3.10	6.70	76.63	8.68	12.75	12.11	1.28	94579.00
30	2.86	2.54	75.65	8.50	12.11	12.13	1.29	94161.00
31	2.70	8.63	75.29	8.48	11.93	12.32	1.27	92877.00
平均值	5.44	10.01	83.60	9.31	12.04	11.98	1.38	94306.87
最大值	9.36	21.43	95.04	10.29	13.42	12.50	1.55	99562.00
最小值	2.70	2.54	72.56	8.48	10.83	11.35	1.27	89634.00