

## P001\_樹林焚化廠CEMS系統月報表

報表日期: 2022年12月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	4.21	4.32	57.24	1.11	18.98	11.72	1.39	75207.00
2	6.91	4.15	56.81	1.56	18.50	11.90	1.44	73399.00
3	10.11	4.23	58.48	1.53	18.26	11.89	1.43	73711.00
4	9.24	1.70	58.44	1.43	18.94	11.50	1.44	75162.00
5	7.24	3.17	60.56	1.66	18.40	11.69	1.41	74421.00
6	9.29	3.99	57.57	1.63	18.05	11.74	1.39	74938.00
7	8.87	6.75	57.21	1.46	18.34	11.65	1.37	74793.00
8	7.94	4.51	57.16	1.46	18.39	11.59	1.38	73885.00
9	9.06	4.36	59.63	1.16	18.94	11.54	1.38	74190.00
10	8.20	2.81	58.81	0.98	19.55	11.50	1.41	74796.00
11	9.11	2.85	51.50	0.67	21.12	10.87	1.39	77915.00
12	6.72	3.76	54.00	1.10	19.76	11.61	1.40	73468.00
13	9.75	3.86	53.11	0.83	20.35	11.43	1.41	75937.00
14	8.57	5.36	54.30	0.82	20.37	11.58	1.40	74931.00
15	8.94	3.86	51.40	0.77	20.73	11.19	1.42	77249.00
16	9.27	4.24	55.51	0.94	20.86	11.39	1.45	75149.00
17	10.60	3.89	58.52	1.63	19.02	11.64	1.44	75783.00
18	5.39	5.17	55.77	0.85	19.11	11.51	1.52	76701.00
19	6.86	2.67	53.11	0.57	19.50	11.32	1.47	77296.00
20	10.21	3.44	54.46	1.03	19.07	11.37	1.42	76816.00
21	8.79	3.99	56.29	0.87	18.89	11.38	1.40	76592.00
22	9.09	3.11	54.15	0.88	18.72	11.33	1.43	77384.00
23	7.66	3.88	50.02	0.60	18.61	11.50	1.45	75899.00
24	8.18	4.00	49.02	0.77	17.56	11.85	1.48	73742.00
25	8.61	4.02	49.09	0.70	18.16	11.78	1.53	74448.00
26	9.26	2.51	45.56	0.99	18.57	11.30	1.53	77509.00
27	7.68	3.32	50.26	1.13	18.58	11.48	1.48	76217.00
28	10.97	4.57	51.93	2.13	18.17	11.44	1.42	76297.00
29	8.34	3.23	57.12	3.31	18.94	11.47	1.41	75847.00
30	9.09	3.77	58.00	2.51	19.19	11.36	1.42	76410.00
31	9.87	3.37	55.68	2.03	19.08	11.32	1.43	77077.00
平均值	8.52	3.83	54.86	1.26	19.06	11.51	1.43	75586.10
最大值	10.97	6.75	60.56	3.31	21.12	11.90	1.53	77915.00
最小值	4.21	1.70	45.56	0.57	17.56	10.87	1.37	73399.00

備註： 1.\*:儀器保養維護中。

2.\*\*:停爐中。

## P002\_樹林焚化廠CEMS系統月報表

報表日期: 2022年12月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	10.29	2.80	64.38	2.15	17.66	10.72	1.29	65346.00
2	9.31	3.69	60.75	2.18	17.83	10.90	1.36	65066.00
3	11.75	4.21	61.30	2.47	17.28	11.04	1.43	64765.00
4	10.18	4.24	59.30	2.41	16.72	11.16	1.46	63918.00
5	8.61	3.00	62.52	2.28	17.06	10.77	1.44	64450.00
6	10.71	3.64	62.40	2.73	16.85	10.97	1.45	65037.00
7	10.44	4.83	62.83	2.67	16.96	10.85	1.46	65372.00
8	10.20	4.67	61.25	2.56	17.43	10.50	1.44	65695.00
9	10.67	4.67	62.30	2.92	17.27	10.70	1.46	65611.00
10	10.45	3.83	61.78	2.91	16.99	10.74	1.51	64746.00
11	8.29	2.99	59.26	1.98	19.06	10.16	1.50	68071.00
12	8.78	1.65	58.53	2.22	17.41	10.74	1.47	65689.00
13	10.28	2.92	57.75	1.95	17.92	10.67	1.45	65893.00
14	10.64	3.48	56.11	1.82	19.08	10.40	1.49	66764.00
15	10.50	4.77	60.88	2.41	17.00	10.92	1.45	64464.00
16	11.10	4.45	58.44	3.12	17.11	11.03	1.41	64377.00
17	9.88	4.87	58.91	1.61	18.74	10.52	1.40	66532.00
18	7.21	3.24	53.04	1.46	18.24	10.56	1.43	66683.00
19	8.41	3.65	61.07	1.78	17.27	10.88	1.45	65133.00
20	8.60	4.17	59.07	2.42	16.26	10.84	1.45	64087.00
21	10.28	3.97	60.60	2.34	16.59	10.75	1.43	65013.00
22	8.08	3.38	57.60	2.18	16.11	10.78	1.40	64444.00
23	9.24	3.78	53.99	1.83	17.21	10.70	1.39	65460.00
24	10.54	5.13	54.04	2.00	16.33	10.77	1.38	65871.00
25	9.02	2.94	50.97	1.65	18.27	10.44	1.37	66516.00
26	9.38	2.53	55.71	2.17	16.11	10.64	1.36	65386.00
27	8.88	3.36	59.10	2.24	16.06	10.85	1.39	64662.00
28	10.35	3.77	54.58	2.69	14.94	10.53	1.41	62684.00
29	9.43	3.08	58.90	2.02	16.40	10.66	1.38	64399.00
30	9.68	4.78	60.87	2.18	16.71	10.76	1.37	64829.00
31	9.68	4.54	60.40	2.34	16.01	10.74	1.32	63544.00
平均值	9.71	3.78	58.99	2.25	17.13	10.73	1.42	65177.65
最大值	11.75	5.13	64.38	3.12	19.08	11.16	1.51	68071.00
最小值	7.21	1.65	50.97	1.46	14.94	10.16	1.29	62684.00

備註： 1.\*:儀器保養維護中。

2.\*\*:停爐中。

## P003\_樹林焚化廠CEMS系統月報表

報表日期: 2022年12月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	8.63	3.89	59.75	2.49	15.99	10.67	1.33	83878.00
2	8.63	5.20	61.75	3.00	15.79	10.97	1.36	82918.00
3	9.34	5.38	59.04	2.80	15.37	11.07	1.39	81792.00
4	8.83	4.88	60.10	3.03	15.30	10.95	1.35	81051.00
5	7.60	2.85	60.47	2.79	15.43	10.82	1.30	82286.00
6	8.83	5.46	57.30	2.39	15.99	10.92	1.29	83521.00
7	9.95	9.33	57.00	2.82	15.68	10.77	1.30	84390.00
8	8.94	5.69	57.26	2.75	15.56	10.73	1.30	82845.00
9	10.43	5.95	58.95	3.10	15.80	10.94	1.29	84151.00
10	10.84	5.22	57.14	2.82	15.98	10.82	1.27	83959.00
11	9.46	3.92	54.47	2.36	17.18	10.21	1.27	86898.00
12	8.13	3.28	54.44	2.31	15.88	10.68	1.30	83804.00
13	8.10	5.40	55.80	2.05	15.82	10.88	1.31	83430.00
14	8.36	3.37	55.90	1.83	16.50	10.91	1.35	84584.00
15	9.23	3.32	56.52	2.22	15.35	10.98	1.35	83326.00
16	8.97	4.57	54.89	2.58	16.23	10.69	1.32	85269.00
17	10.08	4.34	55.56	2.59	15.70	10.94	1.30	85843.00
18	6.40	3.77	57.90	1.47	16.57	10.94	1.34	87867.00
19	7.57	4.13	58.99	2.03	15.13	11.30	1.30	84358.00
20	9.53	4.61	57.46	2.99	14.57	10.98	1.29	83106.00
21	8.53	8.46	59.17	1.90	15.32	11.05	1.27	84480.00
22	7.80	4.90	58.93	1.90	15.22	10.90	1.26	84473.00
23	6.69	5.85	57.09	1.86	15.23	11.21	1.30	85341.00
24	8.59	4.32	50.89	2.20	14.80	10.80	1.31	82669.00
25	7.48	3.91	48.97	1.54	15.83	11.01	1.34	84047.00
26	7.01	3.10	51.16	1.93	14.62	11.02	1.34	82743.00
27	7.20	4.14	56.88	2.50	14.24	11.31	1.57	83008.00
28	10.15	4.87	55.15	3.32	13.04	11.15	1.86	78234.00
29	7.88	2.99	59.71	2.32	15.14	10.75	1.86	82977.00
30	9.38	5.33	61.43	2.47	15.41	10.75	1.83	84184.00
31	9.46	3.69	60.17	2.42	15.36	10.74	1.81	83878.00
平均值	8.65	4.71	57.10	2.41	15.48	10.90	1.39	83719.68
最大值	10.84	9.33	61.75	3.32	17.18	11.31	1.86	87867.00
最小值	6.40	2.85	48.97	1.47	13.04	10.21	1.26	78234.00

備註： 1.\*:儀器保養維護中。

2.\*\*:停爐中。