

P001_樹林焚化廠CEMS系統月報表

報表日期: 2020年09月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	3.16	4.59	58.68	4.42	15.44	11.50	1.06	106424.00
2	3.18	5.77	54.04	4.35	15.29	11.49	1.07	105978.00
3	2.83	9.33	57.03	4.34	15.35	11.52	1.05	105588.00
4	4.91	13.69	56.82	4.63	14.80	11.54	1.04	105904.00
5	3.45	7.87	57.87	4.51	15.05	11.49	1.02	105579.00
6	4.10	10.20	54.91	4.66	14.37	11.55	1.03	105990.00
7	5.43	13.59	52.04	4.65	14.48	11.18	1.06	102446.00
8	4.53	5.01	54.86	4.42	14.79	11.39	1.10	97940.00
9	6.92	9.33	57.12	4.84	14.97	11.44	1.07	101656.00
10	7.53	5.20	56.50	4.90	14.34	11.69	1.05	100654.00
11	5.68	10.45	60.42	4.61	15.47	11.50	1.05	104971.00
12	3.84	7.53	57.51	4.67	14.83	11.74	1.04	103277.00
13	5.49	12.66	56.55	5.02	14.88	11.66	1.04	104376.00
14	3.93	4.48	63.18	4.66	14.84	11.68	1.10	102580.00
15	4.22	5.14	58.03	4.76	14.83	11.69	1.12	103495.00
16	5.95	7.96	58.70	4.92	15.15	11.55	1.11	105451.00
17	7.68	10.85	55.62	5.10	14.77	11.41	1.11	103504.00
18	4.33	6.59	55.31	4.49	15.49	11.33	1.12	102643.00
19	5.18	8.93	55.26	4.63	15.11	11.43	1.11	102335.00
20	5.06	10.08	54.22	4.70	15.47	11.29	1.12	102766.00
21	4.59	14.10	61.80	4.76	14.63	11.36	1.11	96797.00
22	4.12	4.15	55.44	4.69	14.71	11.51	1.05	91766.00
23	11.06	9.48	53.24	5.25	14.27	11.43	1.04	92232.00
24	6.84	7.00	60.08	4.92	14.73	11.46	1.04	91195.00
25	7.15	6.43	61.09	5.29	14.79	11.59	0.99	93237.00
26	4.19	7.00	59.33	5.09	14.80	11.52	1.05	93649.00
27	3.41	7.02	58.60	4.90	15.08	11.38	1.05	94400.00
28	3.16	4.41	59.79	4.74	14.76	11.61	1.06	91819.00
29	4.60	8.70	56.94	4.71	15.17	11.45	1.07	93947.00
30	6.84	14.32	57.12	3.63	14.73	11.62	1.04	93428.00
平均值	5.11	8.40	57.27	4.71	14.91	11.50	1.07	100200.90
最大值	11.06	14.32	63.18	5.29	15.49	11.74	1.12	106424.00
最小值	2.83	4.15	52.04	3.63	14.27	11.18	0.99	91195.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P002_樹林焚化廠CEMS系統月報表

報表日期: 2020年09月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	0.80	11.14	70.97	4.59	14.74	11.65	1.08	80568.00
2	0.79	9.09	70.01	4.45	14.77	11.70	1.08	79730.00
3	0.76	8.29	75.31	4.58	14.42	11.88	1.01	78782.00
4	0.80	8.72	78.16	4.37	14.60	11.74	1.15	79676.00
5	1.00	7.63	78.97	4.46	14.20	11.88	1.17	78518.00
6	0.68	10.53	68.50	4.54	13.96	11.75	1.11	80145.00
7	0.65	11.31	69.77	4.40	13.79	11.68	1.07	80482.00
8	0.68	6.41	75.33	4.42	14.10	11.84	1.00	79032.00
9	0.80	3.96	77.66	4.41	14.49	11.80	1.05	78670.00
10	1.13	6.16	73.05	4.44	14.12	11.73	1.06	78323.00
11	1.06	7.60	71.10	4.35	15.04	11.63	1.06	79679.00
12	0.82	8.21	72.02	4.39	14.28	11.82	1.13	77522.00
13	0.59	3.83	71.91	4.38	14.35	11.78	1.14	77864.00
14	0.57	5.95	75.59	4.48	14.34	11.86	1.09	77780.00
15	0.62	9.77	71.90	4.47	14.70	11.73	1.12	78940.00
16	1.30	10.15	72.47	4.53	14.78	11.72	1.11	79232.00
17	1.86	13.80	70.66	4.72	14.30	11.76	1.05	79186.00
18	1.23	6.82	68.33	4.36	14.83	11.57	1.09	79248.00
19	1.54	10.30	73.67	4.56	14.43	11.68	1.08	79291.00
20	1.12	12.68	74.77	4.54	14.38	11.69	1.09	79651.00
21	0.99	6.83	78.74	4.47	13.67	11.87	1.15	78062.00
22	1.11	8.72	72.79	4.50	13.76	11.82	1.17	78664.00
23	4.47	8.65	70.24	4.90	13.39	11.70	1.09	80055.00
24	1.83	5.66	68.59	4.51	14.32	11.78	1.02	79305.00
25	1.57	9.83	69.64	4.70	14.56	11.75	1.03	79866.00
26	1.26	11.50	76.36	4.84	13.77	11.91	1.09	79228.00
27	1.29	14.43	76.55	4.63	13.26	11.94	1.05	78881.00
28	1.06	8.40	71.59	4.42	13.84	11.75	1.08	79226.00
29	1.60	16.01	70.56	4.73	13.75	11.82	1.05	79537.00
30	2.78	14.12	72.08	3.97	13.44	11.95	1.05	79760.00
平均值	1.23	9.22	72.91	4.50	14.21	11.77	1.08	79163.43
最大值	4.47	16.01	78.97	4.90	15.04	11.95	1.17	80568.00
最小值	0.57	3.83	68.33	3.97	13.26	11.57	1.00	77522.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P003_樹林焚化廠CEMS系統月報表

報表日期: 2020年09月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	17.25	6.74	87.31	6.79	19.17	9.28	1.15	96857.00
2	18.36	8.34	82.02	7.03	18.95	9.21	1.16	98222.00
3	12.18	10.96	80.46	7.23	17.94	9.29	1.15	95128.00
4	11.93	7.67	82.54	6.55	18.05	9.36	1.15	95057.00
5	17.64	7.84	83.41	6.27	20.51	9.08	1.17	97879.00
6	22.02	4.58	76.82	6.84	22.93	9.00	1.16	102060.00
7	22.81	15.47	72.50	4.94	18.16	10.86	1.20	80668.00
8	22.92	11.90	84.27	7.50	18.15	9.26	1.16	93219.00
9	15.87	15.73	84.59	7.04	17.56	9.51	1.16	95033.00
10	19.75	16.10	83.84	7.29	17.54	9.52	1.16	95892.00
11	21.13	12.92	83.00	9.20	18.50	9.37	1.16	98356.00
12	9.24	10.48	82.07	6.63	16.95	9.39	1.20	93110.00
13	7.32	10.06	81.82	6.58	17.18	9.49	1.22	97428.00
14	11.91	10.85	82.22	7.35	17.80	9.36	1.23	98445.00
15	16.45	9.06	85.54	7.34	19.12	9.31	1.21	99097.00
16	13.93	16.98	87.21	7.16	19.01	9.39	1.19	100125.00
17	14.06	10.04	81.21	6.91	19.00	9.15	1.18	98147.00
18	16.00	10.71	85.50	6.87	19.50	9.34	1.15	100984.00
19	19.45	11.44	83.36	7.29	19.10	9.34	1.14	98220.00
20	13.70	10.85	86.19	7.67	19.44	9.06	1.13	97750.00
21	12.99	4.85	84.25	7.36	18.21	9.37	1.15	97786.00
22	11.56	8.36	87.08	6.77	17.20	9.62	1.18	100581.00
23	30.17	12.52	83.04	7.67	17.27	9.56	1.19	99806.00
24	25.52	9.48	83.57	7.35	18.22	9.35	1.19	100508.00
25	23.36	17.31	88.38	8.27	16.25	9.84	1.20	99915.00
26	22.12	12.10	84.74	7.87	16.46	9.71	1.22	96653.00
27	19.76	14.15	84.09	7.85	16.08	9.70	1.20	97197.00
28	19.43	3.41	87.18	7.46	16.40	9.59	1.25	96640.00
29	24.28	15.05	89.61	7.58	16.17	9.81	1.30	98461.00
30	28.51	24.35	87.54	7.64	15.80	10.41	1.28	93852.00
平均值	18.05	11.34	83.85	7.21	18.09	9.48	1.19	97102.53
最大值	30.17	24.35	89.61	9.20	22.93	10.86	1.30	102060.00
最小值	7.32	3.41	72.50	4.94	15.80	9.00	1.13	80668.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。