

P001_樹林焚化廠CEMS系統月報表

報表日期: 2024年2月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	7.62	7.05	48.62	1.66	15.88	11.64	1.05	81098.00
2	9.16	5.79	46.89	1.38	15.99	11.75	1.03	81746.00
3	9.52	6.33	48.21	1.97	14.74	12.02	1.03	80753.00
4	9.05	7.34	48.18	1.45	15.50	11.93	1.03	80526.00
5	9.43	6.76	50.21	1.88	14.71	12.02	1.04	80628.00
6	9.80	5.63	46.99	1.70	14.75	12.17	1.06	79493.00
7	10.40	6.61	47.80	2.94	13.82	12.22	1.04	79506.00
8	8.77	5.96	46.61	2.66	13.49	12.41	1.04	78047.00
9	9.53	4.60	52.88	2.91	12.57	12.59	1.02	76935.00
10	9.04	8.65	48.23	1.91	13.97	12.04	1.06	80905.00
11	9.69	9.99	51.90	1.67	14.00	12.06	1.06	80951.00
12	9.35	9.22	50.57	1.55	14.25	12.00	1.04	81070.00
13	7.04	7.46	48.85	1.15	14.96	11.76	1.03	81869.00
14	7.12	7.27	49.90	1.11	15.72	11.78	1.02	80783.00
15	5.62	7.51	49.61	0.85	16.12	11.87	0.99	79793.00
16	7.19	5.22	46.67	1.16	16.28	11.71	0.99	81622.00
17	7.89	5.74	44.08	1.20	16.64	11.70	1.01	80951.00
18	7.66	5.84	47.24	0.88	17.51	11.56	1.02	81073.00
19	7.50	6.95	51.51	1.09	16.23	11.83	1.02	79830.00
20	8.87	6.16	48.13	1.10	16.50	11.84	0.99	80548.00
21	8.95	5.95	48.51	0.87	16.85	11.91	1.02	79234.00
22	9.47	6.95	53.24	1.43	16.74	11.69	1.01	81324.00
23	9.56	5.90	49.69	2.38	14.90	12.01	1.01	80842.00
24	9.73	6.47	53.00	2.07	15.24	11.90	1.03	81231.00
25	8.87	7.05	53.57	1.38	16.04	11.73	1.01	82119.00
26	8.84	5.95	50.40	1.58	15.45	11.82	1.04	81666.00
27	8.95	6.53	52.91	1.56	16.06	11.71	1.03	82663.00
28	8.88	7.64	56.95	1.59	15.99	11.79	1.03	80977.00
29	8.77	6.29	53.38	2.01	15.00	11.96	1.00	80121.00
平均值	8.70	6.72	49.82	1.62	15.38	11.91	1.03	80631.17
最大值	10.40	9.99	56.95	2.94	17.51	12.59	1.06	82663.00
最小值	5.62	4.60	44.08	0.85	12.57	11.56	0.99	76935.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P002_樹林焚化廠CEMS系統月報表

報表日期: 2024年2月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	3.63	4.00	46.26	2.46	14.44	11.58	1.08	77002.00
2	7.11	3.78	47.21	2.21	14.56	11.56	1.07	77570.00
3	8.51	3.26	46.62	2.52	13.99	11.70	1.05	77334.00
4	7.49	3.64	46.07	2.40	13.98	11.63	1.03	78043.00
5	8.15	3.63	47.98	2.58	13.64	11.73	1.03	78216.00
6	8.86	3.87	47.16	3.16	13.03	11.87	1.01	77371.00
7	8.74	3.91	48.62	3.05	12.81	12.08	1.02	76099.00
8	9.96	2.99	48.62	2.82	12.50	12.00	1.06	77287.00
9	8.75	2.95	51.80	2.83	12.70	11.88	1.10	77708.00
10	7.55	5.43	50.17	2.59	13.32	11.81	1.10	77656.00
11	7.08	5.41	47.70	2.34	13.40	11.72	1.12	78095.00
12	8.42	5.25	48.40	2.41	13.34	11.75	1.09	77839.00
13	4.97	4.73	50.03	1.97	13.76	11.67	1.06	77810.00
14	4.32	4.48	44.78	1.75	15.59	11.29	1.05	79779.00
15	3.84	3.73	47.99	1.91	15.23	11.53	1.05	77943.00
16	3.04	3.72	49.31	2.15	15.06	11.54	1.04	78611.00
17	4.92	3.57	50.29	2.36	15.37	11.45	1.04	78687.00
18	5.26	5.78	47.46	2.03	16.17	11.26	1.05	78966.00
19	5.73	4.20	49.17	2.22	15.19	11.51	1.06	77553.00
20	6.24	4.15	45.04	2.19	15.65	11.25	1.05	79406.00
21	8.67	3.48	48.60	2.47	15.19	11.33	1.05	79047.00
22	6.37	4.54	52.12	2.10	15.18	11.43	1.00	78425.00
23	7.64	4.37	54.87	2.66	14.87	11.59	0.99	78618.00
24	8.05	5.51	53.56	2.58	14.76	11.66	1.02	78186.00
25	6.96	5.42	54.19	2.55	15.50	11.40	1.01	79208.00
26	5.90	4.61	50.21	2.56	14.45	11.74	1.06	77426.00
27	6.72	4.67	45.80	2.42	14.84	11.67	1.07	77606.00
28	8.30	4.69	55.13	2.81	15.04	11.48	1.09	78508.00
29	8.85	4.25	51.98	2.70	15.00	11.43	1.07	78724.00
平均值	6.90	4.28	49.21	2.44	14.43	11.60	1.05	78093.90
最大值	9.96	5.78	55.13	3.16	16.17	12.08	1.12	79779.00
最小值	3.04	2.95	44.78	1.75	12.50	11.25	0.99	76099.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P003_樹林焚化廠CEMS系統月報表

報表日期: 2024年2月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	2.40	4.49	45.78	1.05	15.41	10.51	1.11	76340.00
2	5.57	5.53	41.36	1.16	16.40	10.14	1.10	77108.00
3	7.47	4.21	59.14	2.37	14.27	10.94	1.10	77435.00
4	6.17	4.81	57.78	1.94	14.18	10.89	1.07	75446.00
5	8.59	5.19	60.96	2.27	13.69	11.28	1.03	76977.00
6	9.35	4.21	57.50	1.84	14.04	10.88	1.04	76475.00
7	9.97	4.50	55.60	2.26	13.61	11.22	1.06	76767.00
8	10.21	5.32	55.98	2.03	14.08	11.01	1.04	76038.00
9	9.37	4.34	54.78	1.62	13.60	11.32	1.05	77299.00
10	8.48	4.65	56.13	1.30	14.48	10.98	1.08	79572.00
11	6.48	6.39	58.12	0.97	14.39	10.87	1.09	77040.00
12	7.48	6.93	59.27	1.09	14.54	10.83	1.10	77981.00
13	4.28	5.44	58.36	0.86	15.20	10.65	1.10	79013.00
14	4.16	7.62	51.46	0.62	16.12	10.52	1.10	79506.00
15	4.37	5.42	51.99	0.56	17.07	10.52	1.09	80431.00
16	3.27	4.00	54.72	0.73	16.07	10.76	1.04	78197.00
17	5.12	5.25	52.40	0.93	16.08	10.92	1.04	78930.00
18	4.10	4.59	51.62	0.96	16.02	10.93	1.05	77280.00
19	4.40	5.36	54.07	1.10	15.55	10.81	1.04	76858.00
20	4.96	4.82	46.63	1.15	15.93	10.48	1.03	77815.00
21	8.61	4.98	47.53	1.65	16.02	10.37	1.04	79604.00
22	7.67	3.40	50.81	1.39	15.97	10.32	1.04	78098.00
23	7.34	4.29	51.82	1.94	14.82	10.87	1.04	75689.00
24	6.17	6.90	57.23	1.35	15.27	10.83	1.06	76186.00
25	4.60	6.15	53.18	1.11	15.61	10.65	1.06	76423.00
26	4.67	5.88	47.03	0.97	15.37	10.63	1.09	77015.00
27	4.84	4.56	55.27	1.22	15.38	10.78	1.10	78007.00
28	6.78	4.56	54.52	1.01	16.48	10.42	1.12	79714.00
29	8.17	4.76	52.81	1.75	15.05	10.83	1.12	77651.00
平均值	6.38	5.12	53.58	1.35	15.20	10.76	1.07	77617.07
最大值	10.21	7.62	60.96	2.37	17.07	11.32	1.12	80431.00
最小值	2.40	3.40	41.36	0.56	13.60	10.14	1.03	75446.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。