

P001_樹林焚化廠CEMS系統月報表

報表日期: 2022年11月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	7.79	2.79	54.47	0.27	19.71	11.07	1.47	78160.00
2	6.09	2.64	52.81	0.27	19.23	11.21	1.48	76231.00
3	5.11	4.36	48.22	0.16	19.61	11.19	1.44	70170.00
4	5.71	4.91	54.55	0.54	18.93	11.45	1.47	58944.00
5	6.05	5.30	52.46	0.28	19.20	11.49	1.45	62418.00
6	6.02	5.84	48.18	0.20	20.70	11.11	1.43	63981.00
7	3.84	3.93	52.31	0.11	20.56	11.25	1.44	62554.00
8	4.75	3.60	45.89	0.15	21.34	11.02	1.42	63690.00
9	6.49	3.54	46.90	0.12	20.24	11.31	1.41	61727.00
10	6.87	3.66	49.61	0.11	20.10	11.30	1.42	64001.00
11	3.27	2.97	54.67	0.16	19.25	11.52	1.60	62663.00
12	6.38	4.66	47.80	0.39	19.38	11.40	1.58	61072.00
13	7.39	5.17	41.40	0.27	19.55	11.24	1.53	62324.00
14	4.13	3.33	49.87	0.15	19.38	11.55	1.51	60870.00
15	3.54	4.74	50.96	0.35	18.85	11.62	1.46	64269.00
16	8.91	3.95	52.80	0.53	19.60	11.45	1.43	61447.00
17	6.04	2.19	52.14	0.23	20.46	11.17	1.41	67208.00
18	7.33	3.46	53.92	0.47	20.15	11.21	1.40	63530.00
19	4.81	3.76	51.57	0.46	19.85	11.68	1.41	60127.00
20	5.03	5.00	53.53	0.49	19.81	11.70	1.44	59894.00
21	3.58	4.23	53.76	0.51	19.13	11.67	1.45	62129.00
22	2.59	3.89	56.21	0.28	20.04	11.48	1.43	62739.00
23	7.11	3.24	56.44	0.81	19.55	11.53	1.41	65852.00
24	5.63	4.28	57.56	1.21	19.89	11.50	1.42	74395.00
25	7.03	2.58	58.03	0.83	21.08	11.31	1.42	74908.00
26	7.96	3.59	55.52	1.02	20.42	11.35	1.40	74859.00
27	4.19	2.59	54.84	0.79	20.66	11.36	1.40	74603.00
28	2.86	3.15	58.25	0.91	19.78	11.55	1.41	72913.00
29	4.10	3.89	58.50	0.93	20.14	11.71	1.40	72620.00
30	6.94	5.42	56.67	1.21	18.16	11.85	1.36	74754.00
平均值	5.58	3.89	52.66	0.47	19.83	11.41	1.44	66501.73
最大值	8.91	5.84	58.50	1.21	21.34	11.85	1.60	78160.00
最小值	2.59	2.19	41.40	0.11	18.16	11.02	1.36	58944.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P002_樹林焚化廠CEMS系統月報表

報表日期: 2022年11月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	10.41	4.82	57.73	0.91	16.31	11.43	1.29	86482.00
2	9.52	4.64	55.01	0.83	15.96	11.61	1.36	83582.00
3	7.33	4.96	59.43	0.27	17.00	11.19	1.37	77084.00
4	6.08	4.31	59.27	0.31	16.30	11.35	1.37	62745.00
5	7.77	4.95	56.80	0.41	16.54	11.06	1.41	63858.00
6	8.12	6.16	58.36	0.45	17.60	10.91	1.37	64092.00
7	6.52	3.05	58.49	0.44	17.43	10.70	1.37	63554.00
8	6.89	3.48	59.92	0.59	16.95	11.14	1.40	62888.00
9	7.59	3.39	57.85	0.39	17.25	10.82	1.42	63854.00
10	6.80	2.73	57.02	0.29	17.89	10.64	1.45	66600.00
11	4.37	3.10	57.57	0.21	17.32	10.99	1.48	64685.00
12	8.14	3.14	57.97	0.48	16.99	10.97	1.46	63154.00
13	7.65	5.75	52.58	0.73	17.58	10.90	1.40	63784.00
14	5.73	3.58	56.25	0.37	17.98	10.61	1.39	64137.00
15	6.48	3.94	59.23	0.40	16.83	10.96	1.40	63660.00
16	7.65	3.61	58.40	0.55	17.22	10.80	1.41	64693.00
17	5.71	3.35	56.47	0.18	18.07	10.52	1.44	65982.00
18	8.23	3.84	58.38	0.52	17.65	10.64	1.46	65530.00
19	7.93	2.71	56.99	0.37	17.58	10.68	1.46	65733.00
20	6.71	4.37	57.75	0.53	18.46	10.40	1.45	66390.00
21	5.88	2.31	60.09	0.37	17.07	10.78	1.43	63981.00
22	5.71	4.11	60.28	0.47	17.57	10.61	1.46	65008.00
23	8.01	3.41	59.14	1.14	17.39	10.53	1.44	64860.00
24	7.84	3.62	60.19	2.26	17.15	10.85	1.47	63799.00
25	7.34	3.37	59.16	2.38	18.12	10.68	1.49	65775.00
26	7.49	2.33	62.16	2.09	17.77	10.79	1.47	65083.00
27	5.35	2.73	60.49	1.60	19.04	10.44	1.41	66510.00
28	8.33	2.24	61.78	2.26	18.30	10.40	1.41	65522.00
29	9.15	3.83	59.32	1.89	18.38	10.59	1.38	64910.00
30	10.36	4.06	61.89	2.69	17.39	10.80	1.30	65084.00
平均值	7.37	3.73	58.53	0.88	17.44	10.83	1.41	66433.97
最大值	10.41	6.16	62.16	2.69	19.04	11.61	1.49	86482.00
最小值	4.37	2.24	52.58	0.18	15.96	10.40	1.29	62745.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P003_樹林焚化廠CEMS系統月報表

報表日期: 2022年11月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	8.38	4.58	57.13	2.43	15.83	11.01	1.29	76452.00
2	8.44	3.45	49.55	2.69	15.53	10.68	1.32	76140.00
3	6.71	4.69	52.37	2.32	16.76	10.46	1.32	76683.00
4	6.93	5.36	48.60	2.22	16.30	10.39	1.35	77721.00
5	7.67	5.88	51.23	2.59	15.25	10.83	1.34	77363.00
6	7.12	6.05	50.39	2.16	16.69	10.59	1.34	79337.00
7	7.12	5.06	46.71	2.06	17.25	10.06	1.37	79793.00
8	7.21	4.53	49.02	2.31	16.48	10.47	1.36	79427.00
9	6.21	3.61	49.65	2.00	16.22	10.53	1.34	80150.00
10	5.88	4.05	47.96	1.79	17.23	10.20	1.34	80572.00
11	4.42	3.34	51.71	2.00	16.76	10.42	1.32	80823.00
12	7.10	5.23	49.90	2.50	16.10	10.55	1.30	80153.00
13	8.01	6.40	51.56	2.50	16.17	10.72	1.30	79952.00
14	6.23	3.60	50.46	2.12	16.39	10.58	1.34	81743.00
15	6.29	4.70	55.73	2.54	16.01	10.94	1.38	82353.00
16	8.70	5.13	54.74	2.88	15.97	10.81	1.38	81130.00
17	7.04	2.51	57.96	2.32	16.30	10.73	1.40	82086.00
18	7.73	4.45	59.98	3.10	15.34	10.99	1.38	79366.00
19	5.97	3.05	59.47	2.73	15.39	11.04	1.34	78575.00
20	5.47	4.77	58.29	2.24	16.10	10.72	1.31	79241.00
21	5.49	3.17	58.39	2.57	15.71	10.76	1.30	79521.00
22	6.29	4.68	60.85	2.63	16.25	10.63	1.32	81581.00
23	7.21	5.39	59.21	2.63	15.63	10.58	1.30	78824.00
24	8.08	4.44	57.41	2.81	16.07	10.52	1.31	80405.00
25	7.47	4.07	60.67	3.15	16.67	10.64	1.35	82484.00
26	9.10	3.51	59.18	2.71	16.14	10.62	1.37	81356.00
27	6.03	4.08	57.54	2.31	17.57	10.30	1.38	83241.00
28	5.52	3.82	59.69	2.32	16.54	10.44	1.39	80883.00
29	6.92	4.53	57.81	2.56	16.50	10.50	1.38	82493.00
30	8.19	3.15	61.26	2.73	15.79	10.70	1.35	82860.00
平均值	6.96	4.38	54.81	2.46	16.23	10.61	1.34	80090.27
最大值	9.10	6.40	61.26	3.15	17.57	11.04	1.40	83241.00
最小值	4.42	2.51	46.71	1.79	15.25	10.06	1.29	76140.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。