

P001_樹林焚化廠CEMS系統月報表

報表日期: 2022年04月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	15.11	15.33	56.81	1.62	15.10	12.13	1.49	81447.00
2	14.86	9.47	55.23	1.19	15.38	12.11	1.47	80375.00
3	15.94	11.18	56.28	0.72	16.69	12.01	1.48	63067.00
4	15.86	9.35	56.47	0.64	16.65	12.00	1.45	61849.00
5	15.65	9.49	42.29	0.77	15.68	10.97	1.46	68387.00
6	15.59	9.65	50.43	1.13	16.08	11.72	1.43	66049.00
7	15.46	9.75	53.36	0.72	16.38	12.02	1.47	61897.00
8	14.70	17.57	57.45	0.80	16.16	12.06	1.46	61393.00
9	14.40	12.57	51.33	0.68	16.62	11.83	1.47	62203.00
10	14.41	8.37	55.39	0.54	17.11	11.73	1.47	61024.00
11	13.61	13.64	55.53	0.61	17.30	11.68	1.46	61361.00
12	13.31	19.85	54.20	0.81	16.49	11.90	1.47	60464.00
13	14.22	10.99	55.70	1.04	16.58	11.91	1.49	60438.00
14	13.40	10.45	62.30	1.08	16.43	12.03	1.49	60608.00
15	12.93	8.48	52.94	0.68	17.62	11.50	1.48	64014.00
16	12.57	10.65	53.79	0.78	17.42	11.55	1.50	64111.00
17	12.26	10.15	53.80	0.94	16.83	11.58	1.50	64323.00
18	12.55	8.10	56.02	1.00	16.17	11.77	1.49	62449.00
19	12.07	12.23	53.34	0.77	16.89	11.58	1.49	64040.00
20	12.28	15.00	51.28	0.72	17.05	11.67	1.51	62961.00
21	12.31	10.78	60.88	0.63	17.02	11.69	1.51	61080.00
22	13.18	12.83	57.24	0.77	18.11	11.31	1.48	64030.00
23	14.32	9.51	57.45	1.16	18.04	11.37	1.48	63471.00
24	14.30	7.71	55.74	1.13	18.08	11.25	1.47	64094.00
25	14.11	7.35	57.81	1.13	18.09	11.39	1.48	63362.00
26	14.41	11.50	52.47	0.83	18.30	11.63	1.42	61790.00
27	14.39	8.95	55.08	1.21	17.22	11.54	1.44	61890.00
28	14.03	7.56	61.03	1.06	17.43	11.60	1.41	62148.00
29	14.48	10.19	57.68	0.81	17.51	11.56	1.40	63154.00
30	14.16	12.88	56.72	1.32	15.64	12.16	1.40	60928.00
平均值	14.03	11.05	55.20	0.91	16.87	11.71	1.47	63946.90
最大值	15.94	19.85	62.30	1.62	18.30	12.16	1.51	81447.00
最小值	12.07	7.35	42.29	0.54	15.10	10.97	1.40	60438.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P002_樹林焚化廠CEMS系統月報表

報表日期: 2022年04月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	14.14	6.71	61.28	0.48	15.95	11.43	1.49	58568.00
2	14.13	5.57	59.02	0.34	16.46	11.33	1.48	58600.00
3	14.12	7.97	64.43	0.31	17.57	10.98	1.50	60902.00
4	13.83	4.21	61.35	0.28	16.95	11.03	1.53	59458.00
5	13.48	7.24	53.27	0.25	18.08	10.94	1.53	59512.00
6	13.73	6.09	57.39	0.26	18.03	10.97	1.51	59413.00
7	14.68	7.83	52.26	1.00	17.19	11.18	1.50	69377.00
8	13.68	13.79	56.60	0.57	17.07	11.16	1.48	63981.00
9	14.29	5.42	53.99	0.41	17.10	11.05	1.48	59450.00
10	14.13	6.76	49.02	0.29	18.11	10.70	1.47	59746.00
11	13.01	8.30	52.70	0.29	17.90	10.86	1.45	58888.00
12	13.75	14.23	51.57	0.28	17.71	10.77	1.44	57943.00
13	12.69	15.19	56.41	0.45	16.80	10.88	1.45	57828.00
14	13.62	11.36	57.47	0.34	16.96	10.95	1.43	56789.00
15	11.76	6.37	52.77	0.53	17.24	10.99	1.39	59366.00
16	11.27	8.53	48.48	0.36	17.69	11.03	1.39	58397.00
17	11.93	4.99	49.77	0.17	18.56	10.69	1.37	58686.00
18	12.20	6.25	51.26	0.47	17.27	10.87	1.35	57802.00
19	11.93	9.67	42.05	0.17	18.35	10.85	1.33	58959.00
20	11.79	11.08	49.65	0.20	17.79	10.60	1.35	59477.00
21	11.75	12.53	44.64	0.31	17.09	11.26	1.37	57663.00
22	12.77	6.82	49.90	0.20	18.37	10.71	1.39	62158.00
23	13.76	8.60	55.92	0.37	17.74	10.81	1.43	65055.00
24	13.97	6.99	55.19	0.35	18.30	10.49	1.42	66934.00
25	13.90	7.05	58.08	0.36	18.48	10.48	1.39	66331.00
26	9.12	6.87	61.43	0.25	17.85	10.96	1.39	64727.00
27	12.52	9.82	56.49	0.32	17.31	10.77	1.38	65449.00
28	14.11	8.19	57.95	0.28	17.35	10.71	1.38	66411.00
29	14.48	5.26	56.06	0.22	18.27	10.50	1.38	67815.00
30	14.21	7.00	55.94	0.39	17.34	10.80	1.36	66443.00
平均值	13.16	8.22	54.41	0.35	17.56	10.89	1.43	61404.27
最大值	14.68	15.19	64.43	1.00	18.56	11.43	1.53	69377.00
最小值	9.12	4.21	42.05	0.17	15.95	10.48	1.33	56789.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P003_樹林焚化廠CEMS系統月報表

報表日期: 2022年04月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	14.67	4.97	53.30	2.31	15.62	10.49	1.40	72824.00
2	14.62	5.08	54.05	1.84	16.09	10.54	1.42	73688.00
3	14.78	5.20	55.50	1.97	16.95	10.22	1.45	76930.00
4	14.88	7.76	56.25	2.05	16.43	10.15	1.45	73443.00
5	14.57	5.15	52.99	2.08	17.44	10.01	1.47	76010.00
6	14.24	12.24	47.50	1.95	17.41	9.96	1.46	72153.00
7	14.41	6.92	51.97	1.84	16.55	10.17	1.45	72739.00
8	15.08	7.38	53.60	1.87	17.19	10.57	1.46	73343.00
9	14.62	6.48	56.90	1.64	17.14	10.26	1.45	77230.00
10	14.26	6.18	57.58	1.71	17.64	10.05	1.42	73675.00
11	14.04	8.69	53.13	1.74	17.59	9.77	1.41	73374.00
12	14.09	10.10	51.98	1.71	17.21	10.08	1.42	73772.00
13	14.58	13.80	49.92	2.30	16.77	9.94	1.45	73217.00
14	12.23	7.05	54.11	2.32	16.63	10.12	1.43	73977.00
15	12.49	8.96	48.49	2.29	17.42	9.69	1.40	73536.00
16	11.89	10.11	56.64	2.15	19.17	10.19	1.39	73439.00
17	11.78	5.25	56.66	2.15	17.02	10.03	1.38	73968.00
18	11.78	9.98	54.57	2.34	16.38	10.03	1.38	71684.00
19	11.84	6.82	55.36	2.20	16.57	10.40	1.39	75555.00
20	11.87	10.08	50.98	2.24	16.79	10.08	1.44	73480.00
21	11.94	8.55	63.62	2.41	15.95	10.57	1.45	71446.00
22	13.09	8.45	56.74	2.77	16.98	10.35	1.41	73026.00
23	14.49	9.01	52.99	2.83	17.18	9.91	1.42	72358.00
24	14.38	7.38	58.00	2.76	17.40	10.03	1.46	73369.00
25	14.34	11.98	49.57	3.01	17.62	9.49	1.48	72500.00
26	14.33	8.05	57.82	2.69	18.17	9.71	1.47	72410.00
27	14.44	8.75	55.14	3.02	17.40	9.94	1.44	73448.00
28	14.24	10.52	52.58	3.09	17.06	9.80	1.43	73446.00
29	12.35	10.26	52.26	3.15	16.32	10.59	1.41	75157.00
30	13.28	7.42	54.44	2.97	15.59	10.66	1.42	74270.00
平均值	13.65	8.29	54.15	2.31	16.99	10.13	1.43	73648.90
最大值	15.08	13.80	63.62	3.15	19.17	10.66	1.48	77230.00
最小值	11.78	4.97	47.50	1.64	15.59	9.49	1.38	71446.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。