

P001_樹林焚化廠CEMS系統月報表

報表日期: 2022年01月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	16.44	19.06	55.23	1.96	15.03	11.66	1.35	65603.00
2	20.19	7.98	61.73	1.90	15.34	11.56	1.33	67176.00
3	14.94	9.99	66.53	1.65	15.22	12.00	1.35	63594.00
4	12.98	12.63	59.09	1.65	15.63	11.83	1.40	64423.00
5	11.64	10.09	68.55	1.57	16.02	11.58	1.40	65394.00
6	12.04	8.35	57.45	1.74	15.94	11.31	1.38	68469.00
7	19.17	10.14	67.21	2.52	14.95	11.74	1.37	66746.00
8	21.93	19.90	63.98	2.50	14.83	11.70	1.41	67452.00
9	11.90	6.20	72.09	1.70	15.39	11.80	1.43	65019.00
10	13.33	7.37	69.77	1.98	15.22	11.56	1.42	66717.00
11	13.35	15.01	60.07	2.21	14.39	11.84	1.40	65992.00
12	15.30	18.73	58.38	2.25	14.19	11.82	1.40	65928.00
13	16.13	8.79	58.96	1.68	15.08	11.50	1.40	67414.00
14	12.10	11.35	55.17	1.29	15.36	11.36	1.41	68208.00
15	**	**	**	**	**	**	**	**
16	14.68	18.98	53.47	1.95	15.65	11.23	1.36	69806.00
17	16.98	7.45	64.36	1.57	15.82	11.44	1.34	69123.00
18	14.73	8.09	62.40	1.80	15.62	11.46	1.34	68886.00
19	14.62	14.11	61.24	1.87	15.16	11.54	1.34	68871.00
20	16.06	19.22	56.84	1.73	15.23	11.50	1.37	68713.00
21	13.41	12.94	60.14	1.36	15.78	11.52	1.35	68496.00
22	15.35	12.07	61.85	1.77	15.61	11.71	1.33	66715.00
23	13.95	8.09	57.36	1.24	16.43	11.31	1.36	68991.00
24	14.50	10.91	59.63	1.65	15.43	11.44	1.39	68341.00
25	10.18	8.40	55.93	1.17	15.57	11.61	1.44	67714.00
26	16.10	7.32	55.53	1.50	15.34	11.66	1.44	68096.00
27	15.31	7.66	57.06	1.54	15.15	11.63	1.45	67110.00
28	15.52	6.57	54.69	1.95	14.56	11.74	1.40	67957.00
29	18.35	13.05	60.60	2.50	13.58	12.32	1.35	64275.00
30	18.35	7.80	46.00	1.67	14.36	11.62	1.35	69608.00
31	15.36	9.64	43.89	0.85	15.53	11.33	1.41	70966.00
平均值	15.16	11.26	59.51	1.76	15.25	11.61	1.38	67393.43
最大值	21.93	19.90	72.09	2.52	16.43	12.32	1.45	70966.00
最小值	10.18	6.20	43.89	0.85	13.58	11.23	1.33	63594.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P002_樹林焚化廠CEMS系統月報表

報表日期: 2022年01月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	15.67	7.51	67.22	0.49	15.94	10.94	1.45	61030.00
2	18.60	8.28	73.46	0.78	15.73	11.08	1.44	60974.00
3	14.03	6.96	67.38	0.71	15.77	10.99	1.40	60481.00
4	14.00	11.09	57.52	0.77	15.54	11.01	1.43	60749.00
5	11.83	9.07	59.67	0.46	15.95	11.11	1.48	59022.00
6	11.50	9.91	56.95	0.46	15.99	10.93	1.49	59200.00
7	16.55	8.53	57.91	1.30	15.93	11.00	1.54	64195.00
8	14.50	9.23	63.26	0.83	15.42	10.93	1.51	59659.00
9	12.83	9.57	62.85	0.46	16.25	10.87	1.49	59930.00
10	13.50	6.42	63.78	0.48	15.84	10.94	1.52	60525.00
11	14.38	10.00	61.15	1.60	15.50	11.18	1.51	60238.00
12	17.75	7.03	65.30	1.52	15.17	10.86	1.50	61908.00
13	18.46	7.92	60.65	0.75	15.42	10.98	1.49	60743.00
14	12.35	8.33	64.62	0.34	16.18	10.81	1.50	61477.00
15	14.16	7.97	57.97	0.36	16.46	10.44	1.53	63549.00
16	13.69	7.38	64.26	0.33	16.28	10.58	1.52	62494.00
17	16.35	4.75	61.81	0.41	16.19	10.67	1.46	61852.00
18	15.10	6.98	55.66	0.54	15.81	10.72	1.48	61458.00
19	14.48	12.56	60.45	0.59	15.48	10.90	1.49	60747.00
20	16.50	5.28	64.62	0.53	15.73	10.97	1.49	60545.00
21	14.51	9.45	58.63	0.42	16.19	10.83	1.49	60700.00
22	16.45	8.99	63.48	0.88	15.90	10.68	1.50	60597.00
23	13.63	5.78	61.67	0.31	16.42	10.59	1.54	61106.00
24	12.33	6.20	60.50	0.40	15.64	10.82	1.48	59774.00
25	9.99	4.13	57.18	0.28	15.90	10.80	1.45	60739.00
26	14.95	7.01	59.26	0.50	15.38	11.13	1.48	60697.00
27	13.48	10.40	54.52	0.52	14.87	11.20	1.47	59425.00
28	14.52	9.56	62.69	0.59	14.63	11.30	1.45	60049.00
29	16.21	8.60	56.30	0.68	14.46	11.27	1.41	60341.00
30	14.49	11.82	52.98	0.45	15.02	11.01	1.43	62766.00
31	14.38	7.83	52.12	0.28	15.43	10.91	1.48	62876.00
平均值	14.55	8.21	60.83	0.61	15.69	10.92	1.48	60962.77
最大值	18.60	12.56	73.46	1.60	16.46	11.30	1.54	64195.00
最小值	9.99	4.13	52.12	0.28	14.46	10.44	1.40	59022.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P003_樹林焚化廠CEMS系統月報表

報表日期: 2022年01月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	16.26	14.34	63.28	3.50	15.04	10.54	1.43	72898.00
2	18.24	8.83	59.44	3.07	15.66	10.17	1.44	73966.00
3	14.88	11.47	63.89	3.10	14.73	10.57	1.48	71087.00
4	13.15	5.50	60.77	2.67	15.38	10.64	1.44	72500.00
5	12.69	5.89	62.37	2.56	15.33	10.58	1.41	73224.00
6	12.88	7.91	62.01	2.47	15.92	11.04	1.43	76056.00
7	17.35	11.08	68.38	3.59	15.27	10.50	1.41	74499.00
8	16.95	13.28	64.25	3.55	14.31	10.55	1.41	72784.00
9	12.44	5.53	60.84	2.55	16.18	10.45	1.43	75695.00
10	14.52	4.07	66.71	2.98	15.02	10.51	1.43	73853.00
11	16.94	6.25	60.97	2.96	15.22	10.52	1.39	74644.00
12	14.00	9.55	51.91	2.64	15.13	10.35	1.41	75913.00
13	16.33	6.49	56.70	2.33	15.84	11.50	1.43	76478.00
14	12.61	7.68	59.27	2.16	15.83	10.46	1.41	77119.00
15	13.87	11.37	54.24	2.16	15.51	9.98	1.42	75928.00
16	13.26	7.77	62.50	1.99	15.98	10.05	1.42	75763.00
17	14.92	6.89	64.21	2.66	15.58	10.22	1.39	74197.00
18	11.74	4.17	58.38	2.62	15.37	10.35	1.39	74074.00
19	12.92	9.66	55.83	2.54	15.10	10.31	1.40	73539.00
20	15.67	12.77	56.01	2.34	15.33	10.28	1.38	74318.00
21	13.33	11.00	57.92	2.28	15.41	10.53	1.39	73969.00
22	13.71	15.85	54.48	2.46	15.50	10.04	1.39	73132.00
23	14.38	14.03	50.55	2.34	15.80	10.16	1.39	73078.00
24	16.58	18.64	47.70	2.50	15.43	10.05	1.43	73081.00
25	15.10	10.55	51.02	2.40	15.12	10.33	1.47	74970.00
26	14.37	28.47	43.38	2.16	15.90	9.67	1.47	72986.00
27	13.52	14.61	46.56	2.11	14.70	10.30	1.45	73127.00
28	14.42	27.13	41.36	2.65	14.83	10.05	1.46	69881.00
29	14.83	10.99	45.82	2.16	14.79	10.27	1.47	73757.00
30	13.85	7.25	47.63	5.46	16.54	10.33	1.49	76047.00
31	**	**	**	**	**	**	**	72898.00
平均值	14.52	10.97	56.61	2.70	15.39	10.38	1.43	74047.13
最大值	18.24	28.47	68.38	5.46	16.54	11.50	1.49	77119.00
最小值	11.74	4.07	41.36	1.99	14.31	9.67	1.38	69881.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。