

P001\_樹林焚化廠CEMS系統月報表

報表日期: 2021年1月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	**	**	**	**	**	**	**	**
2	9.00	17.72	61.93	1.79	13.12	13.31	1.20	75159.00
3	4.82	8.71	62.94	0.87	14.19	13.19	1.20	75861.00
4	5.95	11.24	67.91	0.91	14.51	13.21	1.20	76144.00
5	5.61	12.82	59.62	1.46	14.30	13.16	1.20	76000.00
6	11.08	16.24	71.77	2.32	13.58	13.46	1.18	75289.00
7	5.69	3.36	77.49	1.79	13.19	13.66	1.21	73587.00
8	2.84	14.95	69.63	1.24	13.07	13.26	1.25	69421.00
9	5.75	5.51	76.70	1.52	12.85	13.63	1.23	75777.00
10	3.32	5.39	75.29	0.95	13.80	13.65	1.26	75516.00
11	6.38	4.67	74.85	1.48	13.16	13.66	1.22	74963.00
12	4.44	7.70	69.79	1.69	12.94	13.49	1.25	75848.00
13	13.52	22.34	74.32	2.66	12.56	13.91	1.24	72780.00
14	7.49	8.41	69.20	1.59	13.20	13.55	1.23	74900.00
15	5.64	10.27	69.89	1.35	13.48	13.54	1.34	74596.00
16	6.47	16.54	63.73	1.71	13.56	13.22	1.40	74555.00
17	5.20	4.97	70.40	1.54	13.52	13.39	1.32	76471.00
18	4.11	12.65	61.28	1.33	13.37	12.99	1.38	74165.00
19	11.53	14.39	64.41	1.85	13.03	13.27	1.34	75520.00
20	7.14	17.80	58.81	1.16	14.35	13.03	1.31	75190.00
21	9.10	15.36	64.40	1.09	14.05	13.28	1.29	72614.00
22	7.39	24.67	62.71	1.12	14.59	13.21	1.29	73855.00
23	10.87	18.65	65.08	1.49	13.77	13.25	1.27	74510.00
24	11.77	15.11	60.58	1.80	13.43	13.10	1.29	76428.00
25	7.98	23.30	58.07	1.29	13.89	12.74	1.31	75155.00
26	5.66	23.18	58.05	0.96	14.13	12.88	1.31	76204.00
27	7.09	28.08	59.73	1.65	13.87	12.84	1.28	76099.00
28	5.36	23.92	58.62	1.48	13.37	12.87	1.21	76278.00
29	3.02	12.81	69.34	1.18	13.28	13.22	1.15	76625.00
30	5.33	25.33	71.99	1.53	12.82	13.28	1.17	75135.00
31	5.09	14.64	76.34	0.81	13.89	13.28	1.16	76661.00
平均值	6.82	14.69	66.83	1.45	13.56	13.28	1.26	75043.53
最大值	13.52	28.08	77.49	2.66	14.59	13.91	1.40	76661.00
最小值	2.84	3.36	58.05	0.81	12.56	12.74	1.15	69421.00

備註： 1.\*:儀器保養維護中。

2.\*\*:停爐中。

P002\_樹林焚化廠CEMS系統月報表

報表日期: 2021年1月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	22.99	16.29	96.66	2.47	14.42	11.09	1.23	64071.00
2	14.71	12.25	96.85	1.08	15.66	11.10	1.30	62465.00
3	17.55	5.75	91.30	0.69	18.89	10.32	1.34	66212.00
4	16.21	4.80	93.84	0.70	19.34	10.42	1.30	65600.00
5	14.82	9.33	95.42	2.12	16.77	10.89	1.31	64507.00
6	18.53	13.52	95.92	1.91	16.47	10.78	1.36	65457.00
7	18.38	7.85	94.41	1.53	16.30	10.67	1.36	65470.00
8	19.67	12.25	95.69	1.30	16.00	10.93	1.36	64965.00
9	17.63	8.53	94.68	1.37	15.98	10.90	1.37	66483.00
10	12.10	11.79	97.01	0.82	17.37	10.88	1.38	64575.00
11	14.62	9.53	92.15	1.16	16.59	10.82	1.40	65572.00
12	16.10	16.98	91.78	1.03	16.63	10.69	1.39	66539.00
13	19.50	17.62	96.58	1.26	16.35	10.84	1.39	65862.00
14	21.72	9.19	99.80	0.89	16.95	10.70	1.40	66335.00
15	18.09	16.41	100.30	1.41	15.53	11.21	1.42	63775.00
16	20.63	9.33	107.05	1.64	14.89	11.37	1.41	63317.00
17	18.33	6.85	104.56	1.83	14.93	11.40	1.40	63539.00
18	20.95	15.80	101.30	2.07	13.87	11.64	1.43	60975.00
19	13.59	6.55	95.41	1.22	14.78	11.22	1.44	63063.00
20	15.82	6.66	86.91	1.07	15.76	11.12	1.51	63682.00
21	15.35	10.29	89.61	0.92	15.78	11.14	1.49	63011.00
22	14.69	9.47	81.63	1.27	16.13	10.90	1.48	64639.00
23	15.38	8.39	74.70	1.20	17.39	10.45	1.47	67153.00
24	16.14	9.20	70.43	1.65	17.51	10.33	1.40	66655.00
25	20.86	5.76	80.89	1.17	18.96	10.31	1.39	67577.00
26	20.18	4.38	77.18	1.42	19.22	10.45	1.38	67369.00
27	21.67	9.25	71.26	1.80	18.02	10.50	1.39	66160.00
28	13.13	9.25	68.06	1.11	14.94	10.74	1.39	64948.00
29	11.86	8.13	71.80	1.04	15.10	10.73	1.38	66251.00
30	15.50	11.53	76.57	1.74	14.17	11.15	1.41	64027.00
31	15.09	6.56	80.28	1.07	15.58	10.75	1.45	65627.00
平均值	17.15	9.98	89.36	1.35	16.33	10.85	1.39	65028.42
最大值	22.99	17.62	107.05	2.47	19.34	11.64	1.51	67577.00
最小值	11.86	4.38	68.06	0.69	13.87	10.31	1.23	60975.00

備註： 1.\*:儀器保養維護中。

2.\*\*:停爐中。

P003\_樹林焚化廠CEMS系統月報表

報表日期: 2021年1月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	21.18	19.47	84.86	4.83	12.56	11.49	1.17	76491.00
2	15.18	9.95	84.11	3.15	13.41	11.58	1.20	76259.00
3	12.60	4.16	86.44	2.46	14.75	11.44	1.30	78722.00
4	13.80	5.74	93.60	2.32	14.89	11.50	1.37	79591.00
5	13.78	9.51	83.13	2.58	15.02	11.25	1.38	79146.00
6	16.52	10.17	87.48	3.17	14.15	11.64	1.37	77123.00
7	14.54	5.44	84.79	3.08	13.96	11.46	1.38	77014.00
8	22.34	7.21	84.51	3.65	13.55	11.56	1.43	78319.00
9	19.48	10.67	84.39	2.97	15.40	11.38	1.44	80967.00
10	14.95	8.26	100.35	2.66	17.22	11.38	1.48	80478.00
11	17.24	6.82	88.46	2.88	16.01	11.18	1.45	82232.00
12	19.94	12.61	78.19	3.97	13.84	11.22	1.43	82827.00
13	20.69	23.62	78.55	4.11	13.42	11.34	1.40	81277.00
14	22.04	15.54	75.85	3.60	13.51	11.72	1.40	77505.00
15	19.34	12.67	60.31	3.46	14.08	11.30	1.40	82204.00
16	26.08	15.37	62.16	2.86	14.22	11.53	1.38	79597.00
17	16.69	8.28	67.13	3.15	14.28	11.58	1.34	81268.00
18	18.28	9.49	61.88	3.92	13.84	11.33	1.36	80562.00
19	12.33	9.96	61.25	2.73	14.04	11.23	1.34	80548.00
20	14.92	8.82	63.15	2.89	14.85	11.09	1.39	78164.00
21	15.91	10.92	69.54	3.43	14.32	11.40	1.41	76569.00
22	13.32	10.75	63.95	2.52	15.14	11.16	1.38	78418.00
23	13.22	6.09	61.41	2.50	15.61	10.85	1.37	82647.00
24	11.98	4.20	62.39	2.85	14.94	11.06	1.33	81506.00
25	12.03	7.16	62.45	2.83	14.72	10.83	1.35	81577.00
26	10.11	7.81	61.31	2.30	14.30	11.00	1.37	82211.00
27	14.28	11.09	58.37	3.44	14.64	10.77	1.37	80582.00
28	16.82	8.72	58.42	2.92	13.78	10.94	1.36	81886.00
29	10.22	11.34	60.82	2.41	13.80	11.11	1.37	82471.00
30	14.38	17.14	57.12	3.39	13.30	11.11	1.45	78305.00
31	14.22	7.56	68.57	2.73	14.53	10.95	1.49	76491.00
平均值	16.08	10.21	72.74	3.09	14.39	11.27	1.38	79772.81
最大值	26.08	23.62	100.35	4.83	17.22	11.72	1.49	82827.00
最小值	10.11	4.16	57.12	2.30	12.56	10.77	1.17	76259.00

備註： 1.\*:儀器保養維護中。

2.\*\*:停爐中。