

P001\_樹林焚化廠CEMS系統月報表

報表日期: 2023年11月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	8.90	8.93	50.87	1.16	19.06	10.99	1.10	76221.00
2	7.47	8.22	53.14	1.14	17.89	11.24	1.08	74030.00
3	8.59	8.48	48.42	0.98	19.80	10.88	1.06	76389.00
4	8.17	8.36	48.14	0.70	19.58	11.01	1.07	75007.00
5	6.97	8.24	50.19	0.94	18.86	11.06	1.08	74907.00
6	7.05	8.47	40.88	0.66	19.98	10.69	1.06	76404.00
7	7.16	9.15	53.17	1.02	18.01	11.30	1.02	75306.00
8	8.49	10.46	46.34	0.81	19.49	10.91	1.00	76477.00
9	7.19	7.41	48.63	0.95	17.56	11.25	1.03	73363.00
10	6.38	7.86	51.14	0.56	19.40	11.08	1.06	74332.00
11	6.90	7.33	52.70	0.77	18.60	11.30	1.05	75307.00
12	7.74	6.15	51.95	0.74	19.11	11.06	1.06	76071.00
13	7.19	7.56	51.08	0.93	17.30	11.39	1.04	75590.00
14	5.78	8.26	50.42	1.47	18.92	11.03	1.08	76756.00
15	7.47	7.64	52.33	1.68	17.93	11.32	1.09	75617.00
16	7.93	8.80	50.58	1.11	19.17	11.03	1.09	75683.00
17	6.57	8.43	54.56	1.46	17.12	11.50	1.06	74547.00
18	8.07	7.07	51.33	1.17	17.65	11.28	1.07	76072.00
19	8.44	6.97	52.42	1.23	17.49	11.38	1.08	74871.00
20	7.62	7.85	51.69	1.04	17.74	11.53	1.06	74316.00
21	7.29	7.17	51.58	1.34	17.95	11.41	1.07	74214.00
22	8.98	6.56	53.75	2.00	18.39	11.23	1.06	74525.00
23	8.87	6.37	54.37	2.37	16.84	11.39	1.08	74597.00
24	9.40	8.06	55.83	1.92	17.69	11.28	1.07	76167.00
25	9.06	8.22	57.52	2.13	16.85	11.50	1.06	75320.00
26	9.50	8.23	49.68	1.50	18.60	11.17	1.06	75966.00
27	8.87	8.20	48.97	1.27	18.03	11.36	1.05	74158.00
28	5.92	7.97	52.67	0.96	18.30	11.09	1.07	72833.00
29	8.86	6.79	52.63	1.42	17.39	11.45	1.06	73835.00
30	8.81	6.90	55.81	1.31	17.06	11.56	1.04	74101.00
平均值	7.85	7.87	51.43	1.22	18.26	11.22	1.06	75099.40
最大值	9.50	10.46	57.52	2.37	19.98	11.56	1.10	76756.00
最小值	5.78	6.15	40.88	0.56	16.84	10.69	1.00	72833.00

備註： 1.\*:儀器保養維護中。

2.\*\*:停爐中。

P002\_樹林焚化廠CEMS系統月報表

報表日期: 2023年11月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	6.96	5.25	53.63	2.27	16.03	10.73	0.99	83242.00
2	6.24	4.50	52.27	1.76	16.64	10.72	1.04	83406.00
3	5.69	7.01	53.83	2.11	17.49	10.53	1.07	83679.00
4	6.13	5.79	53.45	2.50	17.27	10.42	1.06	84580.00
5	6.21	5.38	50.32	2.46	17.63	10.30	1.06	84925.00
6	7.05	5.09	48.24	1.93	16.78	10.39	1.05	84108.00
7	6.27	5.00	55.22	2.27	16.83	10.29	1.02	84839.00
8	7.63	5.97	55.05	2.32	17.34	10.18	1.02	85539.00
9	7.74	5.38	56.42	1.95	16.49	10.54	1.02	83340.00
10	6.13	5.12	53.86	1.81	17.58	10.14	1.00	85214.00
11	6.12	5.05	57.63	1.86	16.53	10.59	0.99	83543.00
12	4.90	4.11	52.29	2.05	17.16	10.37	1.00	84417.00
13	5.41	4.83	53.88	2.09	16.23	10.51	0.99	84809.00
14	2.83	5.75	56.18	1.99	16.94	10.34	1.01	84733.00
15	6.17	5.04	54.67	2.33	16.55	10.37	1.03	84887.00
16	7.50	5.45	56.30	2.00	16.06	10.58	1.06	83639.00
17	5.59	4.42	56.53	2.28	16.40	10.24	1.04	86323.00
18	6.31	4.78	57.93	2.57	16.01	10.47	1.03	84964.00
19	8.39	3.86	53.45	2.52	16.27	10.34	1.03	85743.00
20	7.33	4.52	54.71	2.20	16.04	10.52	1.01	84279.00
21	6.34	4.37	52.42	2.29	17.10	10.18	1.01	85649.00
22	8.94	4.62	53.91	2.71	16.25	10.42	1.01	84623.00
23	8.15	3.94	50.66	1.92	16.97	10.18	0.99	85824.00
24	9.12	4.26	54.25	2.37	16.11	10.18	1.01	86835.00
25	8.84	5.54	45.86	2.29	16.37	10.27	1.00	85360.00
26	9.28	5.31	49.93	2.10	16.77	10.28	1.03	84865.00
27	6.40	5.06	50.58	1.58	16.27	10.59	1.04	83058.00
28	5.83	4.95	50.37	1.91	17.33	9.87	1.01	87078.00
29	8.70	5.62	54.48	2.21	16.28	10.24	1.00	85261.00
30	8.31	4.35	55.23	1.77	16.83	10.07	1.04	86507.00
平均值	6.88	5.01	53.45	2.15	16.69	10.36	1.02	84842.30
最大值	9.28	7.01	57.93	2.71	17.63	10.73	1.07	87078.00
最小值	2.83	3.86	45.86	1.58	16.01	9.87	0.99	83058.00

備註： 1.\*:儀器保養維護中。

2.\*\*:停爐中。

P003\_樹林焚化廠CEMS系統月報表

報表日期: 2023年11月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	7.52	5.37	51.96	1.95	14.88	11.07	0.94	78048.00
2	6.16	5.15	50.30	1.39	15.41	10.73	0.95	75963.00
3	7.09	4.70	47.53	1.27	15.97	10.73	0.94	77607.00
4	4.85	5.65	47.77	1.28	15.97	10.92	0.93	78120.00
5	7.14	6.83	50.15	1.42	16.44	10.73	0.95	79244.00
6	7.10	5.64	52.40	1.52	15.98	10.57	0.98	77527.00
7	5.01	6.15	50.42	1.64	15.46	10.87	1.01	79095.00
8	7.40	6.61	50.70	1.71	16.03	10.56	1.00	79129.00
9	6.60	4.95	53.81	2.11	14.61	10.84	1.00	75649.00
10	6.60	6.70	49.44	1.72	15.98	10.70	0.98	77156.00
11	4.72	5.50	52.17	1.55	16.00	10.85	0.96	77403.00
12	4.59	5.73	48.61	1.56	15.98	10.78	0.95	77971.00
13	5.56	5.18	51.40	1.80	14.88	10.86	0.92	77062.00
14	5.38	6.74	49.37	1.55	15.73	10.78	0.99	78947.00
15	7.16	5.84	51.01	1.80	15.97	10.68	1.04	78410.00
16	6.18	5.87	51.41	1.73	15.43	10.78	1.02	78024.00
17	4.52	5.97	50.13	1.87	15.06	11.02	1.00	78496.00
18	5.13	4.88	51.06	1.68	14.54	11.15	1.01	76964.00
19	6.83	6.11	51.39	1.80	15.00	10.98	1.01	76563.00
20	4.61	5.75	55.37	1.57	14.62	11.18	1.01	76436.00
21	7.33	6.20	53.84	1.84	15.53	11.09	1.01	79160.00
22	9.53	5.10	53.99	2.94	14.92	10.96	0.99	77508.00
23	8.86	4.62	54.81	2.46	14.75	10.81	0.95	77434.00
24	9.59	5.68	55.24	2.59	14.56	11.08	0.94	79738.00
25	8.66	7.13	55.05	2.22	14.77	11.08	0.95	78533.00
26	8.56	5.75	52.87	1.92	15.24	11.08	0.96	78014.00
27	8.14	6.12	51.41	1.78	15.24	10.69	0.96	76055.00
28	4.37	5.57	51.93	1.64	14.99	10.97	0.97	77655.00
29	8.01	5.20	53.02	2.03	14.79	10.91	0.98	76370.00
30	7.95	4.90	50.19	1.87	14.91	11.00	0.98	76687.00
平均值	6.71	5.72	51.63	1.81	15.32	10.88	0.98	77698.93
最大值	9.59	7.13	55.37	2.94	16.44	11.18	1.04	79738.00
最小值	4.37	4.62	47.53	1.27	14.54	10.56	0.92	75649.00

備註： 1.\*:儀器保養維護中。

2.\*\*:停爐中。