

P001_樹林焚化廠CEMS系統月報表

報表日期: 2020年04月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm ³ /Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	2.54	2.55	90.60	9.16	15.92	11.47	0.84	90856.00
2	3.40	6.36	81.47	8.98	15.52	11.51	0.89	90343.00
3	1.91	4.07	82.80	9.00	16.12	11.40	0.92	91404.00
4	3.56	4.01	84.58	9.05	15.29	11.57	0.89	89949.00
5	2.00	5.31	86.31	8.90	15.96	11.50	0.93	90764.00
6	3.02	6.38	79.72	8.64	15.84	11.22	0.97	90446.00
7	2.72	12.24	77.60	8.99	15.85	11.27	0.97	88375.00
8	3.99	6.15	81.78	8.93	15.74	11.34	0.93	87033.00
9	3.41	4.76	81.56	9.00	15.55	11.34	0.92	84080.00
10	2.06	6.83	82.98	8.83	15.48	11.24	1.00	79627.00
11	1.96	9.84	75.14	8.73	15.42	11.12	1.01	73892.00
12	1.79	10.78	79.69	9.04	15.77	11.37	1.00	77336.00
13	1.85	9.50	74.82	8.40	14.42	11.20	1.00	71508.00
14	1.70	16.41	74.89	8.46	15.07	11.23	1.16	68974.00
15	1.88	4.68	76.77	8.68	15.18	11.30	1.26	75158.00
16	2.51	11.04	68.71	8.44	15.02	11.08	1.02	69213.00
17	3.47	11.17	81.05	7.22	15.53	12.10	1.08	75114.00
18	6.50	5.48	82.46	9.12	15.67	11.54	0.79	88345.00
19	5.79	5.84	77.08	9.07	16.39	11.40	0.83	86503.00
20	5.07	10.73	74.89	9.24	16.67	11.30	0.87	84915.00
21	3.78	12.08	78.47	9.56	15.50	11.68	0.86	84483.00
22	8.54	15.42	79.58	9.81	15.14	11.68	0.82	87555.00
23	6.27	5.21	78.96	9.66	14.87	11.76	0.81	88019.00
24	5.62	8.90	79.79	9.39	14.85	11.71	0.82	88718.00
25	6.50	10.39	87.93	9.52	15.22	11.75	0.85	84362.00
26	4.72	6.97	75.23	9.19	16.29	11.40	0.89	86467.00
27	6.55	6.42	78.43	9.15	16.11	11.27	0.89	86518.00
28	6.65	5.53	85.91	9.43	15.26	11.65	0.84	87382.00
29	7.86	6.21	79.38	9.46	15.44	11.48	0.84	87029.00
30	6.59	13.79	81.09	9.71	15.59	11.45	0.83	86132.00
平均值	4.14	8.17	79.99	9.03	15.56	11.44	0.92	84016.67
最大值	8.54	16.41	90.60	9.81	16.67	12.10	1.26	91404.00
最小值	1.70	2.55	68.71	7.22	14.42	11.08	0.79	68974.00

P002_樹林焚化廠CEMS系統月報表

報表日期: 2020年04月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	2.64	15.18	74.95	5.08	15.02	11.79	0.52	75545.00
2	3.75	11.81	69.56	5.05	14.57	11.76	0.52	76472.00
3	2.37	21.24	71.70	5.09	15.23	11.63	0.51	76354.00
4	3.10	19.21	73.31	5.04	14.15	11.82	0.51	76241.00
5	2.20	15.37	69.05	4.86	15.21	11.66	0.55	76463.00
6	2.11	14.82	71.05	4.75	15.11	11.53	0.55	77388.00
7	1.96	10.59	73.07	5.11	15.22	11.59	0.52	76590.00
8	1.99	21.06	72.64	4.93	14.93	11.73	0.53	76306.00
9	1.98	15.76	74.80	4.93	14.69	11.78	0.55	76271.00
10	1.44	12.19	75.50	4.86	14.85	11.68	0.57	77086.00
11	1.67	17.20	74.57	5.04	14.49	11.88	0.54	76177.00
12	1.16	11.32	76.81	5.05	14.86	11.95	0.52	75660.00
13	1.27	11.04	72.93	5.00	13.56	11.93	0.49	77237.00
14	1.66	14.88	75.53	4.89	14.09	11.93	0.52	75676.00
15	1.38	8.13	72.94	4.89	13.79	11.92	0.51	75080.00
16	1.59	14.50	71.93	4.25	13.98	12.67	0.53	68657.00
17	1.73	10.60	78.37	4.95	13.76	12.02	0.53	75152.00
18	2.36	5.22	83.93	5.02	14.42	11.98	0.51	75030.00
19	1.80	6.51	72.00	4.82	15.78	11.68	0.54	75812.00
20	1.50	12.50	76.98	4.90	15.40	11.80	0.57	75297.00
21	1.34	9.89	75.83	4.93	14.96	11.93	0.54	74915.00
22	2.36	15.80	80.97	5.18	13.86	12.08	0.53	74727.00
23	1.79	10.83	76.21	5.23	14.30	11.94	0.50	76009.00
24	1.24	5.65	77.95	5.11	14.11	12.08	0.50	74894.00
25	1.57	6.10	80.02	5.06	14.31	12.07	0.72	73991.00
26	1.35	5.94	80.39	5.11	14.45	12.09	0.51	73699.00
27	1.70	7.67	82.87	5.07	14.46	12.03	0.51	74060.00
28	2.05	6.39	85.93	5.11	13.70	12.11	0.51	73864.00
29	3.15	6.29	84.64	4.93	14.09	11.83	0.51	74858.00
30	3.23	10.22	83.31	5.10	13.92	11.94	0.49	72817.00
平均值	1.98	11.80	76.32	4.98	14.51	11.89	0.53	75277.60
最大值	3.75	21.24	85.93	5.23	15.78	12.67	0.72	77388.00
最小值	1.16	5.22	69.05	4.25	13.56	11.53	0.49	68657.00

P003_樹林焚化廠CEMS系統月報表

報表日期: 2020年04月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	2.57	17.66	90.60	8.43	12.53	11.74	1.43	96589.00
2	2.52	10.67	81.47	8.74	11.91	12.03	1.46	94074.00
3	2.34	10.32	82.80	8.56	12.32	11.98	1.46	92739.00
4	2.51	12.75	84.58	8.23	11.82	11.82	1.43	95815.00
5	1.80	10.13	86.31	8.45	12.49	11.97	1.44	95130.00
6	1.68	9.03	79.72	8.17	12.85	11.79	1.44	96527.00
7	1.69	19.38	77.60	8.33	12.48	11.75	1.41	96714.00
8	1.75	15.16	81.78	8.30	12.89	11.82	1.41	96327.00
9	3.71	11.72	81.56	8.66	11.86	12.05	1.44	93923.00
10	3.06	17.19	82.98	8.68	12.11	11.97	1.48	94715.00
11	1.89	20.27	75.14	8.45	12.66	11.87	1.47	95014.00
12	1.40	9.42	79.69	8.70	12.69	12.14	1.43	94254.00
13	2.73	14.71	74.82	8.45	11.10	12.18	1.43	95353.00
14	2.22	13.40	74.89	8.40	11.61	12.15	1.47	93873.00
15	2.06	19.98	76.77	7.18	11.90	13.02	1.48	83491.00
16	2.02	21.54	68.71	8.23	12.42	11.80	1.46	95572.00
17	5.06	13.52	81.05	8.69	11.98	12.21	1.44	91017.00
18	2.79	14.92	82.46	8.88	12.25	12.27	1.45	89886.00
19	2.47	13.28	77.08	8.34	13.54	11.95	1.44	91455.00
20	2.02	10.33	74.89	8.70	12.95	12.11	1.44	91783.00
21	1.83	18.87	78.47	8.70	13.03	12.14	1.42	90995.00
22	2.16	13.25	79.58	9.26	11.66	12.50	1.37	90803.00
23	1.84	11.25	78.96	8.86	12.20	12.15	1.33	94112.00
24	1.82	6.65	79.79	9.11	11.76	12.38	1.33	92251.00
25	1.85	12.24	87.93	9.11	12.13	12.44	1.39	88924.00
26	1.69	14.78	75.23	8.34	13.57	11.90	1.38	92402.00
27	2.23	24.83	78.43	9.23	12.35	12.34	1.44	89613.00
28	3.22	15.62	85.91	9.01	12.23	12.15	1.45	91116.00
29	3.10	12.96	79.38	8.62	11.83	11.83	1.44	92990.00
30	3.19	19.02	81.09	9.03	12.42	12.00	1.42	91041.00
平均值	2.37	14.50	79.99	8.59	12.32	12.08	1.43	92949.93
最大值	5.06	24.83	90.60	9.26	13.57	13.02	1.48	96714.00
最小值	1.40	6.65	68.71	7.18	11.10	11.74	1.33	83491.00