

煙囪編號：P001

新北市樹林垃圾焚化廠CEMS煙囪監測系統月報表

資料日期：2018/8

文件編號：

煙囪編號：P001

測 項	氮化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量	溫度
日 / 單位	PPM	PPM	PPM	PPM	%	%	%	Nm <sup>3</sup> /Hr	℃
01	21.49	6.90	94.55	2.48	18.86	11.99	0.84	76839.39	138.26
02	21.18	6.70	91.84	2.36	18.74	11.76	0.83	82047.35	138.84
03	20.90	6.41	88.21	2.32	18.22	11.40	0.95	82944.96	141.09
04	22.97	6.60	90.89	2.74	18.34	11.65	1.26	74204.52	140.28
05	23.49	6.31	86.68	2.21	17.66	11.33	1.65	72015.15	139.95
06	10.00	6.44	91.53	2.17	18.08	11.47	1.21	66274.65	140.59
07	10.08	6.57	103.95	2.17	18.26	11.62	0.96	83246.35	140.01
08	24.59	12.52	94.02	3.02	20.05	11.54	0.92	66937.28	138.67
09	14.39	9.14	96.55	2.63	19.22	11.56	1.19	62869.92	138.52
10	16.89	12.95	84.95	2.29	16.98	12.12	1.09	66050.81	139.91
11	19.71	15.02	90.51	2.74	20.57	13.30	1.29	67622.83	139.41
12	16.67	12.42	73.73	2.30	15.93	12.21	1.39	72366.53	139.69
13	16.37	12.77	76.30	2.55	16.95	12.34	1.29	71187.15	139.87
14	14.86	12.02	72.76	2.22	19.55	11.60	1.59	66841.27	140.29
15	15.54	12.20	73.35	2.63	21.07	11.53	1.85	62793.34	139.61
16	16.36	12.72	96.42	2.69	17.34	12.31	1.97	77217.31	139.53
17	15.75	12.39	84.21	2.37	18.84	11.85	1.36	72968.74	140.04
18	16.66	12.69	72.16	2.50	24.21	11.60	1.75	68227.80	138.94
19	16.30	12.48	71.09	2.33	23.05	11.55	1.87	63773.57	139.22
20	15.52	11.90	80.59	2.22	21.67	11.21	1.76	69866.61	138.86
21	15.70	12.09	85.47	2.25	20.96	11.36	1.79	77071.19	139.62
22	12.11	11.43	83.78	2.55	19.63	10.98	1.80	68404.38	139.69
23	9.95	12.11	88.92	2.34	21.08	11.46	1.78	65874.16	139.31
24	13.83	12.21	87.28	2.31	22.14	11.40	2.13	73963.49	139.07
25	16.09	14.12	75.35	2.80	22.47	12.43	2.38	69598.79	143.29
26	15.13	13.13	87.21	2.72	20.22	12.24	2.03	67730.48	144.59
27	11.38	13.59	87.69	2.70	19.21	12.59	2.17	56116.41	144.29
28	11.63	17.16	88.95	2.71	18.37	13.09	1.62	59678.44	145.83
29	11.48	16.22	83.33	2.66	17.41	12.73	1.78	61949.26	145.49
30	12.89	17.04	87.78	2.83	16.19	13.22	2.24	64875.51	145.01
31	15.86	16.10	83.85	2.55	17.93	12.24	1.72	73594.65	146.62
平均值	16.10	11.51	85.74	2.48	19.33	11.93	1.56	69843.62	140.79
最大值	24.59	17.16	103.95	3.02	24.21	13.30	2.38	83246.35	146.62
最小值	9.95	6.31	71.09	2.17	15.93	10.98	0.83	56116.41	138.26
排放標準	< 53.3	< 100.0	< 166.7	< 53.3			< 10		
月排放量	1354.49	727.58	9059.28	363.08	0.00	0.00	0.00	0.00	0.00

煙函編號：P002

資料日期：2018/8

新北市樹林垃圾焚化廠CEMS煙函監測系統月報表

文件編號：

煙函編號：P002

測 項	氮化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量	溫度
日 / 單位	PPM	PPM	PPM	PPM	%	%	%	Nm3/Hr	℃
01	15.07	5.98	79.77	5.28	18.73	12.11	1.08	70444.28	135.23
02	15.26	5.88	90.28	5.32	18.74	12.00	1.12	71170.02	135.14
03	21.33	6.01	91.06	5.40	18.69	12.13	1.12	70565.37	133.32
04	22.95	5.95	94.60	5.31	18.69	12.07	1.13	71457.95	131.18
05	22.51	5.84	92.79	5.25	18.70	11.90	1.15	72697.32	131.92
06	14.05	6.24	88.17	5.50	18.72	12.32	1.16	67062.12	133.68
07	19.41	5.92	85.74	5.28	18.67	12.01	1.05	65302.60	134.14
08	29.65	11.95	98.06	5.66	19.35	11.90	1.06	65690.86	133.38
09	26.29	15.48	94.53	8.13	19.38	12.00	1.08	64816.01	133.43
10	24.42	7.37	74.61	8.20	19.37	12.01	1.11	66222.64	133.52
11	19.96	7.37	79.79	8.12	19.39	12.02	1.11	70778.29	133.89
12	17.81	7.52	80.26	8.35	19.40	12.03	1.13	70622.10	134.38
13	停爐	停爐	停爐	停爐	停爐	停爐	停爐	停爐	停爐
14	5.05	10.06	83.43	5.04	19.45	12.31	1.29	68205.53	135.36
15	10.16	13.55	83.00	5.09	19.67	12.32	1.18	67790.86	135.23
16	10.57	13.97	86.31	5.21	20.17	12.61	0.91	65294.07	135.30
17	10.47	13.84	85.43	5.15	19.92	12.52	0.92	66014.85	135.68
18	10.71	14.16	87.39	5.27	20.43	12.69	0.92	64377.62	135.77
19	10.50	13.87	85.75	5.14	20.36	12.50	0.92	65807.11	135.96
20	10.27	13.58	83.85	5.10	20.36	12.31	0.93	67560.60	135.04
21	11.21	13.73	85.50	5.15	20.53	12.38	0.95	66695.51	135.28
22	16.35	13.77	84.97	5.58	20.72	12.41	0.93	66349.77	135.50
23	16.05	13.52	83.34	5.47	20.34	12.28	0.93	67627.54	135.52
24	16.17	13.61	84.03	5.51	20.70	12.31	0.94	67238.19	134.71
25	16.56	13.96	86.07	5.65	20.87	12.51	0.95	65393.34	136.23
26	17.29	14.35	89.22	5.63	20.82	12.29	0.99	67684.13	136.55
27	17.86	13.85	91.98	5.03	19.48	12.53	1.20	60578.83	136.22
28	7.72	2.82	78.82	3.84	18.69	13.27	1.42	55826.25	135.08
29	7.75	2.81	82.77	4.12	18.80	13.31	1.93	55726.65	134.08
30	8.79	3.22	85.72	4.72	18.47	14.32	2.18	65688.11	132.52
31	13.36	3.09	70.91	4.51	18.37	14.01	2.38	78271.45	132.05
平均值	16.00	9.98	85.79	5.58	19.53	12.45	1.17	66965.33	134.51
最大值	29.65	15.48	98.06	8.35	20.87	14.32	2.38	78271.45	136.55
最小值	5.05	2.81	70.91	3.84	18.37	11.90	0.91	55726.65	131.18
排放標準	< 53.3	< 100.0	< 166.7	< 53.3					
月排放量	1215.36	574.53	8139.88	741.16	0.00	0.00	0.00	0.00	0.00

煙囪編號：P003  
資料日期：2018/8

新北市樹林垃圾焚化廠C E M S 煙囪監測系統月報表

文件編號：

煙囪編號：P003

測 項	氮化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量	溫度
日 / 單位	PPM	PPM	PPM	PPM	%	%	%	Nm3/Hr	℃
01	19.71	7.54	97.44	5.64	20.86	13.26	2.83	64149.86	131.39
02	21.54	7.31	92.76	5.45	20.92	12.97	2.85	65827.87	136.21
03	18.62	6.31	79.05	4.70	20.80	11.87	2.91	75161.91	134.61
04	19.11	6.28	83.25	4.75	20.76	12.04	2.95	73689.34	135.56
05	18.69	6.33	81.45	4.66	20.79	11.85	2.29	75304.87	134.88
06	17.35	6.09	83.67	4.45	20.70	11.82	1.13	75380.78	133.09
07	20.42	5.71	87.78	4.21	18.21	11.39	1.16	74457.98	133.43
08	17.56	9.56	76.51	4.51	17.70	11.18	1.17	75967.82	136.43
09	22.82	9.47	101.63	7.43	17.71	11.40	1.17	75159.92	131.47
10	22.44	8.96	82.23	7.32	17.70	11.24	1.18	57762.66	129.17
11	15.79	10.93	87.53	7.31	17.83	11.32	1.21	66459.20	136.01
12	16.49	11.08	85.12	7.14	17.85	10.98	1.21	67816.84	138.88
13	15.27	13.30	80.29	5.07	17.81	11.63	1.22	69344.52	134.58
14	16.76	15.33	81.75	3.19	17.84	12.20	1.23	62930.78	136.24
15	17.10	15.37	83.08	3.32	17.78	12.35	1.23	62498.44	135.64
16	17.16	15.62	84.06	3.30	17.83	12.44	1.25	65766.75	138.61
17	17.36	15.95	85.19	3.48	17.84	12.50	1.26	65739.25	135.42
18	16.58	15.47	82.26	3.53	17.81	12.36	1.27	67052.94	134.65
19	16.52	13.54	80.02	7.53	17.83	12.11	1.28	67654.41	141.31
20	17.02	14.80	83.54	8.20	17.83	12.85	1.29	64929.12	138.18
21	18.63	17.00	76.05	9.02	17.94	13.66	1.30	54413.12	140.84
22	15.72	10.72	80.82	7.44	17.96	12.30	1.31	75258.07	137.17
23	15.23	15.91	81.15	7.42	17.87	12.16	1.32	76347.65	138.27
24	15.63	16.04	83.39	7.59	17.90	12.33	1.33	74621.10	139.25
25	15.52	15.58	83.06	7.71	17.93	12.34	1.34	74418.93	140.05
26	15.36	16.47	82.26	7.53	17.61	12.23	1.26	72996.12	143.72
27	10.03	10.75	77.91	7.13	15.79	11.85	1.09	68948.70	142.31
28	停爐	停爐	停爐	停爐	停爐	停爐	停爐	停爐	停爐
29	停爐	停爐	停爐	停爐	停爐	停爐	停爐	停爐	停爐
30	11.65	6.75	102.80	7.77	18.85	13.87	1.75	58282.10	126.83
31	14.27	8.29	82.46	6.21	18.81	12.22	0.91	76186.88	131.48
平均值	17.33	11.50	84.32	5.89	18.45	12.16	1.51	69121.65	136.06
最大值	22.82	17.00	102.80	9.02	20.92	13.87	2.95	76347.65	143.72
最小值	10.03	5.71	76.05	3.19	15.79	10.98	0.91	54413.12	126.83
排放標準	< 53.3	< 100.0	< 166.7	< 53.3			< 10		
月排放量	1314.86	663.96	8058.53	784.06	0.00	0.00	0.00	0.00	0.00