

P001\_樹林焚化廠CEMS系統月報表

報表日期: 2023年9月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	5.73	7.47	56.28	1.37	17.87	11.53	1.01	77868.00
2	5.83	7.66	57.05	1.39	17.64	11.75	1.01	76313.00
3	4.85	9.24	56.00	1.45	17.94	11.64	1.06	78469.00
4	4.08	8.95	56.71	1.55	17.47	11.80	1.05	76351.00
5	7.20	10.04	55.92	1.98	18.31	11.40	1.03	77740.00
6	7.12	9.54	53.64	2.08	17.99	11.47	1.03	77692.00
7	4.88	7.65	56.01	1.78	17.39	11.66	1.05	76859.00
8	6.42	8.91	55.19	1.85	18.20	11.44	1.04	78538.00
9	8.52	9.39	53.74	1.90	17.92	11.42	1.01	77430.00
10	7.57	8.73	51.20	1.72	18.42	11.33	1.00	78889.00
11	6.03	7.02	51.29	1.53	17.51	11.57	1.04	76941.00
12	6.04	8.43	48.48	1.45	18.53	11.38	1.05	76713.00
13	6.82	8.69	48.15	1.37	17.91	11.49	1.03	76183.00
14	5.46	9.20	51.70	1.82	17.62	11.43	1.04	76567.00
15	7.30	8.62	53.93	2.46	17.20	11.69	1.06	76476.00
16	6.36	7.22	53.13	1.85	17.29	11.61	1.06	77167.00
17	6.19	8.18	52.05	1.76	17.85	11.47	1.07	70988.00
18	5.71	8.31	48.48	2.42	17.24	11.45	1.05	70543.00
19	5.19	8.49	57.54	2.14	16.96	11.60	1.06	72156.00
20	7.84	8.15	53.29	2.22	17.32	11.57	1.02	72446.00
21	7.51	9.57	50.04	2.05	16.69	11.63	1.02	71747.00
22	7.33	9.00	54.25	1.76	17.01	11.79	1.03	71461.00
23	7.91	8.69	53.33	1.88	16.69	11.90	1.02	71384.00
24	6.31	9.39	56.39	1.63	16.86	11.77	1.01	71466.00
25	4.78	7.42	54.87	1.43	17.08	11.69	1.01	72026.00
26	4.45	7.53	54.49	1.06	17.64	11.59	1.01	72174.00
27	5.35	7.73	48.46	1.33	17.07	11.68	1.01	72518.00
28	6.46	8.43	48.25	0.97	18.13	11.47	1.03	73081.00
29	5.56	9.52	48.43	1.18	18.16	11.45	1.02	73349.00
30	4.48	7.41	44.13	1.16	18.70	11.36	1.01	73675.00
平均值	6.18	8.49	52.75	1.68	17.62	11.57	1.03	74840.33
最大值	8.52	10.04	57.54	2.46	18.70	11.90	1.07	78889.00
最小值	4.08	7.02	44.13	0.97	16.69	11.33	1.00	70543.00

備註： 1.\*:儀器保養維護中。

2.\*\*:停爐中。

P002\_樹林焚化廠CEMS系統月報表

報表日期: 2023年9月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	5.02	5.35	54.26	1.96	17.15	10.49	0.99	83951.00
2	3.24	6.27	55.78	1.87	17.35	10.55	1.01	83588.00
3	1.84	6.06	57.45	1.65	17.23	10.56	1.01	82651.00
4	2.15	6.98	52.53	1.64	17.45	10.41	1.02	83456.00
5	6.42	7.27	50.83	1.89	18.16	10.32	1.02	84609.00
6	4.65	5.71	50.48	1.83	18.02	10.27	0.99	85100.00
7	5.38	5.43	53.84	1.49	18.37	10.30	0.99	84652.00
8	4.48	3.93	49.89	2.35	18.08	10.35	0.97	85205.00
9	6.90	5.27	52.03	2.49	17.07	10.49	0.97	84906.00
10	4.88	5.30	51.14	2.00	18.05	10.31	0.97	85570.00
11	4.11	5.29	44.64	1.72	18.26	10.24	0.99	84978.00
12	3.36	5.16	48.69	2.09	18.27	10.28	1.00	84518.00
13	5.43	4.94	53.17	2.49	16.76	10.60	0.99	83938.00
14	4.24	6.25	49.59	1.88	17.91	10.37	0.99	84784.00
15	6.14	6.11	48.04	2.40	18.68	10.26	1.00	84933.00
16	4.39	5.24	50.69	2.37	17.87	10.40	1.00	84638.00
17	3.65	5.43	51.00	2.33	18.18	10.20	0.97	85694.00
18	2.90	5.61	51.55	2.58	15.84	11.17	0.96	78778.00
19	3.86	5.32	53.19	1.70	17.23	10.54	0.97	84734.00
20	6.85	5.74	50.29	1.86	17.70	10.28	1.00	85166.00
21	5.84	5.86	52.11	2.15	15.74	10.95	1.02	81068.00
22	4.95	6.51	51.34	1.70	17.84	10.70	1.02	82241.00
23	7.56	6.12	50.22	2.16	17.79	10.22	1.01	86485.00
24	5.54	5.01	52.32	2.07	17.54	10.44	1.01	84365.00
25	6.17	5.52	52.63	1.96	16.95	10.49	1.00	84624.00
26	3.80	5.90	46.85	1.86	17.77	10.30	1.01	85449.00
27	5.83	6.15	51.08	1.74	17.28	10.30	1.01	85914.00
28	6.16	6.32	51.67	1.58	16.85	10.42	1.01	84913.00
29	6.95	6.19	47.88	1.59	18.37	10.12	1.01	86718.00
30	5.28	6.81	48.19	1.38	18.30	10.20	0.99	85710.00
平均值	4.93	5.77	51.11	1.96	17.60	10.42	1.00	84444.53
最大值	7.56	7.27	57.45	2.58	18.68	11.17	1.02	86718.00
最小值	1.84	3.93	44.64	1.38	15.74	10.12	0.96	78778.00

備註： 1.\*:儀器保養維護中。

2.\*\*:停爐中。

P003\_樹林焚化廠CEMS系統月報表

報表日期: 2023年9月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	4.05	7.32	52.28	1.76	16.15	10.75	0.97	77746.00
2	3.85	7.30	53.87	1.78	16.02	10.95	0.99	76689.00
3	2.60	8.13	55.40	1.56	16.44	10.87	0.99	77546.00
4	3.94	7.12	49.19	1.40	16.45	10.71	0.99	76815.00
5	3.54	6.81	52.89	1.50	16.68	10.83	1.00	79468.00
6	7.39	6.77	53.23	2.10	16.00	10.78	0.98	77223.00
7	5.04	6.42	56.78	1.70	16.11	10.63	1.00	78169.00
8	5.20	5.39	51.30	1.57	16.22	10.97	1.02	78210.00
9	5.16	7.48	49.85	1.86	15.38	11.08	1.03	76249.00
10	5.50	6.26	47.34	1.45	16.34	10.84	1.04	78293.00
11	6.61	6.96	45.50	2.09	15.89	10.37	1.01	75619.00
12	5.96	6.75	47.86	1.79	15.63	11.01	1.01	77321.00
13	7.19	6.31	42.47	1.62	16.16	10.66	1.01	77588.00
14	7.02	5.09	50.25	1.64	16.01	10.49	1.04	77339.00
15	6.30	6.18	44.16	2.20	15.89	10.71	1.04	74830.00
16	5.83	6.35	42.35	1.50	16.88	10.60	1.04	78495.00
17	3.83	6.17	47.74	1.51	16.31	10.78	1.03	78275.00
18	4.32	7.39	51.79	2.58	15.85	10.53	1.00	77986.00
19	3.80	6.70	48.60	1.86	15.86	10.45	1.01	76966.00
20	6.88	7.41	51.42	1.87	15.90	10.77	1.02	78234.00
21	7.07	6.05	51.38	2.00	15.45	10.55	1.00	77320.00
22	7.46	7.07	52.19	1.93	15.43	10.94	0.98	76747.00
23	8.70	6.23	45.30	2.70	14.69	10.93	0.98	78303.00
24	4.79	5.85	52.10	2.07	15.13	10.89	0.98	77639.00
25	4.24	6.16	51.71	1.87	15.29	10.74	0.96	77465.00
26	3.91	6.65	48.16	1.41	15.78	10.58	0.94	78105.00
27	5.10	5.73	41.55	1.22	16.90	10.28	0.94	78547.00
28	5.85	6.04	51.01	1.61	15.61	10.53	0.94	76951.00
29	5.77	6.33	40.84	1.05	17.69	10.21	0.94	79975.00
30	4.74	5.71	45.35	1.32	16.44	10.74	0.96	78226.00
平均值	5.39	6.54	49.13	1.75	16.02	10.71	0.99	77611.30
最大值	8.70	8.13	56.78	2.70	17.69	11.08	1.04	79975.00
最小值	2.60	5.09	40.84	1.05	14.69	10.21	0.94	74830.00

備註： 1.\*:儀器保養維護中。

2.\*\*:停爐中。