

P001_樹林焚化廠CEMS系統月報表

報表日期: 2023年7月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	8.82	15.38	44.34	2.55	18.90	10.68	1.03	70228.00
2	8.81	17.44	51.68	2.09	19.84	10.87	1.04	70670.00
3	8.76	16.83	43.03	2.42	18.51	10.89	1.07	69974.00
4	7.85	16.22	50.15	2.16	17.76	11.18	1.08	69489.00
5	9.36	16.89	49.09	1.91	19.47	10.65	1.09	72735.00
6	5.44	16.26	49.21	1.90	18.87	10.67	1.10	70120.00
7	7.86	17.01	51.94	2.31	18.23	10.93	1.06	72083.00
8	7.41	16.34	52.86	2.47	18.01	11.11	1.05	70678.00
9	8.44	14.37	54.41	2.01	19.56	10.68	1.01	72324.00
10	7.85	14.59	52.20	1.95	18.93	10.76	1.00	73057.00
11	4.94	13.67	55.32	1.73	17.59	11.23	1.01	70758.00
12	7.09	12.53	54.60	0.89	17.70	11.14	1.03	73484.00
13	6.58	10.13	52.93	0.77	17.86	11.10	1.00	83290.00
14	7.42	8.03	55.90	0.53	18.28	11.07	0.99	82680.00
15	7.42	9.70	53.25	0.65	17.17	11.34	0.98	80916.00
16	6.91	9.28	51.36	0.51	18.04	11.12	0.99	81453.00
17	6.82	8.41	52.56	0.56	17.67	11.47	0.98	81716.00
18	6.74	9.62	53.68	1.23	17.17	11.41	1.01	80616.00
19	8.69	8.29	52.61	0.92	17.29	11.28	1.04	81041.00
20	8.14	9.67	55.63	1.36	18.21	11.12	1.08	82641.00
21	8.90	10.67	57.71	2.14	18.16	11.32	1.07	80847.00
22	9.41	10.83	55.22	1.82	17.99	11.39	1.04	80255.00
23	9.77	13.05	54.08	2.02	17.76	11.40	1.04	80746.00
24	8.17	10.75	51.52	1.50	18.03	11.34	1.06	80370.00
25	7.58	11.01	54.03	1.76	16.94	11.75	1.08	78191.00
26	8.43	12.28	53.34	2.34	16.43	11.73	1.07	79354.00
27	8.73	10.68	53.36	2.17	17.00	11.70	1.06	78974.00
28	7.87	12.28	52.08	1.76	17.86	11.57	1.04	77507.00
29	8.69	9.93	52.41	1.88	16.96	11.69	1.04	78128.00
30	7.10	9.73	55.94	1.82	16.82	11.80	1.04	77426.00
31	6.75	10.21	55.86	1.64	16.78	11.86	1.05	77241.00
平均值	7.83	12.33	52.65	1.67	17.93	11.23	1.04	76741.68
最大值	9.77	17.44	57.71	2.55	19.84	11.86	1.10	83290.00
最小值	4.94	8.03	43.03	0.51	16.43	10.65	0.98	69489.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P002_樹林焚化廠CEMS系統月報表

報表日期: 2023年7月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	8.16	14.81	60.27	1.80	18.07	9.79	1.10	78385.00
2	6.66	15.52	62.47	1.26	18.78	10.21	1.15	78838.00
3	5.27	16.30	58.52	1.26	18.59	10.01	1.18	78067.00
4	4.63	16.36	57.49	1.43	17.78	9.80	1.20	78080.00
5	5.87	15.97	54.76	1.40	18.07	9.60	1.19	77737.00
6	3.61	14.81	58.17	1.12	17.85	10.04	1.16	78876.00
7	5.90	14.40	58.51	1.39	18.24	9.78	1.15	79256.00
8	7.15	13.51	55.20	1.86	17.93	9.79	1.17	78151.00
9	5.96	13.84	54.50	1.19	19.59	9.65	1.15	78628.00
10	4.05	13.29	55.06	1.22	18.35	10.05	1.14	76623.00
11	2.43	10.97	58.62	0.97	17.44	10.16	1.15	76182.00
12	5.49	7.40	51.79	0.92	17.45	9.73	1.16	79837.00
13	7.23	7.27	52.26	0.78	17.53	9.63	1.12	78372.00
14	4.71	5.62	53.96	0.72	17.92	9.99	1.11	78368.00
15	7.04	8.36	51.54	0.75	17.83	9.67	1.08	79816.00
16	6.13	6.77	47.08	0.73	18.05	9.75	1.09	80168.00
17	6.05	9.99	49.32	0.69	17.84	9.71	1.11	77431.00
18	7.03	7.14	48.04	0.74	18.01	9.90	1.12	81622.00
19	8.97	6.14	47.69	0.60	18.49	9.83	1.15	82651.00
20	6.38	7.35	51.66	1.13	18.32	9.94	1.19	82514.00
21	7.56	7.57	50.46	1.99	19.30	9.87	1.21	84453.00
22	8.60	7.31	52.55	2.17	18.09	10.16	1.21	81651.00
23	8.30	9.54	54.08	2.38	17.62	10.17	1.24	81717.00
24	7.53	7.23	53.68	1.90	17.40	10.12	1.22	81296.00
25	6.65	8.42	51.91	1.85	18.09	9.80	1.19	80994.00
26	8.36	8.75	51.24	1.79	17.91	9.71	1.19	81024.00
27	8.41	8.24	52.83	1.75	18.23	9.90	1.23	83644.00
28	8.03	7.87	52.85	2.37	17.67	10.03	1.20	81903.00
29	8.96	8.49	53.57	1.99	17.45	9.78	1.18	80854.00
30	6.65	9.48	53.50	1.93	17.94	10.33	1.19	80277.00
31	8.34	8.28	54.35	1.60	18.46	9.93	1.16	83809.00
平均值	6.65	10.23	53.80	1.41	18.07	9.90	1.16	80039.48
最大值	8.97	16.36	62.47	2.38	19.59	10.33	1.24	84453.00
最小值	2.43	5.62	47.08	0.60	17.40	9.60	1.08	76182.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P003_樹林焚化廠CEMS系統月報表

報表日期: 2023年7月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	7.73	13.50	60.96	3.63	16.91	10.39	1.03	79498.00
2	9.16	16.80	62.51	2.84	18.17	10.48	1.04	82483.00
3	8.83	17.04	59.82	3.04	16.51	10.59	1.05	78761.00
4	5.72	17.11	58.02	2.61	16.30	10.45	1.05	77924.00
5	9.40	16.20	62.30	2.97	15.69	10.86	1.08	79838.00
6	5.61	15.26	59.95	2.43	15.71	11.11	1.08	78613.00
7	5.03	16.23	59.08	2.69	16.50	10.54	1.07	79281.00
8	6.12	14.45	58.22	2.91	16.20	10.67	1.04	79180.00
9	4.79	13.34	57.97	2.37	17.46	10.25	1.03	79324.00
10	5.49	14.34	59.41	2.27	16.99	10.33	1.02	80186.00
11	2.43	12.20	55.48	2.25	16.33	10.87	1.02	78897.00
12	4.54	8.81	50.48	2.18	15.97	10.79	1.05	79022.00
13	5.50	8.20	49.25	2.20	15.31	10.66	1.02	75955.00
14	6.67	8.05	54.05	1.95	16.02	11.02	1.01	80312.00
15	4.56	8.00	50.42	1.79	15.94	10.93	0.98	78312.00
16	5.69	8.69	51.47	1.85	16.10	10.93	0.96	79897.00
17	4.51	7.97	49.87	1.59	15.98	10.75	0.96	77125.00
18	3.46	8.86	54.57	1.94	16.11	10.88	0.97	79165.00
19	3.56	6.74	53.16	2.18	15.83	10.96	0.96	79575.00
20	2.23	8.17	54.25	2.16	16.11	10.64	0.99	78437.00
21	1.89	9.07	54.34	1.79	16.59	10.80	1.01	78792.00
22	4.74	10.61	53.73	1.69	16.55	10.73	1.01	78625.00
23	3.87	12.81	56.04	1.60	16.22	10.98	1.02	78159.00
24	2.42	8.05	51.89	1.07	16.63	10.48	1.01	77796.00
25	3.07	10.29	50.09	1.27	16.12	10.72	1.01	76727.00
26	5.66	9.76	50.52	1.41	16.35	10.75	0.99	78249.00
27	5.92	8.85	58.13	1.67	15.84	10.80	0.98	79119.00
28	5.31	10.43	54.05	1.43	16.41	10.73	1.00	78587.00
29	6.51	9.59	55.77	1.76	15.04	11.08	1.00	75375.00
30	3.24	10.44	55.66	0.99	16.45	10.83	1.00	76499.00
31	1.93	8.97	57.12	1.07	16.43	10.80	1.01	83878.00
平均值	5.02	11.25	55.44	2.05	16.28	10.74	1.01	78825.52
最大值	9.40	17.11	62.51	3.63	18.17	11.11	1.08	83878.00
最小值	1.89	6.74	49.25	0.99	15.04	10.25	0.96	75375.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。