

P001_樹林焚化廠CEMS系統月報表

報表日期: 2022年07月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	13.22	6.23	52.22	0.87	17.68	11.53	1.51	82293.00
2	11.55	6.77	48.83	0.66	16.78	11.85	1.52	78553.00
3	12.64	6.64	50.91	0.67	17.73	11.82	1.51	65400.00
4	12.60	6.13	50.45	0.91	18.10	11.26	1.56	73256.00
5	13.81	4.91	55.25	0.96	17.45	11.53	1.63	83617.00
6	13.01	5.16	46.71	0.96	18.13	11.65	1.73	81600.00
7	13.50	7.21	56.66	1.04	18.38	11.42	1.70	82578.00
8	13.89	6.76	57.15	1.10	17.97	11.51	1.69	82547.00
9	12.92	7.99	56.50	0.59	18.17	11.67	1.62	81531.00
10	12.84	5.94	59.83	0.34	18.58	11.66	1.63	81233.00
11	9.98	5.69	56.31	1.31	19.07	11.56	1.61	82256.00
12	13.28	4.63	55.51	1.89	18.48	11.51	1.61	81879.00
13	13.08	5.85	53.45	1.35	18.77	11.37	1.58	83309.00
14	11.71	6.97	54.10	0.87	17.43	11.70	1.53	81449.00
15	12.37	6.12	51.61	0.86	17.86	11.59	1.56	82945.00
16	12.66	6.20	53.44	0.67	17.29	11.76	1.57	81332.00
17	11.95	6.19	54.41	0.49	18.58	11.43	1.54	83069.00
18	13.34	5.47	46.91	0.30	19.98	10.62	1.58	88722.00
19	12.76	7.63	48.12	0.49	18.53	11.41	1.58	81765.00
20	12.11	4.37	53.04	0.25	18.88	11.48	1.58	82747.00
21	11.59	6.13	51.95	0.37	17.99	11.54	1.57	81128.00
22	12.42	5.67	53.08	0.36	18.66	11.37	1.55	82526.00
23	10.42	6.56	52.77	0.34	18.93	11.36	1.53	82433.00
24	12.82	4.95	52.77	0.28	19.76	11.07	1.51	84230.00
25	12.14	4.88	58.83	1.09	18.88	11.14	1.52	84106.00
26	11.43	5.33	56.47	1.00	19.09	11.14	1.56	84422.00
27	12.14	4.16	48.68	0.54	18.93	11.11	1.56	84312.00
28	13.82	5.10	47.33	0.46	19.20	11.05	1.57	84161.00
29	13.60	6.86	48.42	0.23	18.91	11.40	1.58	82664.00
30	13.90	6.79	46.21	0.17	19.10	11.36	1.62	82022.00
31	13.71	6.30	42.18	0.34	19.17	11.05	1.63	83950.00
平均值	12.62	5.99	52.26	0.70	18.47	11.42	1.58	81872.10
最大值	13.90	7.99	59.83	1.89	19.98	11.85	1.73	88722.00
最小值	9.98	4.16	42.18	0.17	16.78	10.62	1.51	65400.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P002_樹林焚化廠CEMS系統月報表

報表日期: 2022年07月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	12.94	5.46	53.39	0.35	17.53	10.60	1.42	84239.00
2	12.93	3.91	58.03	0.36	16.98	10.94	1.41	85008.00
3	12.73	4.58	56.65	0.27	17.88	10.85	1.43	86651.00
4	13.81	8.39	51.79	0.16	17.81	10.52	1.52	93540.00
5	13.29	8.73	49.55	0.80	18.28	10.45	1.43	86926.00
6	12.78	6.07	54.34	0.17	18.97	10.49	1.46	86413.00
7	13.49	5.73	55.34	0.24	18.50	10.55	1.44	84415.00
8	13.40	4.88	60.27	0.44	17.64	10.65	1.42	83105.00
9	12.63	5.48	60.12	0.40	17.74	10.93	1.42	82896.00
10	12.19	6.55	54.58	0.23	18.66	10.45	1.43	84374.00
11	10.09	4.55	56.81	0.32	18.56	10.45	1.42	84151.00
12	12.28	4.14	58.24	0.41	18.35	10.59	1.41	85617.00
13	11.61	7.29	56.19	0.66	17.91	10.60	1.42	84654.00
14	11.85	4.71	54.91	0.49	17.24	10.95	1.46	81522.00
15	12.53	7.15	52.63	0.50	18.38	10.64	1.45	84206.00
16	11.70	4.31	54.60	0.47	18.05	10.97	1.47	83911.00
17	11.35	6.35	49.60	0.29	22.13	10.74	1.52	81439.00
18	**	**	**	**	**	**	**	**
19	9.88	10.03	59.13	0.72	15.85	11.68	1.43	58522.00
20	11.33	3.95	53.51	0.22	17.82	10.94	1.44	60529.00
21	12.68	5.60	57.12	0.36	17.38	10.91	1.48	61735.00
22	13.39	3.64	58.92	0.20	17.20	11.02	1.49	61445.00
23	12.33	4.43	58.98	0.26	17.08	10.96	1.48	61928.00
24	12.31	3.69	58.56	0.21	17.31	11.08	1.46	59768.00
25	12.36	4.19	61.09	0.29	16.91	11.32	1.44	58931.00
26	12.10	5.22	59.83	0.31	17.21	11.50	1.45	59637.00
27	13.45	3.14	58.26	0.28	17.56	11.08	1.45	61888.00
28	14.40	4.89	59.18	0.21	17.52	11.20	1.44	60217.00
29	13.88	3.33	54.52	0.29	17.55	11.02	1.47	60693.00
30	14.14	4.00	54.99	0.29	17.69	10.83	1.48	60294.00
31	14.20	5.04	50.87	0.25	18.14	10.72	1.50	60587.00
平均值	12.60	5.31	56.07	0.35	17.86	10.85	1.45	74308.03
最大值	14.40	10.03	61.09	0.80	22.13	11.68	1.52	93540.00
最小值	9.88	3.14	49.55	0.16	15.85	10.45	1.41	58522.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P003_樹林焚化廠CEMS系統月報表

報表日期: 2022年07月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	13.48	6.47	54.86	1.94	16.99	10.16	1.43	73678.00
2	13.24	4.41	54.00	1.89	16.37	10.13	1.42	73030.00
3	13.42	3.85	55.13	1.97	17.09	10.19	1.42	73652.00
4	13.35	7.22	44.85	1.21	17.43	9.55	1.41	71944.00
5	13.77	6.26	43.74	2.92	17.06	9.54	1.41	68572.00
6	13.52	8.54	43.54	2.48	17.90	9.65	1.51	74803.00
7	11.80	5.95	56.69	2.66	17.31	9.95	1.57	72379.00
8	13.89	6.33	48.83	2.49	17.19	10.01	1.62	73496.00
9	13.64	6.79	52.87	1.98	17.24	10.31	1.59	72883.00
10	13.18	8.08	50.04	1.67	17.67	10.04	1.57	74921.00
11	14.17	6.41	55.89	2.88	17.25	10.17	1.55	72037.00
12	12.42	5.69	57.25	3.17	16.94	10.13	1.57	74517.00
13	12.88	4.53	57.14	2.62	17.43	9.90	1.58	75519.00
14	12.85	5.66	50.86	1.97	16.15	10.17	1.59	71793.00
15	13.43	6.30	50.77	1.52	16.49	10.34	1.59	72235.00
16	13.14	7.17	52.86	1.48	16.34	10.32	1.61	71666.00
17	13.17	5.65	52.92	1.51	17.75	9.93	1.58	75190.00
18	12.09	7.32	55.50	1.63	16.48	10.56	1.57	74222.00
19	13.09	6.39	53.84	2.01	17.04	10.40	1.54	72202.00
20	10.61	6.57	51.87	1.78	17.78	10.44	1.53	75104.00
21	11.53	5.73	58.67	2.01	16.45	10.50	1.52	73016.00
22	13.45	7.17	51.40	1.95	17.29	9.99	1.52	73512.00
23	12.59	5.50	55.81	2.44	16.63	10.18	1.52	72326.00
24	13.22	5.42	56.69	2.17	16.85	10.30	1.51	72943.00
25	14.23	4.04	54.28	2.15	16.78	10.18	1.50	72766.00
26	13.14	7.57	50.54	2.07	17.25	10.13	1.48	74224.00
27	13.07	5.35	53.81	2.07	17.04	10.21	1.48	73549.00
28	13.43	5.03	55.72	1.72	16.70	10.33	1.48	72271.00
29	12.34	4.41	54.92	1.35	16.91	10.26	1.47	71378.00
30	12.57	4.04	54.23	1.15	16.81	10.38	1.49	70550.00
31	13.17	5.19	54.78	1.08	18.46	10.00	1.50	73678.00
平均值	13.03	5.97	53.04	2.00	17.07	10.14	1.52	73034.06
最大值	14.23	8.54	58.67	3.17	18.46	10.56	1.62	75519.00
最小值	10.61	3.85	43.54	1.08	16.15	9.54	1.41	68572.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。