

P001_樹林焚化廠CEMS系統月報表

報表日期: 2026年2月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	10.34	12.45	49.65	2.70	15.66	11.62	1.06	80495.00
2	10.33	12.37	52.56	2.61	15.41	11.76	1.08	79456.00
3	9.86	12.18	50.20	2.01	15.64	11.58	1.11	80780.00
4	10.26	12.75	46.17	1.99	15.53	11.67	1.16	79884.00
5	9.34	13.13	46.51	2.08	15.84	11.55	1.21	80373.00
6	10.07	12.99	45.52	1.67	15.76	11.56	1.27	80602.00
7	9.21	12.84	48.22	1.90	14.33	11.83	1.28	80100.00
8	9.13	12.87	45.95	2.57	14.61	11.79	1.28	80573.00
9	8.73	12.60	47.69	2.74	14.11	11.84	1.32	79331.00
10	9.40	12.89	52.51	2.61	14.44	11.88	1.33	79156.00
11	10.66	13.28	51.26	2.75	14.12	11.91	1.31	78733.00
12	10.41	12.58	52.85	2.06	14.75	11.72	1.30	80357.00
13	10.27	12.38	50.75	2.91	14.81	11.73	1.29	77466.00
14	11.51	12.45	53.04	2.79	14.62	11.81	1.25	78222.00
15	10.41	13.29	54.37	2.75	14.01	12.25	1.21	74718.00
16	10.34	13.42	53.78	2.73	14.97	11.74	1.24	78001.00
17	10.17	11.98	53.88	2.49	15.62	11.69	1.24	78996.00
18	9.84	12.15	52.23	2.48	15.20	11.83	1.27	78449.00
19	10.09	12.09	52.25	2.15	15.43	11.61	1.29	78862.00
20	9.59	12.41	51.40	1.93	15.87	11.75	1.35	77582.00
21	9.40	12.26	51.77	1.58	18.68	11.11	1.35	80640.00
22	9.85	11.98	53.17	1.59	17.40	11.37	1.30	79792.00
23	9.60	12.18	54.48	1.79	17.62	11.17	1.31	80358.00
24	9.50	12.04	53.22	2.31	17.52	11.14	1.30	80146.00
25	8.70	12.18	49.22	2.42	16.50	11.53	1.27	78360.00
26	6.87	12.35	51.27	2.18	16.59	11.60	1.28	78411.00
27	8.61	12.11	52.75	2.19	17.57	11.45	1.28	80176.00
28	8.61	12.79	51.65	2.70	17.80	11.24	1.31	81282.00
平均值	9.68	12.54	51.01	2.31	15.73	11.63	1.26	79332.18
最大值	11.51	13.42	54.48	2.91	18.68	12.25	1.35	81282.00
最小值	6.87	11.98	45.52	1.58	14.01	11.11	1.06	74718.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P002_樹林焚化廠CEMS系統月報表

報表日期: 2026年2月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	10.14	12.09	49.10	2.30	16.02	10.80	1.02	77535.00
2	3.05	12.02	46.73	1.30	15.92	10.70	1.00	77431.00
3	4.42	12.21	45.09	1.55	16.04	10.56	1.04	77770.00
4	7.62	11.91	48.23	1.90	16.28	10.35	1.03	77618.00
5	8.46	11.34	45.46	1.31	16.99	10.01	1.00	77856.00
6	7.49	12.09	50.75	2.44	15.98	10.89	1.03	77525.00
7	3.14	12.01	50.57	1.89	15.28	10.91	1.03	77172.00
8	2.51	12.02	49.88	1.66	15.21	10.79	1.00	77437.00
9	2.45	11.72	51.89	1.18	15.52	10.63	1.01	78062.00
10	6.35	12.05	48.25	1.76	15.32	10.73	1.04	76206.00
11	8.57	11.93	51.96	1.79	15.34	10.47	1.03	76188.00
12	9.43	12.05	50.76	1.70	14.79	10.68	1.04	76359.00
13	8.17	11.95	52.76	1.86	14.88	10.94	1.05	77107.00
14	8.63	11.72	48.68	1.84	14.88	10.66	1.04	75502.00
15	10.06	11.72	47.77	2.21	14.35	10.78	1.03	74334.00
16	10.80	12.34	52.85	2.60	14.62	11.13	1.04	76151.00
17	10.65	11.84	49.23	1.91	15.91	10.45	1.04	77627.00
18	9.68	12.02	52.76	2.00	15.41	10.85	1.05	78875.00
19	8.42	11.83	52.00	1.52	15.66	10.36	1.04	78164.00
20	9.17	12.07	49.29	1.47	16.46	10.66	1.04	77757.00
21	9.67	12.39	52.81	0.97	18.97	10.08	1.03	80610.00
22	9.79	12.13	50.82	1.27	18.53	10.19	1.03	80332.00
23	9.76	11.66	55.89	1.19	18.12	9.95	1.03	79758.00
24	9.91	11.57	51.97	1.49	17.75	10.32	1.02	78755.00
25	9.54	12.02	53.52	1.92	16.61	10.53	1.00	77476.00
26	9.46	11.78	48.77	1.78	16.47	10.26	1.00	76356.00
27	9.33	12.24	49.93	1.52	17.87	10.38	1.01	79053.00
28	8.30	11.87	51.59	1.68	17.68	10.20	1.01	77973.00
平均值	8.03	11.95	50.33	1.71	16.17	10.55	1.03	77606.75
最大值	10.80	12.39	55.89	2.60	18.97	11.13	1.05	80610.00
最小值	2.45	11.34	45.09	0.97	14.35	9.95	1.00	74334.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P003_樹林焚化廠CEMS系統月報表

報表日期: 2026年2月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	10.17	11.86	51.26	2.22	16.06	9.90	1.41	74027.00
2	9.32	11.32	44.36	2.27	16.27	9.71	1.43	74153.00
3	9.10	11.44	47.96	2.27	16.53	9.68	1.45	74115.00
4	9.34	11.83	38.88	2.15	17.22	9.07	1.45	72812.00
5	9.44	11.14	40.46	2.29	17.24	9.34	1.44	73816.00
6	9.67	11.09	46.25	1.91	16.92	9.67	1.43	72950.00
7	9.65	11.29	40.66	2.33	16.41	9.46	1.42	72226.00
8	8.18	11.06	38.52	2.05	16.35	9.32	1.46	73202.00
9	7.49	11.44	36.63	2.02	16.90	9.17	1.47	74141.00
10	8.93	11.75	52.78	2.45	15.68	10.23	1.46	74254.00
11	8.55	11.74	49.07	2.16	16.51	9.10	1.43	72386.00
12	9.32	11.34	52.41	1.96	16.22	9.04	1.40	72887.00
13	9.52	11.56	54.49	2.72	15.13	10.06	1.40	71548.00
14	9.21	11.56	52.55	3.10	14.94	10.04	1.41	71139.00
15	9.28	11.19	52.49	3.20	14.88	9.77	1.41	69936.00
16	10.51	11.27	50.84	2.74	15.12	9.97	1.43	70815.00
17	9.35	11.73	53.22	2.52	15.62	10.16	1.45	72438.00
18	9.13	12.14	53.13	2.42	14.79	10.28	1.44	71937.00
19	8.76	12.40	46.11	2.17	17.04	8.83	1.43	71604.00
20	8.56	11.80	49.96	1.92	16.97	9.53	1.42	73165.00
21	9.04	12.03	52.72	1.66	18.42	10.08	1.43	74913.00
22	8.52	11.70	52.94	1.38	18.88	9.80	1.41	74012.00
23	9.19	11.92	52.28	1.84	18.27	9.86	1.39	73080.00
24	9.41	11.97	51.54	2.19	17.76	10.06	1.40	73052.00
25	8.84	11.71	51.43	1.93	17.02	9.75	1.42	73198.00
26	9.31	11.58	50.16	2.01	17.33	9.55	1.41	72672.00
27	9.09	11.66	51.82	1.78	18.22	9.65	1.40	74744.00
28	7.25	11.59	53.64	1.97	17.61	10.04	1.43	74964.00
平均值	9.08	11.61	48.88	2.20	16.65	9.68	1.43	73006.64
最大值	10.51	12.40	54.49	3.20	18.88	10.28	1.47	74964.00
最小值	7.25	11.06	36.63	1.38	14.79	8.83	1.39	69936.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。