

P001_樹林焚化廠CEMS系統月報表

報表日期: 2024年9月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	8.98	11.11	55.26	2.60	14.64	11.94	1.24	69499.00
2	9.13	13.09	57.10	2.61	15.00	11.92	1.23	69964.00
3	9.00	13.40	56.76	2.30	15.28	11.86	1.24	70057.00
4	8.84	13.68	57.61	2.53	14.52	12.09	1.25	68605.00
5	8.58	13.52	56.64	2.93	14.83	11.84	1.25	69613.00
6	7.97	12.60	54.02	2.65	14.44	12.02	1.24	68256.00
7	8.90	13.28	55.39	2.52	15.60	11.71	1.21	70221.00
8	8.73	12.34	53.31	2.58	15.41	11.68	1.22	70144.00
9	8.96	12.76	54.75	2.39	15.62	11.60	1.23	73599.00
10	8.98	12.58	55.85	2.16	15.50	11.68	1.24	78579.00
11	8.38	12.90	59.15	2.83	15.25	11.60	1.22	79624.00
12	6.37	13.46	56.99	3.24	15.54	11.50	1.19	78578.00
13	8.61	13.28	56.13	2.79	15.19	11.67	1.22	77773.00
14	9.03	12.50	59.71	2.55	15.89	11.58	1.22	80037.00
15	8.19	12.92	56.91	3.20	15.13	11.68	1.21	78702.00
16	8.93	13.22	56.16	2.65	16.09	11.44	1.21	80789.00
17	8.72	12.56	56.03	2.98	15.24	11.39	1.22	80598.00
18	8.95	13.05	56.00	3.21	14.80	11.59	1.19	79190.00
19	9.17	13.53	55.58	3.02	15.08	11.67	1.19	79385.00
20	8.07	13.59	56.11	3.33	14.74	11.83	1.20	76849.00
21	9.20	13.36	56.29	2.89	15.61	11.60	1.21	79172.00
22	9.18	12.94	54.15	2.84	15.53	11.60	1.24	79198.00
23	9.86	13.16	56.98	2.82	15.62	11.63	1.24	80446.00
24	6.04	12.98	59.34	4.05	15.19	11.61	1.24	78506.00
25	8.99	14.12	58.67	3.41	15.12	11.64	1.25	78639.00
26	9.32	13.36	60.18	2.80	15.18	11.63	1.25	79919.00
27	9.07	13.04	59.35	2.54	15.31	11.65	1.22	78928.00
28	8.83	13.21	56.90	2.60	15.72	11.54	1.21	79559.00
29	8.02	13.07	51.11	2.54	15.29	11.36	1.21	78983.00
30	8.88	12.09	57.75	2.51	15.61	11.41	1.26	81092.00
平 均 值	8.66	13.02	56.54	2.80	15.27	11.67	1.23	76483.47
最 大 值	9.86	14.12	60.18	4.05	16.09	12.09	1.26	81092.00
最 小 值	6.04	11.11	51.11	2.16	14.44	11.36	1.19	68256.00

備註： 1.*:儀器保養維護中。
2.**:停爐中。

P002_樹林焚化廠CEMS系統月報表

報表日期: 2024年9月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	2.33	11.13	51.03	2.20	16.14	10.96	0.99	78790.00
2	2.41	13.12	59.69	2.50	16.38	11.04	0.98	79130.00
3	2.20	12.98	56.92	2.57	15.95	11.34	0.95	79571.00
4	2.35	13.00	57.04	2.15	16.02	11.31	0.99	78091.00
5	3.05	12.80	59.85	2.33	16.17	11.06	1.00	78240.00
6	3.88	12.79	56.99	1.47	15.92	11.11	1.02	78875.00
7	2.07	12.75	59.64	2.07	16.15	11.14	1.00	79499.00
8	2.06	12.63	58.69	2.01	16.24	11.05	0.98	79810.00
9	1.91	12.87	57.86	2.80	15.90	11.26	0.99	79574.00
10	2.31	13.08	59.61	2.17	16.18	11.13	0.99	80421.00
11	2.53	12.48	59.97	2.01	16.12	10.76	0.97	80375.00
12	2.53	12.94	54.66	2.61	15.94	11.18	0.98	78501.00
13	2.74	13.10	55.37	2.13	16.20	11.02	1.00	80980.00
14	5.00	13.22	55.67	2.06	16.86	10.92	1.01	79003.00
15	3.49	12.82	54.37	1.86	16.36	10.99	1.00	78516.00
16	7.95	13.00	57.92	2.27	16.88	11.14	1.02	78848.00
17	6.78	11.96	56.01	2.82	16.08	10.90	1.00	79333.00
18	7.39	12.74	57.48	2.32	16.06	10.68	1.01	81736.00
19	2.97	12.94	58.12	2.41	15.42	10.86	0.99	79368.00
20	2.92	13.01	57.81	2.40	15.23	11.23	0.99	78155.00
21	3.56	12.73	56.50	2.02	16.37	10.91	0.98	80757.00
22	4.08	12.62	54.02	1.97	16.44	10.76	0.98	80600.00
23	7.41	13.02	54.77	2.16	16.61	11.08	1.01	80146.00
24	2.57	12.50	59.24	1.75	17.14	10.98	1.01	79847.00
25	3.52	13.08	56.30	1.51	17.14	10.74	0.99	80757.00
26	5.96	12.53	56.50	1.67	16.83	10.84	0.97	80879.00
27	6.60	13.12	59.00	2.00	16.28	11.17	0.98	80514.00
28	3.71	12.37	56.45	1.83	17.13	11.01	0.96	80684.00
29	4.64	13.03	53.06	1.55	16.76	10.99	0.95	81387.00
30	5.49	12.36	57.17	1.28	17.01	10.93	0.94	81773.00
平 均 值	3.88	12.76	56.92	2.10	16.33	11.02	0.99	79805.33
最 大 值	7.95	13.22	59.97	2.82	17.14	11.34	1.02	81773.00
最 小 值	1.91	11.13	51.03	1.28	15.23	10.68	0.94	78091.00

備註： 1.*:儀器保養維護中。
2.**:停爐中。

P003_樹林焚化廠CEMS系統月報表

報表日期: 2024年9月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	5.76	11.24	53.41	2.68	16.84	9.16	1.36	74009.00
2	8.44	12.52	56.04	2.59	16.28	9.76	1.38	77154.00
3	9.09	12.19	56.43	3.10	16.62	9.76	1.35	78841.00
4	8.32	13.19	57.10	3.12	16.28	9.90	1.35	78427.00
5	9.51	12.63	56.74	2.85	16.93	9.92	1.35	79440.00
6	9.14	12.13	56.67	2.59	16.01	10.00	1.34	80100.00
7	6.99	12.32	54.88	3.17	17.19	9.60	1.37	80819.00
8	8.60	12.13	56.27	2.34	17.24	9.35	1.38	79819.00
9	8.92	11.81	59.64	2.58	16.74	9.89	1.39	78291.00
10	8.14	12.26	57.22	3.44	17.26	9.62	1.38	77791.00
11	6.36	12.34	60.83	3.06	16.56	9.82	1.39	79690.00
12	7.93	12.16	57.67	3.00	16.80	9.37	1.42	77970.00
13	8.95	12.57	57.00	2.75	17.38	9.23	1.39	79021.00
14	8.99	11.49	54.73	2.86	18.13	8.93	1.38	79370.00
15	9.05	11.82	54.87	3.02	17.19	9.03	1.39	78566.00
16	7.97	11.60	53.78	2.72	18.14	9.38	1.36	80369.00
17	8.27	11.81	54.32	2.57	18.18	8.91	1.33	80306.00
18	7.75	12.57	54.03	2.81	17.68	8.94	1.33	78272.00
19	8.02	12.20	57.85	2.98	16.55	9.86	1.35	78408.00
20	7.47	12.21	58.60	2.66	16.35	9.74	1.36	76691.00
21	7.37	12.06	60.18	3.56	17.04	9.79	1.35	79694.00
22	3.60	12.59	59.64	3.02	16.95	9.66	1.39	80616.00
23	4.70	11.68	56.77	2.38	17.48	9.39	1.40	80065.00
24	6.73	12.71	60.08	3.67	16.79	9.81	1.43	80327.00
25	9.01	12.26	57.95	3.36	16.42	9.42	1.43	77117.00
26	8.83	12.43	57.91	2.19	16.59	9.80	1.43	78925.00
27	8.26	12.65	57.89	2.67	16.46	9.97	1.43	76982.00
28	7.65	12.58	58.15	3.20	17.08	10.17	1.42	79819.00
29	7.70	12.63	53.26	3.11	16.92	9.75	1.41	79460.00
30	8.92	12.09	51.16	2.75	16.69	9.97	1.39	80268.00
平 均 值	7.88	12.23	56.70	2.89	16.96	9.60	1.38	78887.57
最 大 值	9.51	13.19	60.83	3.67	18.18	10.17	1.43	80819.00
最 小 值	3.60	11.24	51.16	2.19	16.01	8.91	1.33	74009.00

備註： 1.*:儀器保養維護中。
2.**:停爐中。