

P001\_樹林焚化廠CEMS系統月報表

報表日期: 2026年4月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	9.82	12.26	48.05	2.26	16.91	11.27	1.29	81927.00
2	8.70	12.59	49.26	2.36	16.79	11.41	1.24	81242.00
3	9.60	12.64	54.42	2.48	17.75	11.08	1.22	78710.00
4	9.73	12.42	53.20	2.48	17.79	11.13	1.24	74085.00
5	11.05	12.53	50.63	2.78	18.42	10.92	1.24	74105.00
6	8.38	12.18	47.23	2.16	18.65	10.81	1.25	73967.00
7	8.91	11.69	54.61	2.23	18.60	10.96	1.25	74629.00
8	10.96	11.73	55.24	2.36	18.32	11.11	1.23	73568.00
9	9.67	11.96	52.22	2.02	18.77	10.93	1.21	73550.00
10	9.31	13.06	56.24	2.44	18.15	11.37	1.18	72909.00
11	7.47	12.52	55.90	2.40	18.25	11.24	1.18	72056.00
12	7.97	13.29	53.16	2.24	18.48	11.16	1.20	72546.00
13	7.67	13.00	52.54	2.33	17.97	11.31	1.22	72442.00
14	9.05	12.70	54.97	2.13	18.35	11.09	1.24	73688.00
15	8.74	12.51	52.50	2.23	17.62	11.27	1.24	73279.00
16	8.74	12.05	50.92	2.03	17.70	11.28	1.24	73458.00
17	7.99	12.11	50.72	1.86	18.19	11.20	1.24	73695.00
18	6.59	12.37	56.00	2.30	17.77	11.22	1.25	74431.00
19	8.64	11.83	47.01	2.44	17.50	11.23	1.28	72133.00
20	8.34	12.41	50.80	2.46	17.60	11.39	1.27	72658.00
21	9.36	12.88	51.94	2.31	17.86	11.16	1.25	74161.00
22	8.82	12.75	49.51	2.07	17.48	11.15	1.20	74790.00
23	8.91	12.04	50.80	2.12	17.47	11.29	1.18	73982.00
24	9.35	12.21	54.02	2.20	17.14	11.38	1.22	74256.00
25	7.02	11.99	54.24	2.12	17.44	11.36	1.22	74400.00
26	6.37	11.92	54.58	1.92	18.06	11.07	1.24	74787.00
27	8.11	12.53	54.83	2.16	17.16	11.31	1.22	73095.00
28	7.83	12.74	53.23	1.52	17.80	11.14	1.23	74242.00
29	8.20	13.19	53.21	2.37	17.19	11.41	1.18	71804.00
30	8.78	13.03	57.10	2.05	17.18	11.42	1.19	73227.00
平均值	8.67	12.44	52.64	2.23	17.81	11.20	1.23	74260.73
最大值	11.05	13.29	57.10	2.78	18.77	11.42	1.29	81927.00
最小值	6.37	11.69	47.01	1.52	16.79	10.81	1.18	71804.00

備註： 1.\*:儀器保養維護中。

2.\*\*:停爐中。

P002\_樹林焚化廠CEMS系統月報表

報表日期: 2026年4月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	10.66	12.57	55.22	1.09	17.66	11.55	0.82	69836.00
2	10.44	12.13	50.88	1.12	17.73	10.88	0.91	73739.00
3	10.81	12.04	47.16	1.44	19.19	10.01	0.95	78398.00
4	10.54	12.76	49.50	1.22	19.19	10.31	0.95	80115.00
5	10.17	12.35	47.65	1.14	19.72	10.18	1.02	81681.00
6	10.72	12.31	49.57	0.71	19.96	9.94	1.04	80486.00
7	9.57	12.73	51.02	1.07	19.29	10.65	1.01	78487.00
8	11.01	12.03	55.12	1.13	18.87	10.35	1.04	79453.00
9	10.18	12.12	50.81	0.88	19.48	10.25	1.04	78288.00
10	9.30	12.31	53.37	2.02	17.80	10.86	1.03	77153.00
11	8.53	13.64	55.14	2.12	17.61	10.96	1.04	79390.00
12	7.74	13.03	56.39	1.72	17.27	11.31	1.02	79007.00
13	6.93	12.67	54.60	1.15	17.36	11.18	0.98	78212.00
14	6.57	12.11	52.88	1.26	10.59	10.59	0.95	74877.00
15	7.83	12.20	50.62	1.28	17.37	10.45	0.95	75948.00
16	7.60	12.43	51.66	0.80	17.74	10.77	0.94	77569.00
17	8.28	12.67	53.64	1.06	18.27	10.42	0.96	80399.00
18	6.84	11.62	47.76	1.30	17.47	10.54	0.96	78614.00
19	7.90	11.95	50.68	1.51	17.74	10.34	0.94	79986.00
20	7.41	11.62	53.90	1.49	17.47	10.63	0.98	81096.00
21	7.45	12.55	52.60	1.74	17.68	10.63	1.02	79115.00
22	9.60	12.27	53.52	2.27	16.64	10.76	1.00	79130.00
23	9.41	11.89	52.46	2.28	17.02	10.60	0.96	78793.00
24	9.29	12.16	56.41	2.66	16.61	10.75	0.93	78437.00
25	9.90	11.81	56.54	1.92	17.56	10.37	0.96	78725.00
26	9.05	12.57	49.76	1.53	18.05	10.38	1.00	79391.00
27	8.35	11.72	52.91	2.02	17.59	10.15	1.02	79326.00
28	8.08	11.73	54.87	1.87	17.76	10.33	1.04	80363.00
29	9.13	12.43	52.78	2.12	17.22	10.57	1.06	78344.00
30	10.05	12.60	55.99	1.43	17.45	10.60	1.04	79641.00
平均值	8.98	12.30	52.51	1.51	17.71	10.58	0.99	78466.63
最大值	11.01	13.64	56.54	2.66	19.96	11.55	1.06	81681.00
最小值	6.57	11.62	47.16	0.71	10.59	9.94	0.82	69836.00

備註： 1.\*:儀器保養維護中。

2.\*\*:停爐中。

P003\_樹林焚化廠CEMS系統月報表

報表日期: 2026年4月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	9.51	11.41	52.82	2.36	17.35	9.64	1.36	76663.00
2	7.43	11.40	53.63	2.91	17.54	9.91	1.36	74859.00
3	9.01	12.07	54.90	2.02	18.32	9.86	1.35	77012.00
4	9.26	11.51	52.06	2.25	18.65	9.72	1.32	77427.00
5	8.81	12.00	49.14	3.01	18.83	9.66	1.34	76608.00
6	9.46	12.05	49.82	2.38	18.80	9.70	1.35	75291.00
7	8.95	11.91	52.23	2.92	18.42	10.16	1.31	76737.00
8	9.48	11.39	50.15	1.79	19.03	9.02	1.31	75125.00
9	8.36	11.38	50.41	2.56	19.53	9.06	1.31	74971.00
10	7.15	11.25	45.98	2.05	19.23	8.84	1.33	74490.00
11	9.31	12.19	52.23	1.87	18.57	9.41	1.32	74446.00
12	8.12	11.96	46.06	3.04	19.58	8.89	1.32	72475.00
13	8.84	11.49	52.50	2.16	18.33	9.49	1.35	73465.00
14	5.98	11.68	51.36	2.76	19.27	9.56	1.36	75509.00
15	7.08	11.64	52.17	2.62	18.52	9.19	1.36	72873.00
16	7.36	11.90	55.47	2.71	17.32	10.26	1.37	75085.00
17	6.05	12.02	55.73	2.99	17.50	10.22	1.37	75489.00
18	4.86	11.26	51.97	2.81	18.32	9.64	1.35	73123.00
19	7.66	11.59	50.23	2.86	17.88	10.16	1.34	74407.00
20	8.10	11.38	50.39	2.03	18.13	9.41	1.35	73559.00
21	5.99	11.61	52.85	2.92	17.69	9.69	1.33	72736.00
22	6.96	11.73	50.19	2.48	17.45	9.81	1.32	73136.00
23	6.87	11.82	52.86	2.64	16.74	10.58	1.31	72025.00
24	5.67	11.70	51.46	2.53	18.35	9.76	1.34	75856.00
25	6.68	11.36	48.95	2.65	17.94	9.56	1.34	75652.00
26	7.09	11.58	46.02	2.43	18.50	9.40	1.32	75726.00
27	5.70	11.58	49.18	2.33	17.61	9.62	1.30	75271.00
28	6.48	11.59	51.45	2.71	18.05	9.66	1.30	75519.00
29	7.09	11.95	56.13	2.28	16.86	10.08	1.33	72333.00
30	8.79	11.77	57.66	2.88	17.52	9.62	1.35	74883.00
平均值	7.60	11.67	51.53	2.53	18.19	9.65	1.34	74758.37
最大值	9.51	12.19	57.66	3.04	19.58	10.58	1.37	77427.00
最小值	4.86	11.25	45.98	1.79	16.74	8.84	1.30	72025.00

備註： 1.\*:儀器保養維護中。

2.\*\*:停爐中。