

P001_樹林焚化廠CEMS系統月報表

報表日期: 2025年10月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	9.38	13.60	53.96	1.80	15.49	11.41	1.25	79408.00
2	8.68	13.55	52.06	2.33	15.54	11.52	1.22	78943.00
3	9.02	12.55	50.52	3.12	15.56	11.56	1.19	78900.00
4	8.71	13.44	53.59	2.28	15.41	11.62	1.17	78528.00
5	8.90	12.85	54.04	2.40	15.55	11.48	1.18	79584.00
6	8.17	12.86	56.03	2.91	15.36	11.75	1.18	76922.00
7	8.97	12.45	51.62	2.47	16.38	11.35	1.19	79051.00
8	8.36	13.11	53.24	3.10	15.57	11.67	1.19	78652.00
9	7.76	13.11	54.84	3.35	15.48	11.79	1.20	78584.00
10	8.97	13.30	54.14	2.92	16.13	11.45	1.21	79161.00
11	9.02	13.92	52.58	2.88	16.43	11.42	1.23	78569.00
12	9.16	13.50	49.89	2.80	16.62	11.05	1.24	79688.00
13	9.01	13.42	53.80	2.74	15.51	11.67	1.25	78134.00
14	8.89	13.62	56.29	3.11	16.23	11.60	1.22	72488.00
15	8.70	13.12	57.57	2.59	16.53	11.40	1.23	72612.00
16	8.82	13.86	54.88	2.90	15.67	11.57	1.20	72191.00
17	7.90	13.55	57.36	3.64	15.84	11.57	1.19	70970.00
18	8.82	13.11	57.28	1.87	15.49	11.63	1.19	70427.00
19	8.83	13.26	49.14	2.12	15.47	11.80	1.19	70017.00
20	8.36	13.36	57.10	2.16	15.28	11.92	1.20	70147.00
21	9.84	12.53	57.62	2.53	15.60	11.96	1.21	73523.00
22	6.23	12.17	53.28	2.44	16.69	11.45	1.25	73243.00
23	6.45	13.23	53.94	2.70	16.47	11.58	1.26	73723.00
24	5.15	12.88	55.91	2.50	16.74	11.55	1.25	74028.00
25	6.67	13.30	54.43	2.64	16.85	11.54	1.26	74208.00
26	6.12	13.93	52.90	2.87	16.69	11.64	1.25	73104.00
27	8.52	13.72	52.15	2.72	15.69	11.81	1.24	72653.00
28	7.45	13.67	52.22	2.70	16.59	11.56	1.22	71925.00
29	8.40	13.47	55.26	2.80	15.04	11.92	1.22	73283.00
30	10.95	12.81	54.07	2.87	16.22	11.67	1.20	72799.00
31	11.08	12.59	54.88	3.58	16.55	11.49	1.22	73333.00
平 均 值	8.43	13.22	54.08	2.70	15.96	11.59	1.22	75122.52
最 大 值	11.08	13.93	57.62	3.64	16.85	11.96	1.26	79688.00
最 小 值	5.15	12.17	49.14	1.80	15.04	11.05	1.17	70017.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P002_樹林焚化廠CEMS系統月報表

報表日期: 2025年10月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	5.46	13.73	50.17	1.01	17.56	10.79	0.92	81887.00
2	4.91	12.96	48.12	1.04	17.66	11.05	0.92	81725.00
3	3.56	13.12	49.76	0.92	18.16	11.00	0.92	82250.00
4	3.79	12.60	50.51	1.00	17.72	10.92	0.94	81237.00
5	2.87	12.81	52.11	0.82	17.83	10.84	0.94	83055.00
6	3.14	13.03	51.44	0.48	17.75	10.79	0.96	81578.00
7	2.57	12.91	48.16	0.84	17.46	10.77	0.99	80958.00
8	3.30	12.99	46.38	0.95	17.15	10.64	0.99	81560.00
9	2.80	12.85	49.12	0.58	17.04	10.66	0.98	81256.00
10	5.04	12.34	45.99	1.08	17.92	10.66	0.95	81746.00
11	7.84	12.60	44.42	1.09	17.73	10.68	0.95	80005.00
12	2.56	12.93	45.83	0.57	18.27	10.45	0.95	82134.00
13	3.54	13.40	44.90	0.44	17.60	10.97	0.94	82620.00
14	4.56	13.10	48.58	1.33	17.47	10.92	0.95	82411.00
15	7.21	13.09	49.45	1.44	17.35	10.98	0.92	82575.00
16	6.57	13.66	54.28	1.30	17.15	10.80	0.91	82722.00
17	5.74	13.73	53.88	1.20	17.61	10.79	0.90	83029.00
18	4.58	13.64	50.14	1.56	16.83	10.89	0.90	82740.00
19	4.23	13.12	47.57	1.60	16.68	11.08	0.90	81527.00
20	7.54	13.10	51.84	1.08	17.74	10.81	0.92	82767.00
21	5.56	13.98	54.92	1.05	18.42	10.80	0.93	82237.00
22	5.92	12.78	53.44	1.08	18.34	10.71	0.94	82907.00
23	5.50	13.27	52.30	0.83	18.95	10.50	1.00	85219.00
24	2.78	13.22	50.14	1.01	19.45	10.40	1.02	84929.00
25	2.71	12.42	48.36	0.90	19.34	10.38	1.02	85775.00
26	2.41	12.87	49.98	1.31	19.05	10.63	1.00	83682.00
27	2.52	12.82	49.39	1.02	18.26	10.49	0.94	85592.00
28	3.19	12.93	54.19	1.00	18.56	10.65	0.97	84442.00
29	3.08	13.14	48.62	1.09	17.80	10.76	0.98	84103.00
30	2.96	12.92	49.80	1.11	17.93	10.58	0.97	84920.00
31	4.66	12.68	53.09	1.62	18.06	10.64	0.97	85075.00
平 均 值	4.29	13.06	49.90	1.04	17.90	10.74	0.95	82860.10
最 大 值	7.84	13.98	54.92	1.62	19.45	11.08	1.02	85775.00
最 小 值	2.41	12.34	44.42	0.44	16.68	10.38	0.90	80005.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P003_樹林焚化廠CEMS系統月報表

報表日期: 2025年10月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	8.88	12.72	52.62	1.43	17.09	10.11	1.39	79483.00
2	8.70	11.93	50.59	0.90	17.11	9.71	1.38	75313.00
3	8.25	12.09	55.58	0.95	17.11	9.82	1.36	75869.00
4	9.05	12.81	55.43	1.14	17.17	10.00	1.36	77870.00
5	8.85	12.94	54.46	0.97	17.03	10.13	1.37	79266.00
6	8.82	13.04	54.85	0.98	17.50	9.74	1.38	78434.00
7	9.10	12.56	51.48	0.94	18.09	9.78	1.38	79162.00
8	8.87	11.94	54.34	1.02	17.30	9.73	1.40	77666.00
9	8.63	12.47	56.07	1.01	17.07	9.66	1.43	79045.00
10	8.63	11.08	51.50	0.95	16.81	10.02	1.42	77320.00
11	8.19	12.92	56.37	0.69	17.88	9.74	1.40	78065.00
12	8.90	12.89	51.22	0.87	18.21	9.32	1.38	79010.00
13	7.82	12.53	53.49	1.11	17.16	9.50	1.37	76863.00
14	9.07	12.45	52.20	2.04	16.88	9.69	1.36	78094.00
15	9.24	12.29	52.53	1.91	16.94	9.42	1.35	77694.00
16	8.87	12.13	54.50	2.01	16.89	9.61	1.37	74723.00
17	8.70	12.42	53.62	2.10	17.06	9.60	1.38	76219.00
18	8.88	12.99	56.98	2.14	16.36	10.09	1.36	77492.00
19	9.00	12.32	53.83	2.21	17.31	9.38	1.38	76991.00
20	8.94	12.88	56.68	2.17	17.18	10.14	1.41	80088.00
21	9.25	12.44	55.21	2.15	17.65	9.91	1.39	81002.00
22	9.53	12.29	53.96	2.43	17.28	9.91	1.38	80279.00
23	10.96	12.11	56.22	2.24	17.95	9.61	1.39	82105.00
24	11.52	13.42	54.41	2.09	18.35	9.64	1.38	81979.00
25	11.48	12.35	52.71	1.98	18.49	9.78	1.39	81825.00
26	10.17	12.94	53.14	1.86	18.93	9.48	1.40	78751.00
27	10.78	11.39	55.53	1.83	17.77	9.49	1.38	79197.00
28	11.30	12.01	53.38	1.87	18.24	9.72	1.38	79285.00
29	11.49	12.08	56.85	1.98	16.95	10.22	1.38	79416.00
30	11.71	12.11	51.00	2.59	18.21	9.41	1.43	80115.00
31	12.07	12.37	58.00	3.38	17.49	9.94	1.45	79483.00
平 均 值	9.54	12.42	54.15	1.68	17.47	9.75	1.39	78648.52
最 大 值	12.07	13.42	58.00	3.38	18.93	10.22	1.45	82105.00
最 小 值	7.82	11.08	50.59	0.69	16.36	9.32	1.35	74723.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。