

P001\_樹林焚化廠CEMS系統月報表

報表日期: 2023年1月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	11.17	4.44	58.27	1.92	19.90	11.16	1.41	76807.00
2	10.40	4.92	58.16	2.16	19.26	11.29	1.41	76094.00
3	9.38	4.21	57.46	2.25	18.48	11.45	1.44	76569.00
4	9.57	3.27	55.22	3.19	18.65	11.51	1.48	76854.00
5	9.44	2.05	59.43	3.37	19.25	11.29	1.45	76223.00
6	10.04	3.57	56.09	3.43	18.97	11.40	1.43	75701.00
7	8.87	3.66	56.50	3.35	18.43	11.67	1.45	75065.00
8	7.12	3.92	55.41	3.05	19.18	11.48	1.45	74709.00
9	7.50	3.61	54.13	3.19	18.73	11.46	1.41	74828.00
10	8.35	4.15	54.17	3.42	18.14	11.73	1.40	74016.00
11	8.46	3.18	53.98	3.27	18.67	11.68	1.43	73594.00
12	8.25	3.28	53.07	3.22	18.71	11.69	1.41	72731.00
13	9.36	3.01	54.04	2.52	18.93	11.70	1.41	72722.00
14	10.29	3.58	52.60	2.40	18.44	11.76	1.41	72341.00
15	10.45	4.04	50.72	2.47	18.00	11.80	1.39	73661.00
16	8.65	3.66	51.42	2.26	17.75	11.79	1.35	74412.00
17	9.94	4.28	51.30	2.73	17.12	12.03	1.39	72837.00
18	9.73	3.46	52.21	2.35	17.38	12.00	1.42	72603.00
19	9.72	3.00	51.82	2.24	17.55	11.87	1.46	73264.00
20	10.71	3.57	48.54	2.76	16.65	12.10	1.46	72600.00
21	9.04	3.52	56.35	2.31	17.13	11.98	1.48	72868.00
22	6.65	2.85	58.23	2.17	17.61	11.88	1.48	71929.00
23	5.35	4.79	53.28	2.32	17.27	12.07	1.43	71002.00
24	8.71	5.83	53.60	2.74	15.94	12.46	1.42	69713.00
25	7.71	4.91	50.67	1.70	17.49	11.90	1.48	73174.00
26	5.90	4.07	50.57	1.44	19.42	11.54	1.44	72937.00
27	5.05	3.49	53.30	1.88	19.01	11.69	1.46	72918.00
28	3.25	2.68	50.45	1.34	19.24	11.39	1.41	75012.00
29	3.28	2.12	51.00	1.19	19.70	11.37	1.41	74612.00
30	3.63	3.09	52.23	1.33	19.37	11.43	1.45	74741.00
31	3.50	3.84	52.25	1.56	18.60	11.70	1.43	72660.00
平均值	8.05	3.68	53.76	2.44	18.35	11.69	1.43	73845.06
最大值	11.17	5.83	59.43	3.43	19.90	12.46	1.48	76854.00
最小值	3.25	2.05	48.54	1.19	15.94	11.16	1.35	69713.00

備註： 1.\*:儀器保養維護中。

2.\*\*:停爐中。

P002\_樹林焚化廠CEMS系統月報表

報表日期: 2023年1月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	9.94	5.60	62.60	2.29	16.79	10.55	1.33	64438.00
2	9.82	3.84	57.43	2.33	16.24	10.67	1.32	64452.00
3	9.24	3.26	61.47	2.40	15.80	10.75	1.34	65683.00
4	9.95	3.21	58.37	2.48	16.01	10.69	1.41	65108.00
5	9.09	2.44	60.14	2.16	16.26	10.80	1.40	65040.00
6	9.93	4.45	60.44	2.43	16.27	10.76	1.38	64404.00
7	10.05	4.07	60.54	2.55	15.80	10.81	1.40	63772.00
8	9.35	4.52	55.66	2.17	17.18	10.43	1.36	64154.00
9	9.75	3.95	55.89	2.28	16.70	10.61	1.30	63831.00
10	9.84	4.34	57.38	2.25	16.54	10.56	1.27	64539.00
11	9.53	4.03	57.27	2.80	15.69	10.74	1.30	63818.00
12	9.54	3.63	52.61	2.37	17.19	10.58	1.30	64845.00
13	10.40	3.59	53.78	2.76	17.12	10.72	1.35	64501.00
14	10.82	3.27	52.72	2.60	17.05	10.57	1.37	63172.00
15	10.82	2.73	51.86	2.63	16.33	10.50	1.36	63040.00
16	10.51	3.52	53.64	2.40	15.75	10.60	1.40	63247.00
17	10.83	3.10	54.85	2.86	15.74	10.82	1.40	63275.00
18	10.43	3.38	53.89	2.58	15.43	10.80	1.43	63937.00
19	10.38	2.68	54.22	2.34	15.23	10.66	1.41	63251.00
20	10.34	4.30	50.88	2.36	14.96	10.82	1.38	63697.00
21	10.19	3.35	50.78	2.33	15.29	10.87	1.43	63132.00
22	9.56	3.66	48.63	2.12	15.91	10.72	1.43	63884.00
23	6.64	3.03	50.83	2.05	15.43	10.76	1.41	62483.00
24	10.08	3.73	50.94	2.14	14.54	10.52	1.40	61788.00
25	7.82	3.80	50.63	1.88	15.18	10.76	1.37	63193.00
26	6.24	2.88	50.51	1.49	17.31	10.35	1.39	63975.00
27	3.52	3.32	49.35	1.41	17.16	10.29	1.42	64745.00
28	4.48	2.29	46.71	1.41	16.69	10.40	1.49	64210.00
29	3.07	2.09	46.90	1.34	17.55	10.27	1.50	64324.00
30	4.39	1.56	56.66	1.43	16.96	10.43	1.46	63753.00
31	2.69	2.22	58.15	1.29	17.12	10.56	1.45	63700.00
平均值	8.69	3.41	54.38	2.19	16.23	10.62	1.39	63915.84
最大值	10.83	5.60	62.60	2.86	17.55	10.87	1.50	65683.00
最小值	2.69	1.56	46.71	1.29	14.54	10.27	1.27	61788.00

備註： 1.\*:儀器保養維護中。

2.\*\*:停爐中。

P003\_樹林焚化廠CEMS系統月報表

報表日期: 2023年1月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	10.29	3.31	61.70	2.53	15.84	10.64	1.82	84929.00
2	9.64	4.89	56.83	2.82	15.20	10.68	1.80	82847.00
3	9.37	3.62	63.95	2.87	14.89	10.86	1.77	84607.00
4	10.89	3.46	61.61	2.75	14.93	10.75	1.74	82741.00
5	9.07	2.45	62.36	2.42	15.33	10.67	1.76	83158.00
6	8.95	5.28	60.03	2.57	15.42	10.83	1.74	83150.00
7	8.54	4.46	61.37	2.76	14.87	10.97	1.73	83925.00
8	8.32	6.28	53.72	1.89	16.82	10.46	1.73	84618.00
9	9.00	3.38	57.00	2.27	16.12	10.61	1.72	84253.00
10	9.07	4.99	57.52	2.99	14.71	10.89	1.68	82241.00
11	8.51	4.15	57.27	2.96	14.70	10.87	1.70	81590.00
12	11.06	2.83	55.64	2.81	15.74	10.68	1.72	82882.00
13	11.72	3.14	55.81	2.99	15.87	10.80	1.74	82747.00
14	11.45	3.22	55.07	3.01	15.60	10.77	1.75	80997.00
15	12.63	3.79	55.87	2.93	15.31	10.91	1.71	83414.00
16	11.50	3.65	53.77	2.44	14.46	11.10	1.72	84643.00
17	11.92	4.33	55.32	2.63	14.22	11.50	1.73	83189.00
18	11.04	5.29	53.57	2.74	13.85	11.56	1.77	82190.00
19	11.37	4.36	59.42	2.78	13.37	11.58	1.77	80516.00
20	12.31	4.07	60.81	3.22	13.31	11.45	1.75	80597.00
21	11.10	3.83	56.18	2.67	13.69	11.28	1.78	80923.00
22	10.24	4.08	55.81	2.30	14.43	11.12	1.79	83786.00
23	7.89	3.98	55.08	2.38	14.14	10.98	1.73	80695.00
24	9.42	2.94	60.03	2.35	13.46	11.17	1.74	82259.00
25	7.55	3.00	60.30	1.59	14.26	11.31	1.77	85584.00
26	5.50	5.06	57.77	1.17	15.60	11.23	1.86	85435.00
27	5.04	4.34	61.07	1.47	15.18	11.31	1.83	85857.00
28	4.28	3.97	58.70	1.15	15.05	11.42	1.82	84352.00
29	4.87	4.47	55.60	0.92	15.90	11.14	1.84	86098.00
30	5.06	3.86	58.38	1.28	15.02	11.11	1.82	83183.00
31	2.99	5.27	60.30	1.11	15.20	11.10	1.83	83878.00
平均值	9.05	4.06	58.00	2.35	14.92	11.02	1.76	83267.23
最大值	12.63	6.28	63.95	3.22	16.82	11.58	1.86	86098.00
最小值	2.99	2.45	53.57	0.92	13.31	10.46	1.68	80516.00

備註： 1.\*:儀器保養維護中。

2.\*\*:停爐中。