

P001_樹林焚化廠CEMS系統月報表

報表日期: 2021年3月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	4.20	7.30	74.30	2.02	12.73	14.02	1.27	70812.00
2	3.30	4.98	65.50	1.80	12.92	13.82	1.25	73270.00
3	8.32	13.26	64.82	2.29	12.89	13.71	1.27	74190.00
4	8.77	16.03	71.18	2.44	12.37	14.14	1.34	70057.00
5	8.76	13.10	67.56	1.90	13.25	13.74	1.36	72965.00
6	8.71	16.00	64.33	2.10	13.10	13.73	1.31	73303.00
7	5.72	6.56	67.48	1.29	13.90	13.70	1.37	73069.00
8	10.23	11.19	62.68	2.11	13.10	13.64	1.34	74560.00
9	11.00	16.82	60.54	2.08	13.28	13.58	1.40	74548.00
10	12.15	9.78	59.83	2.05	13.28	13.57	1.38	75235.00
11	12.93	13.38	60.28	1.97	13.20	13.59	1.41	74147.00
12	13.37	11.67	61.26	2.34	13.20	13.56	1.40	74897.00
13	8.96	16.73	61.09	2.15	13.04	13.52	1.36	75914.00
14	7.68	7.55	64.81	1.68	13.52	13.54	1.43	74046.00
15	13.34	16.06	68.61	2.45	12.85	13.66	1.45	73191.00
16	11.85	18.21	59.82	2.39	13.02	13.58	1.43	74090.00
17	15.41	17.56	60.07	2.43	13.36	13.58	1.42	73527.00
18	12.98	14.80	63.80	2.41	13.32	13.64	1.40	72803.00
19	13.67	15.48	64.19	2.65	13.24	13.66	1.39	72398.00
20	11.17	21.03	60.92	2.99	13.36	13.68	1.41	70499.00
21	14.34	18.17	54.37	3.06	13.29	13.43	1.33	75342.00
22	10.97	10.62	65.02	2.75	12.54	13.59	1.27	75956.00
23	9.44	17.11	61.39	2.60	12.74	13.53	1.30	75444.00
24	10.07	21.85	59.71	2.13	13.54	13.30	1.32	76560.00
25	12.41	11.88	71.19	2.41	12.60	13.74	1.31	74187.00
26	9.96	22.95	53.60	1.76	13.82	13.22	1.40	76229.00
27	11.29	17.04	59.28	1.52	14.02	13.29	1.40	75580.00
28	8.73	14.32	65.34	1.67	14.16	13.42	1.43	73780.00
29	8.70	20.76	61.26	1.81	13.76	13.47	1.45	73565.00
30	7.73	19.71	55.30	1.66	14.05	13.38	1.47	73654.00
31	7.99	15.75	57.75	1.43	14.47	13.27	1.41	74642.00
平均值	10.13	14.76	62.82	2.14	13.29	13.59	1.37	73950.32
最大值	15.41	22.95	74.30	3.06	14.47	14.14	1.47	76560.00
最小值	3.30	4.98	53.60	1.29	12.37	13.22	1.25	70057.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P002_樹林焚化廠CEMS系統月報表

報表日期: 2021年3月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	10.64	6.23	87.76	0.22	19.27	10.29	1.35	67618.00
2	10.54	7.95	91.41	0.15	19.71	10.08	1.30	68792.00
3	9.14	7.66	87.20	0.19	19.26	10.09	1.28	69225.00
4	11.99	7.19	91.58	0.63	19.20	10.17	1.28	68114.00
5	15.84	10.59	85.70	0.36	19.85	9.75	1.28	69082.00
6	9.86	8.50	91.01	0.20	19.50	10.04	1.32	69072.00
7	9.48	7.50	90.97	0.16	20.37	9.87	1.33	70020.00
8	12.76	7.81	93.38	0.36	19.44	9.97	1.38	69787.00
9	10.93	10.14	92.53	0.23	19.28	9.93	1.39	68885.00
10	7.79	8.04	90.86	0.15	19.73	9.90	1.41	69041.00
11	9.05	5.60	91.63	0.16	18.33	10.26	1.43	68077.00
12	11.16	9.69	92.04	0.83	15.75	11.06	1.41	64659.00
13	10.36	11.81	94.24	0.65	16.29	11.03	1.43	65264.00
14	10.14	7.46	104.20	1.22	17.13	10.69	1.42	66477.00
15	7.89	5.35	103.48	0.50	16.48	10.63	1.39	64035.00
16	7.87	11.59	91.58	0.74	16.67	10.39	1.40	64369.00
17	15.42	15.34	99.40	1.66	16.29	10.52	1.40	63075.00
18	12.37	14.35	96.99	0.96	16.34	10.45	1.40	62255.00
19	14.58	8.91	95.64	1.10	16.54	10.64	1.41	63433.00
20	17.72	13.91	99.61	2.09	16.64	10.68	1.41	63294.00
21	23.98	7.13	99.69	1.18	18.95	10.78	1.31	65966.00
22	21.89	9.38	103.28	0.90	18.52	10.90	1.28	65353.00
23	16.55	6.01	100.11	0.81	16.98	10.79	1.35	64604.00
24	13.62	12.90	104.61	0.89	15.90	10.97	1.36	64809.00
25	13.58	13.48	102.17	0.82	14.87	10.98	1.38	63355.00
26	11.49	7.62	99.22	1.01	15.93	10.93	1.39	62961.00
27	13.27	13.27	99.12	0.81	16.22	10.84	1.41	62916.00
28	7.34	4.81	108.41	0.42	17.00	10.92	1.46	63403.00
29	8.01	6.31	104.26	0.45	16.80	10.85	1.45	64205.00
30	8.74	7.37	100.25	0.63	16.74	10.89	1.47	65271.00
31	9.91	9.60	97.22	0.86	16.72	10.63	1.46	64601.00
平均值	12.06	9.15	96.44	0.69	17.64	10.51	1.38	65871.55
最大值	23.98	15.34	108.41	2.09	20.37	11.06	1.47	70020.00
最小值	7.34	4.81	85.70	0.15	14.87	9.75	1.28	62255.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P003_樹林焚化廠CEMS系統月報表

報表日期: 2021年3月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	7.61	4.72	87.29	1.39	15.70	10.95	1.47	83671.00
2	5.79	4.45	85.48	1.45	15.50	11.11	1.45	86259.00
3	8.40	5.91	81.56	1.58	15.19	11.07	1.45	84504.00
4	12.51	5.55	85.45	1.82	14.92	11.21	1.47	83502.00
5	12.70	3.86	80.54	1.42	16.00	10.82	1.51	84027.00
6	16.40	4.55	77.13	1.68	15.38	10.77	1.50	82893.00
7	10.52	3.58	86.30	1.57	16.05	11.01	1.50	85754.00
8	10.77	4.51	85.79	1.63	15.32	11.10	1.51	84144.00
9	14.93	6.04	77.79	1.82	15.57	10.79	1.48	83544.00
10	5.40	2.87	76.98	1.34	15.78	10.73	1.47	83744.00
11	10.23	7.34	76.32	1.79	14.88	11.04	1.45	82872.00
12	10.21	7.93	75.66	1.56	15.38	10.94	1.40	82753.00
13	11.13	14.77	61.23	1.70	15.44	10.65	1.38	81028.00
14	7.82	4.82	66.10	1.33	15.71	10.64	1.40	79395.00
15	7.66	3.62	73.56	1.34	15.39	10.63	1.43	79370.00
16	13.01	9.91	70.03	2.00	15.07	10.67	1.41	79610.00
17	13.81	6.54	74.84	2.32	15.35	10.68	1.46	79278.00
18	14.94	8.71	77.72	2.08	14.82	10.88	1.49	77895.00
19	11.63	6.82	77.80	1.70	15.44	10.76	1.50	78576.00
20	13.87	8.25	70.88	1.88	15.34	10.77	1.49	77915.00
21	11.18	4.21	74.16	1.75	15.66	10.64	1.40	80442.00
22	11.40	7.25	70.15	1.91	15.32	10.57	1.38	76862.00
23	7.30	10.61	64.93	1.61	15.52	10.40	1.44	76407.00
24	15.59	5.27	80.51	1.82	17.06	10.67	1.47	77236.00
25	18.59	20.85	72.23	2.35	14.92	10.56	1.43	77526.00
26	8.90	8.29	61.76	1.31	16.08	10.34	1.46	79630.00
27	11.60	11.65	68.83	1.71	15.73	10.66	1.45	78209.00
28	8.52	5.32	69.61	1.17	16.92	10.40	1.44	78624.00
29	9.06	4.10	71.02	1.22	16.26	10.55	1.46	79558.00
30	9.70	10.27	66.92	1.22	16.59	10.52	1.47	79696.00
31	13.97	8.51	70.26	1.57	16.48	10.58	1.49	83671.00
平均值	11.13	7.13	74.80	1.65	15.64	10.75	1.46	80922.42
最大值	18.59	20.85	87.29	2.35	17.06	11.21	1.51	86259.00
最小值	5.40	2.87	61.23	1.17	14.82	10.34	1.38	76407.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。