

P001_樹林焚化廠CEMS系統月報表

報表日期: 2021年11月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	21.01	11.44	85.49	2.06	16.01	11.62	1.09	68828.00
2	15.87	11.48	83.63	1.67	16.28	11.38	0.98	68875.00
3	11.76	16.03	68.71	2.47	13.71	11.73	0.95	47806.00
4	19.21	14.48	81.12	2.88	14.14	12.12	1.09	52414.00
5	18.20	14.43	81.92	1.52	16.53	11.52	1.18	60584.00
6	14.94	13.35	81.16	1.78	16.04	11.34	1.07	69461.00
7	17.50	15.15	81.32	2.08	16.18	11.41	0.91	68981.00
8	16.38	10.08	94.04	2.17	15.89	11.31	1.05	69278.00
9	16.19	12.92	90.44	1.85	15.98	11.43	1.05	69930.00
10	16.07	11.63	81.24	1.69	15.82	11.40	1.06	69342.00
11	17.14	11.03	91.43	1.49	15.67	11.40	1.12	69721.00
12	13.54	18.36	83.99	2.51	15.00	11.59	1.29	67029.00
13	17.01	8.02	97.56	2.81	15.71	11.61	1.28	68446.00
14	15.32	7.48	86.47	1.65	17.13	11.05	1.32	71269.00
15	14.84	7.32	95.10	1.60	16.26	11.25	1.34	69408.00
16	16.10	9.16	98.61	1.71	16.61	11.26	1.32	68275.00
17	16.59	12.09	89.98	2.26	15.99	11.61	1.33	66648.00
18	15.15	9.99	85.21	1.55	16.63	11.30	1.31	68398.00
19	16.91	10.01	88.89	1.60	17.23	11.37	1.34	68450.00
20	15.59	10.85	91.86	1.47	17.38	11.46	1.37	67532.00
21	19.16	8.18	95.77	1.67	17.62	11.21	1.35	68409.00
22	18.42	6.88	108.12	2.81	15.05	12.16	1.34	64702.00
23	15.25	10.91	84.26	1.73	16.18	11.50	1.31	68799.00
24	17.50	9.36	81.30	2.10	15.81	11.56	1.28	68492.00
25	15.83	14.99	84.28	1.63	16.04	11.68	1.32	68421.00
26	20.56	10.02	87.68	1.68	16.60	11.47	1.36	69419.00
27	17.38	7.34	91.58	1.08	16.61	11.67	1.37	67611.00
28	19.15	6.94	89.42	0.89	17.04	11.47	1.38	67745.00
29	17.78	9.51	105.27	0.74	17.42	11.43	1.37	66556.00
30	16.83	11.37	79.39	0.75	17.30	11.39	1.36	68436.00
平均值	16.77	11.03	88.17	1.80	16.20	11.49	1.23	66975.50
最大值	21.01	18.36	108.12	2.88	17.62	12.16	1.38	71269.00
最小值	11.76	6.88	68.71	0.74	13.71	11.05	0.91	47806.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P002_樹林焚化廠CEMS系統月報表

報表日期: 2021年11月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	17.38	3.87	98.71	0.50	17.46	10.61	1.42	62359.00
2	16.81	6.00	90.78	0.38	16.98	10.84	1.44	62302.00
3	17.49	9.34	88.11	0.71	16.79	10.73	1.45	62818.00
4	16.48	10.30	91.69	0.74	16.68	10.79	1.43	62923.00
5	15.97	5.14	90.63	0.34	17.66	10.73	1.44	63377.00
6	15.19	9.42	85.53	0.56	17.34	10.58	1.43	62573.00
7	15.31	11.45	86.88	0.74	16.74	10.68	1.40	62170.00
8	16.77	3.81	95.52	0.53	16.45	10.71	1.39	62066.00
9	18.04	7.67	96.27	0.65	17.02	10.64	1.38	63569.00
10	18.72	10.16	87.43	0.87	16.27	10.82	1.42	62650.00
11	18.13	11.26	87.48	0.67	16.41	10.77	1.42	62578.00
12	13.85	7.16	92.76	0.32	16.84	10.55	1.42	63238.00
13	14.97	6.38	94.23	0.51	16.76	10.78	1.42	62147.00
14	13.42	4.52	86.50	0.35	17.41	10.58	1.45	63461.00
15	13.67	7.10	97.82	0.27	17.19	10.51	1.45	62180.00
16	14.55	9.60	92.90	0.47	17.17	10.66	1.44	61480.00
17	16.20	12.26	89.70	0.77	16.66	10.68	1.40	62587.00
18	14.70	12.36	80.99	0.33	17.56	10.42	1.42	62313.00
19	14.71	6.38	90.43	0.18	18.39	10.62	1.43	62534.00
20	15.33	4.63	89.55	0.23	17.98	10.61	1.43	62787.00
21	16.76	11.74	93.13	0.42	17.97	10.56	1.44	62571.00
22	15.84	12.67	82.09	0.85	16.58	10.78	1.44	60656.00
23	15.16	8.19	88.91	0.37	16.90	10.93	1.45	61472.00
24	16.54	7.63	83.91	1.15	16.38	10.74	1.39	60706.00
25	15.94	17.01	86.54	0.71	16.74	10.77	1.43	60532.00
26	15.10	10.58	82.48	0.25	18.02	10.37	1.42	61514.00
27	15.67	16.69	79.87	0.39	18.37	10.24	1.41	61422.00
28	16.09	12.37	84.69	0.33	18.32	10.36	1.43	62836.00
29	16.83	7.64	88.70	0.23	18.56	10.40	1.45	63229.00
30	16.38	12.96	82.91	0.48	18.22	10.69	1.47	61253.00
平均值	15.93	9.21	88.90	0.51	17.26	10.64	1.43	62276.77
最大值	18.72	17.01	98.71	1.15	18.56	10.93	1.47	63569.00
最小值	13.42	3.81	79.87	0.18	16.27	10.24	1.38	60532.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P003_樹林焚化廠CEMS系統月報表

報表日期: 2021年11月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	14.69	3.85	94.72	4.36	15.48	10.63	1.33	73981.00
2	13.37	3.69	95.86	3.05	16.54	10.55	1.34	77085.00
3	15.83	9.83	94.18	3.56	15.88	10.75	1.34	78982.00
4	16.27	11.23	95.99	4.18	14.78	10.92	1.33	76130.00
5	15.26	11.10	94.89	3.54	16.01	10.82	1.31	77665.00
6	16.75	9.21	98.97	4.11	15.68	10.84	1.29	77724.00
7	16.00	10.75	97.02	4.16	15.05	10.67	1.29	74468.00
8	16.01	10.04	84.14	3.48	15.82	10.47	1.24	75681.00
9	17.34	13.07	94.61	3.54	15.79	10.82	1.26	78592.00
10	15.63	6.62	99.21	4.82	14.75	11.18	1.29	79054.00
11	16.28	4.88	97.50	3.16	15.44	10.90	1.34	79944.00
12	13.64	11.00	95.93	3.30	15.49	10.79	1.33	79876.00
13	15.54	13.99	101.25	3.88	15.19	11.10	1.32	78658.00
14	13.33	8.26	99.46	3.58	15.59	11.14	1.32	79349.00
15	13.06	6.74	100.18	3.69	15.03	11.05	1.29	78240.00
16	10.50	11.24	92.49	3.73	15.09	10.99	1.32	75397.00
17	11.29	12.91	91.74	3.97	15.41	10.77	1.34	74686.00
18	15.10	9.91	92.12	3.61	16.19	10.54	1.31	78689.00
19	15.71	9.03	99.17	3.11	16.93	10.75	1.30	80910.00
20	14.46	6.53	99.17	3.35	16.29	10.76	1.28	78475.00
21	17.23	19.94	98.74	4.17	15.57	10.86	1.30	77972.00
22	19.11	11.35	91.54	6.24	14.82	10.74	1.28	78340.00
23	14.27	12.03	97.68	3.28	15.75	10.95	1.26	80610.00
24	15.79	9.89	88.78	3.79	15.15	11.06	1.26	79000.00
25	15.31	13.12	87.71	3.38	15.63	10.59	1.31	77913.00
26	14.74	11.77	91.14	3.42	16.12	10.72	1.30	78894.00
27	15.76	8.25	89.37	3.05	16.77	10.61	1.32	78491.00
28	17.47	6.94	88.39	4.39	16.49	10.68	1.34	79068.00
29	16.66	5.37	83.74	2.31	16.65	10.69	1.36	77409.00
30	15.42	7.16	86.02	2.54	17.19	10.54	1.39	79806.00
平均值	15.26	9.66	94.06	3.69	15.75	10.80	1.31	78036.30
最大值	19.11	19.94	101.25	6.24	17.19	11.18	1.39	80910.00
最小值	10.50	3.69	83.74	2.31	14.75	10.47	1.24	73981.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。