

P001_樹林焚化廠CEMS系統月報表

報表日期: 2022年09月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	11.51	7.99	49.59	0.37	18.36	11.86	1.68	64402.00
2	11.39	4.24	43.13	0.13	19.20	11.58	1.77	64448.00
3	11.53	5.10	44.63	0.14	19.37	11.94	1.83	61732.00
4	11.85	4.51	39.62	0.13	19.66	11.46	1.77	65144.00
5	11.42	4.19	45.33	0.27	19.43	11.75	1.63	62616.00
6	12.49	3.44	49.83	0.14	18.78	11.93	1.52	61263.00
7	12.27	3.40	50.56	0.14	18.83	11.80	1.49	62535.00
8	11.17	3.83	53.39	0.14	17.42	12.08	1.48	60756.00
9	12.18	4.05	46.90	0.13	17.25	12.13	1.45	61647.00
10	8.91	5.88	53.46	0.28	17.95	12.59	1.49	59678.00
11	11.31	5.26	52.34	0.18	19.94	12.31	1.48	59081.00
12	9.88	4.89	48.89	0.17	19.35	12.16	1.50	61918.00
13	9.54	4.87	45.99	0.16	17.72	12.20	1.46	62030.00
14	9.84	4.21	43.53	0.15	18.38	12.06	1.41	63485.00
15	11.47	3.17	42.93	0.15	18.43	11.87	1.41	66549.00
16	11.84	4.44	44.67	0.14	17.52	11.90	1.37	67060.00
17	11.44	4.04	42.46	0.19	18.26	11.89	1.34	66422.00
18	10.61	3.47	46.85	0.17	18.52	11.83	1.39	66354.00
19	11.16	4.46	43.71	0.19	17.80	12.00	1.36	67305.00
20	11.84	3.33	43.48	0.16	16.97	11.88	1.35	67395.00
21	11.63	5.50	43.24	0.24	16.41	12.15	1.34	65284.00
22	11.69	3.87	45.57	0.22	17.84	11.82	1.36	68613.00
23	11.90	4.41	47.77	0.19	17.44	11.98	1.37	68668.00
24	11.24	4.67	47.80	0.17	18.24	11.87	1.36	69057.00
25	11.09	4.07	43.10	0.16	19.18	11.51	1.37	70548.00
26	11.10	5.22	49.86	0.14	18.74	11.61	1.38	69867.00
27	11.79	5.39	48.60	0.13	18.49	11.67	1.37	69454.00
28	11.94	5.14	49.21	0.15	17.96	11.87	1.32	67886.00
29	11.49	3.17	48.99	0.13	18.32	11.67	1.33	68926.00
30	10.94	5.42	47.88	0.13	18.66	11.71	1.33	68871.00
平均值	11.28	4.52	46.78	0.17	18.35	11.90	1.46	65299.80
最大值	12.49	7.99	53.46	0.37	19.94	12.59	1.83	70548.00
最小值	8.91	3.17	39.62	0.13	16.41	11.46	1.32	59081.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P002_樹林焚化廠CEMS系統月報表

報表日期: 2022年09月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	12.17	3.91	62.49	0.19	16.73	11.62	1.60	81561.00
2	11.07	4.30	56.03	0.24	17.74	11.25	1.59	84143.00
3	12.56	3.62	61.15	0.16	18.21	11.36	1.69	82938.00
4	12.38	3.75	55.00	0.16	18.18	11.16	1.64	85228.00
5	12.15	3.37	55.88	0.23	18.06	11.31	1.61	83127.00
6	12.95	3.93	56.26	0.22	17.24	11.64	1.51	80979.00
7	13.16	2.66	58.16	0.23	17.45	11.41	1.46	84056.00
8	13.05	3.27	56.99	0.19	16.63	11.55	1.42	83513.00
9	12.34	2.89	57.78	0.13	16.58	11.70	1.42	81818.00
10	12.20	2.43	49.43	0.16	17.54	11.22	1.44	85106.00
11	11.86	2.63	51.45	0.20	18.35	11.28	1.42	83164.00
12	11.20	2.35	56.17	0.16	18.43	11.21	1.39	83641.00
13	11.08	4.64	54.25	0.16	17.93	11.47	1.43	81775.00
14	11.28	4.19	51.68	0.16	17.85	11.43	1.53	82481.00
15	11.30	2.75	52.89	0.24	18.24	11.06	1.50	86181.00
16	11.59	2.88	52.06	0.22	17.43	11.34	1.49	84349.00
17	12.50	3.79	47.27	0.31	18.13	11.10	1.46	85384.00
18	11.57	3.83	46.81	0.28	18.86	10.93	1.43	86104.00
19	11.53	3.76	52.41	0.16	17.20	11.47	1.40	83169.00
20	11.94	4.27	52.99	0.15	16.75	11.39	1.37	84046.00
21	11.50	3.22	52.76	0.20	17.33	11.32	1.36	83628.00
22	12.19	2.78	52.96	0.31	17.46	11.08	1.38	85563.00
23	11.74	4.30	51.61	0.17	17.33	11.33	1.39	83818.00
24	11.61	5.10	50.37	0.18	18.05	11.20	1.37	84557.00
25	12.01	4.05	48.78	0.17	18.84	11.05	1.38	84819.00
26	11.44	3.99	53.42	0.16	18.67	11.19	1.40	83460.00
27	12.04	5.06	49.87	0.14	18.25	11.09	1.43	85481.00
28	12.50	6.06	47.47	0.31	17.11	11.26	1.47	84468.00
29	11.32	3.28	48.22	0.25	18.24	11.05	1.45	84252.00
30	11.08	5.43	53.24	0.18	18.25	11.18	1.44	83599.00
平均值	11.91	3.75	53.20	0.20	17.77	11.29	1.46	83880.27
最大值	13.16	6.06	62.49	0.31	18.86	11.70	1.69	86181.00
最小值	11.07	2.35	46.81	0.13	16.58	10.93	1.36	80979.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。

P003_樹林焚化廠CEMS系統月報表

報表日期: 2022年09月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	12.53	5.40	60.27	1.78	16.96	10.64	1.85	76984.00
2	12.16	5.40	51.79	1.73	17.00	10.47	1.92	74508.00
3	12.10	5.07	53.31	1.28	18.01	10.77	1.99	74608.00
4	12.86	6.00	51.81	1.51	17.44	10.62	1.87	75223.00
5	11.11	6.19	53.53	0.53	17.55	10.95	1.74	78296.00
6	12.04	5.23	51.91	0.75	16.45	11.59	1.63	73243.00
7	13.29	3.53	48.72	0.98	16.81	10.92	1.55	74022.00
8	12.24	3.86	53.06	1.02	15.28	11.19	1.48	72444.00
9	12.92	5.68	45.33	0.91	16.10	10.78	1.43	71464.00
10	12.56	3.87	45.73	0.57	16.65	10.57	1.41	73357.00
11	11.94	3.24	51.83	0.69	18.08	10.38	1.35	74713.00
12	12.18	4.46	51.68	0.47	17.81	10.66	1.30	76174.00
13	11.20	4.96	51.61	0.66	17.61	10.72	1.26	74733.00
14	11.18	3.94	51.54	0.78	17.49	10.76	1.31	75530.00
15	11.68	2.86	49.45	0.78	17.15	11.10	1.42	73863.00
16	10.00	10.02	54.96	1.89	14.56	12.07	1.29	77318.00
17	12.12	5.60	50.05	1.04	16.13	11.19	1.34	71716.00
18	11.81	4.76	53.70	0.83	17.44	10.78	1.31	75398.00
19	11.53	4.76	50.61	0.76	16.49	10.88	1.29	74894.00
20	12.02	4.40	48.85	0.55	15.81	11.05	1.26	73930.00
21	12.18	5.04	51.30	1.39	15.02	11.13	1.26	72675.00
22	11.94	3.64	50.39	1.32	15.37	11.01	1.24	72756.00
23	12.02	3.55	49.81	1.37	15.12	11.31	1.22	72635.00
24	11.73	3.89	48.27	1.07	15.72	11.29	1.23	73234.00
25	12.19	3.70	47.13	0.88	17.00	10.88	1.25	75491.00
26	11.20	4.25	49.98	1.01	16.69	11.02	1.25	73994.00
27	11.99	6.74	49.40	1.10	16.43	10.99	1.22	74184.00
28	11.96	3.77	51.26	0.71	16.28	10.91	1.21	74817.00
29	11.53	4.22	54.29	0.59	16.67	10.89	1.20	75345.00
30	10.87	4.30	47.57	0.62	16.96	10.79	1.20	76136.00
平均值	11.90	4.74	50.97	0.99	16.60	10.94	1.41	74456.17
最大值	13.29	10.02	60.27	1.89	18.08	12.07	1.99	78296.00
最小值	10.00	2.86	45.33	0.47	14.56	10.38	1.20	71464.00

備註： 1.*:儀器保養維護中。

2.**:停爐中。