

P001\_樹林焚化廠CEMS系統月報表

報表日期: 2023年10月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	3.99	8.24	49.27	1.20	17.48	11.69	1.01	72083.00
2	3.29	8.67	48.65	0.99	17.64	11.67	1.02	72097.00
3	3.82	6.97	48.49	1.52	17.63	11.62	0.99	71825.00
4	7.28	6.53	46.54	1.06	19.62	11.25	1.01	73800.00
5	8.13	7.28	46.90	1.40	18.27	11.48	1.02	73717.00
6	7.27	5.78	55.46	1.31	18.24	11.54	1.04	73372.00
7	8.65	8.43	56.22	1.23	19.23	11.21	1.03	74217.00
8	7.82	8.78	56.84	1.53	18.47	11.34	1.02	73931.00
9	7.79	6.91	56.04	1.29	18.10	11.41	1.01	74495.00
10	6.48	8.32	57.85	1.32	18.03	11.45	1.04	73957.00
11	6.84	6.98	55.80	1.35	18.10	11.24	1.07	74951.00
12	5.66	7.22	52.59	1.31	17.66	11.26	1.09	76322.00
13	8.46	8.54	56.08	1.40	17.92	11.15	1.11	75409.00
14	7.53	8.82	54.42	1.17	18.51	11.09	1.12	74761.00
15	7.48	9.79	56.15	1.23	17.89	11.26	1.10	75049.00
16	7.04	10.38	55.06	1.23	16.96	11.29	1.09	75203.00
17	5.72	9.85	53.71	1.06	18.33	11.19	1.08	74861.00
18	7.81	8.96	50.77	0.92	19.31	10.82	1.07	75706.00
19	6.24	7.68	51.19	0.85	18.00	11.13	1.04	74087.00
20	6.67	5.91	49.10	0.80	19.17	11.00	1.04	75048.00
21	7.72	7.52	50.65	1.01	18.08	11.30	1.05	75014.00
22	3.39	8.24	52.00	1.13	17.28	11.18	1.02	74681.00
23	6.75	8.51	50.00	1.07	18.49	10.89	1.07	75292.00
24	6.50	9.48	51.57	1.29	18.77	10.83	1.09	76227.00
25	5.86	8.39	54.23	1.52	17.62	11.36	1.09	73422.00
26	5.46	9.10	55.47	1.05	17.97	11.27	1.10	73840.00
27	8.57	7.72	53.37	1.17	18.37	11.08	1.09	75487.00
28	8.56	8.10	55.27	1.05	17.88	11.25	1.08	75813.00
29	8.34	7.29	51.81	1.14	18.74	11.08	1.04	75471.00
30	8.56	8.96	48.76	1.13	18.54	11.10	1.07	74641.00
31	4.29	9.00	53.44	1.22	17.25	11.43	1.09	74156.00
平均值	6.71	8.14	52.70	1.19	18.18	11.25	1.06	74481.77
最大值	8.65	10.38	57.85	1.53	19.62	11.69	1.12	76322.00
最小值	3.29	5.78	46.54	0.80	16.96	10.82	0.99	71825.00

備註： 1.\*:儀器保養維護中。

2.\*\*:停爐中。

P002\_樹林焚化廠CEMS系統月報表

報表日期: 2023年10月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	5.00	6.14	48.92	1.81	17.11	10.30	1.01	85411.00
2	6.73	5.99	50.32	1.32	18.02	10.17	1.02	85649.00
3	2.43	6.24	49.96	1.71	17.39	10.38	1.02	84353.00
4	7.98	6.16	51.53	1.90	17.36	10.38	1.00	84502.00
5	7.09	5.15	49.75	1.53	18.18	10.26	1.00	84673.00
6	5.02	6.84	53.62	2.18	17.31	10.57	1.02	84786.00
7	7.51	6.03	59.81	2.34	16.95	10.54	1.05	84001.00
8	7.24	6.62	57.23	2.20	17.84	10.32	1.03	85745.00
9	6.33	5.32	54.45	1.71	17.65	10.25	1.04	85853.00
10	6.88	4.71	54.84	2.02	17.36	10.33	1.06	85311.00
11	7.35	4.83	47.48	1.93	18.56	10.22	1.06	87320.00
12	6.42	5.29	51.65	2.05	17.12	10.30	1.07	85684.00
13	6.98	4.62	55.91	2.15	16.79	10.48	1.05	84658.00
14	7.82	6.19	52.23	2.03	17.09	10.38	1.07	85417.00
15	7.88	6.57	58.12	1.67	17.01	10.30	1.06	85608.00
16	6.36	6.17	56.05	1.37	17.19	10.29	1.07	85529.00
17	4.22	6.95	54.80	1.84	17.18	10.18	1.06	85813.00
18	6.30	5.18	55.11	1.55	17.60	10.12	1.05	85861.00
19	5.21	5.42	53.07	1.75	17.79	10.11	1.02	85995.00
20	5.89	5.48	57.48	2.51	17.22	10.29	1.03	85588.00
21	4.39	5.31	57.38	2.40	16.67	10.53	1.00	84278.00
22	3.81	5.78	52.50	1.83	17.81	10.39	1.01	84243.00
23	7.59	5.96	54.33	1.46	16.89	10.51	1.03	84256.00
24	4.13	6.35	55.07	2.05	16.98	10.34	1.04	85333.00
25	4.29	4.98	53.88	2.00	17.33	10.22	1.03	86087.00
26	5.56	6.00	54.86	1.90	17.15	10.28	1.03	85041.00
27	5.06	5.50	54.20	2.09	17.57	10.35	0.99	84554.00
28	5.21	6.10	56.40	2.45	17.00	10.53	0.99	84411.00
29	6.44	5.42	53.90	2.18	17.05	10.42	0.97	84549.00
30	5.87	6.10	51.95	1.59	16.60	10.55	0.97	84094.00
31	4.38	6.64	47.13	2.08	17.26	10.46	0.96	83980.00
平均值	5.92	5.81	53.68	1.92	17.32	10.35	1.03	85115.58
最大值	7.98	6.95	59.81	2.51	18.56	10.57	1.07	87320.00
最小值	2.43	4.62	47.13	1.32	16.60	10.11	0.96	83980.00

備註： 1.\*:儀器保養維護中。

2.\*\*:停爐中。

P003\_樹林焚化廠CEMS系統月報表

報表日期: 2023年10月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	3.32	6.31	49.88	1.49	18.45	10.75	0.94	76422.00
2	3.86	4.81	52.74	1.40	15.23	10.82	0.95	77348.00
3	3.09	5.64	49.90	1.59	15.54	10.87	0.98	77376.00
4	7.42	6.25	48.45	1.75	16.23	11.01	0.99	78622.00
5	7.82	7.84	51.22	1.49	16.49	10.63	1.00	78035.00
6	7.41	6.34	47.26	1.87	16.25	10.41	1.00	78349.00
7	9.32	6.77	51.07	2.12	15.56	10.65	0.99	79444.00
8	8.79	7.66	50.68	1.93	15.93	10.59	0.98	80108.00
9	6.21	5.38	50.04	1.38	17.21	10.49	0.98	81202.00
10	5.85	6.36	47.09	1.63	16.02	10.55	0.95	77468.00
11	6.66	6.85	49.10	1.41	16.09	10.45	0.96	79067.00
12	4.78	6.13	52.42	1.28	15.62	10.68	0.97	79375.00
13	6.21	5.38	50.99	1.27	15.98	10.86	0.97	79438.00
14	8.98	5.75	52.59	1.59	15.38	10.86	0.98	77469.00
15	9.08	7.69	50.70	1.25	16.15	10.48	0.97	79244.00
16	7.06	5.67	54.71	1.15	15.33	10.70	0.99	78990.00
17	4.98	6.27	53.64	1.21	15.29	10.91	1.01	79219.00
18	5.93	5.86	47.70	1.16	15.69	10.58	1.03	77853.00
19	7.56	6.52	50.21	1.13	15.85	10.63	1.03	79717.00
20	7.21	5.64	48.19	1.23	16.05	10.57	1.02	79626.00
21	5.76	7.49	50.20	1.65	15.27	10.84	0.99	77912.00
22	4.05	6.97	45.43	1.66	14.65	11.00	1.00	73440.00
23	7.32	6.13	51.80	1.58	14.64	11.07	1.02	80082.00
24	6.59	6.34	50.13	1.67	15.75	10.76	1.00	81107.00
25	6.21	7.05	50.40	1.81	15.52	10.77	0.97	77105.00
26	4.70	5.20	51.24	1.26	16.10	10.54	1.00	78642.00
27	5.26	6.22	50.39	1.41	16.03	10.89	0.97	78824.00
28	7.10	6.98	51.91	1.69	15.33	11.06	0.96	78342.00
29	6.07	5.94	48.25	1.48	15.86	10.87	0.94	78262.00
30	5.36	5.79	48.29	1.57	15.31	10.76	0.92	76890.00
31	6.02	6.19	52.00	1.88	14.63	11.16	0.94	83878.00
平均值	6.32	6.30	50.28	1.52	15.79	10.75	0.98	78672.77
最大值	9.32	7.84	54.71	2.12	18.45	11.16	1.03	83878.00
最小值	3.09	4.81	45.43	1.13	14.63	10.41	0.92	73440.00

備註： 1.\*:儀器保養維護中。

2.\*\*:停爐中。