

P001\_樹林焚化廠CEMS系統月報表

報表日期: 2022年06月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	14.29	7.87	51.30	0.55	16.87	11.81	1.46	74388.00
2	13.81	6.39	54.39	0.54	17.01	11.75	1.44	77634.00
3	13.74	7.64	53.24	0.83	17.31	11.73	1.46	78314.00
4	11.47	5.45	47.87	1.04	16.20	12.20	1.43	76161.00
5	13.60	5.42	50.04	0.68	17.36	11.77	1.44	79037.00
6	13.54	7.67	52.07	0.79	16.39	11.99	1.47	78155.00
7	13.72	9.91	45.68	0.88	16.63	11.77	1.51	78511.00
8	13.95	6.55	49.61	0.79	16.71	11.90	1.55	79499.00
9	13.53	4.65	59.00	0.34	17.69	11.83	1.58	78967.00
10	14.24	7.51	57.75	0.22	18.18	11.71	1.57	79517.00
11	14.34	7.95	49.49	0.57	17.94	11.63	1.56	80996.00
12	14.53	8.36	51.10	0.37	18.48	11.43	1.56	81827.00
13	13.45	8.63	56.77	0.26	17.90	11.63	1.56	80835.00
14	13.08	7.17	51.52	0.33	18.24	11.44	1.57	81823.00
15	14.33	9.00	54.19	0.44	18.25	11.54	1.58	80966.00
16	14.65	7.08	51.85	0.65	16.94	11.71	1.52	80665.00
17	13.73	8.50	58.78	0.48	17.71	11.85	1.53	79200.00
18	13.32	6.55	59.03	0.46	17.64	11.90	1.53	79143.00
19	13.37	6.20	54.63	0.60	18.03	11.83	1.49	79861.00
20	13.36	7.15	55.25	0.81	16.93	11.94	1.49	79132.00
21	13.32	6.01	49.91	0.63	17.33	11.74	1.46	80274.00
22	13.68	7.20	51.09	1.27	17.15	11.81	1.46	80528.00
23	13.67	6.88	52.03	0.80	16.93	11.90	1.49	80793.00
24	13.24	6.19	52.60	1.30	17.32	11.79	1.51	80752.00
25	12.68	7.68	56.07	1.03	17.57	11.75	1.54	81832.00
26	14.14	5.87	50.56	0.92	18.16	11.50	1.53	83377.00
27	13.42	6.54	55.76	1.11	17.24	11.78	1.55	81964.00
28	13.57	5.39	53.64	0.65	17.76	11.68	1.53	81627.00
29	13.70	6.44	49.65	0.73	17.75	11.64	1.54	81277.00
30	14.33	6.67	49.69	1.60	17.04	11.71	1.52	81995.00
平均值	13.66	7.02	52.82	0.72	17.42	11.76	1.51	79968.33
最大值	14.65	9.91	59.03	1.60	18.48	12.20	1.58	83377.00
最小值	11.47	4.65	45.68	0.22	16.20	11.43	1.43	74388.00

備註： 1.\*:儀器保養維護中。

2.\*\*:停爐中。

P002\_樹林焚化廠CEMS系統月報表

報表日期: 2022年06月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	14.00	6.12	57.23	0.16	18.33	10.92	1.48	88728.00
2	13.29	5.82	56.55	0.13	18.45	10.66	1.48	90531.00
3	13.55	6.26	51.91	0.31	18.31	10.76	1.46	89769.00
4	13.14	4.40	49.24	0.26	17.52	11.11	1.46	84925.00
5	13.84	5.02	52.32	0.18	18.52	10.68	1.44	89451.00
6	13.67	6.11	52.85	0.23	17.22	10.86	1.44	88043.00
7	12.31	6.18	57.05	0.42	17.30	10.95	1.47	86496.00
8	14.66	5.62	58.81	0.45	17.34	10.75	1.44	89995.00
9	13.69	3.67	57.71	0.20	18.28	10.64	1.47	90151.00
10	14.22	5.81	58.21	0.16	18.95	10.56	1.46	91922.00
11	14.29	5.72	59.45	0.27	18.32	10.65	1.46	91291.00
12	14.23	6.09	56.98	0.18	18.62	10.53	1.46	91367.00
13	13.62	5.64	55.62	0.13	18.18	10.69	1.47	89248.00
14	12.54	5.79	47.42	0.46	18.41	10.28	1.44	86734.00
15	14.53	6.27	53.54	0.88	17.93	10.47	1.43	89564.00
16	15.00	6.58	58.97	0.32	16.81	10.92	1.45	87817.00
17	11.16	3.43	56.52	0.44	18.13	10.81	1.47	91225.00
18	8.27	6.47	58.09	0.27	17.42	10.96	1.46	89745.00
19	12.65	5.38	51.76	0.49	17.69	10.94	1.45	88136.00
20	13.41	5.22	51.64	0.18	18.72	10.44	1.47	91076.00
21	13.63	5.27	60.49	0.37	17.35	10.98	1.42	87733.00
22	13.87	6.90	54.51	0.98	17.47	10.65	1.38	85905.00
23	14.17	4.28	53.05	0.33	17.45	10.74	1.37	83933.00
24	13.46	5.52	55.82	0.40	17.71	10.78	1.38	86235.00
25	13.25	5.89	56.39	0.47	17.10	10.95	1.40	84481.00
26	13.44	4.57	54.63	0.44	17.55	10.75	1.43	85581.00
27	12.48	4.95	57.33	0.41	16.77	10.89	1.43	83903.00
28	13.23	3.94	57.47	0.28	17.66	10.79	1.44	85595.00
29	13.47	5.65	58.71	0.21	17.48	10.96	1.45	83580.00
30	13.30	6.02	56.82	0.52	16.53	11.05	1.44	82754.00
平均值	13.35	5.49	55.57	0.35	17.78	10.77	1.44	87863.80
最大值	15.00	6.90	60.49	0.98	18.95	11.11	1.48	91922.00
最小值	8.27	3.43	47.42	0.13	16.53	10.28	1.37	82754.00

備註： 1.\*:儀器保養維護中。

2.\*\*:停爐中。

P003\_樹林焚化廠CEMS系統月報表

報表日期: 2022年06月

項目	氯化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	14.88	5.71	57.63	1.42	17.06	10.28	1.30	71115.00
2	14.08	5.41	53.36	2.00	16.47	10.17	1.28	70653.00
3	14.18	6.72	48.81	2.25	17.07	10.34	1.27	73050.00
4	11.64	4.83	52.01	2.06	17.02	10.20	1.32	70738.00
5	14.03	5.73	54.18	2.04	17.82	9.76	1.36	73961.00
6	13.88	4.90	58.00	2.76	16.11	10.52	1.38	75058.00
7	14.37	7.48	51.41	2.58	16.35	10.72	1.33	74313.00
8	15.11	6.53	54.11	2.66	15.88	11.06	1.35	76211.00
9	14.67	5.12	53.59	2.52	16.15	10.76	1.35	73225.00
10	15.15	6.98	47.87	1.90	16.95	10.36	1.37	72519.00
11	14.57	5.30	54.85	1.75	17.09	10.24	1.41	73466.00
12	15.14	7.14	53.81	1.94	17.22	10.05	1.43	73165.00
13	14.06	6.90	55.37	1.56	17.46	10.00	1.46	72440.00
14	13.25	6.97	45.48	1.50	17.52	10.11	1.49	73175.00
15	14.71	8.18	56.19	2.64	17.52	9.82	1.47	75576.00
16	14.70	6.40	56.97	2.35	16.05	10.37	1.46	71136.00
17	16.14	6.48	55.12	2.55	16.88	10.38	1.44	73130.00
18	14.53	6.85	53.25	2.37	16.67	10.30	1.45	73289.00
19	13.99	5.52	49.91	2.60	16.38	10.24	1.42	70168.00
20	14.37	5.86	53.10	2.38	16.58	9.91	1.41	72807.00
21	14.01	5.75	52.10	2.28	16.65	10.08	1.42	72454.00
22	14.21	6.76	53.21	2.41	16.82	10.08	1.40	73660.00
23	14.94	5.56	53.86	2.33	16.49	10.11	1.41	73282.00
24	14.01	7.79	54.96	2.61	16.82	10.22	1.40	74561.00
25	14.08	6.75	54.43	2.31	16.70	10.30	1.40	72713.00
26	14.26	6.75	55.02	2.43	16.51	10.28	1.40	73546.00
27	13.38	3.76	55.10	2.21	16.25	10.18	1.43	72057.00
28	13.55	5.12	50.47	1.99	17.05	10.17	1.43	73836.00
29	14.42	7.23	48.58	2.41	16.65	10.12	1.42	72654.00
30	15.25	6.73	54.43	2.38	15.88	10.37	1.40	74133.00
平均值	14.32	6.24	53.24	2.24	16.74	10.25	1.40	73069.70
最大值	16.14	8.18	58.00	2.76	17.82	11.06	1.49	76211.00
最小值	11.64	3.76	45.48	1.42	15.88	9.76	1.27	70168.00

備註： 1.\*:儀器保養維護中。

2.\*\*:停爐中。