

P001\_樹林焚化廠CEMS系統月報表

報表日期: 2024年3月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm <sup>3</sup> /Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	9.32	5.53	53.97	2.17	14.98	11.91	1.03	81199.00
2	9.00	6.81	50.81	1.75	15.60	11.91	1.08	80944.00
3	8.53	6.23	52.22	1.54	16.34	11.71	1.08	81511.00
4	8.22	6.91	51.63	1.60	16.16	11.62	1.09	80538.00
5	8.58	6.39	48.84	1.88	15.95	11.66	1.08	79359.00
6	8.30	4.83	46.49	2.48	15.64	11.38	1.04	80494.00
7	8.45	5.54	47.70	2.10	15.51	11.64	1.02	81019.00
8	9.83	6.33	53.98	2.34	14.21	11.75	1.05	81047.00
9	8.33	6.54	54.85	2.25	14.00	11.80	1.03	78872.00
10	7.34	7.27	54.12	1.27	16.94	11.47	1.04	82201.00
11	7.93	6.66	50.09	1.63	16.44	11.52	1.02	81361.00
12	8.01	7.21	54.05	1.78	15.90	11.59	1.03	81094.00
13	5.89	5.48	47.39	1.38	16.03	11.58	1.05	80873.00
14	8.04	5.18	52.38	2.14	14.93	11.69	1.04	78881.00
15	8.99	5.54	53.85	1.71	16.28	11.65	1.06	80100.00
16	8.75	7.02	54.24	1.74	15.82	11.65	1.09	79345.00
17	8.92	6.49	51.78	1.65	16.55	11.61	1.05	80736.00
18	7.72	5.02	52.86	1.98	15.36	11.90	1.04	79081.00
19	7.20	6.04	47.77	1.60	15.86	11.84	1.05	79743.00
20	8.55	5.83	52.38	2.01	15.70	11.55	1.04	81959.00
21	8.17	6.11	52.51	2.24	15.44	11.72	1.03	81285.00
22	6.20	6.15	53.96	1.64	16.27	11.56	1.05	80863.00
23	8.00	7.20	53.25	2.18	15.13	11.92	1.04	78352.00
24	6.32	7.60	51.43	1.85	16.08	11.84	1.06	78623.00
25	7.02	6.36	51.30	1.48	15.99	11.76	1.04	78370.00
26	5.43	5.78	51.27	1.72	14.96	11.88	1.01	78468.00
27	7.54	5.30	48.94	1.74	15.68	11.65	1.02	79733.00
28	8.23	6.22	51.92	1.65	16.34	11.53	1.02	79848.00
29	8.02	5.21	54.01	1.85	15.81	11.66	1.05	80611.00
30	7.05	4.90	52.05	2.26	15.57	11.89	1.04	78933.00
31	5.47	5.88	55.12	1.91	15.77	11.75	1.05	79382.00
平均值	7.85	6.11	51.84	1.86	15.72	11.70	1.05	80155.65
最大值	9.83	7.60	55.12	2.48	16.94	11.92	1.09	82201.00
最小值	5.43	4.83	46.49	1.27	14.00	11.38	1.01	78352.00

備註： 1.\*:儀器保養維護中。

2.\*\*:停爐中。

P002\_樹林焚化廠CEMS系統月報表

報表日期: 2024年3月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	9.18	3.94	51.34	2.90	14.62	11.59	1.07	78385.00
2	6.83	4.27	49.76	2.61	15.66	11.56	1.05	77877.00
3	8.14	4.04	46.86	2.81	16.11	11.30	1.05	79189.00
4	7.06	5.01	46.58	2.57	15.82	11.49	1.05	79355.00
5	7.03	4.12	49.83	2.89	16.33	11.47	1.05	78012.00
6	7.93	3.74	49.29	2.70	15.66	11.40	1.03	78788.00
7	6.10	3.81	50.29	2.60	15.66	11.39	1.03	79422.00
8	6.12	3.98	50.63	2.06	14.56	11.56	1.05	78939.00
9	6.31	4.70	51.99	2.57	14.94	11.53	1.03	78820.00
10	6.87	4.38	53.84	2.63	16.03	11.27	1.05	79357.00
11	6.29	3.94	50.84	2.86	15.30	11.45	1.05	78916.00
12	6.67	4.51	50.16	2.69	15.25	11.31	1.03	80115.00
13	5.12	3.24	56.58	2.49	15.49	11.33	1.03	79641.00
14	6.58	4.43	51.90	2.54	14.96	11.54	1.04	78138.00
15	6.53	4.71	52.43	2.82	14.87	11.48	1.04	78350.00
16	7.47	4.45	54.17	2.63	15.07	11.52	1.06	77877.00
17	6.55	3.91	50.19	2.33	16.09	11.46	1.05	77455.00
18	6.18	3.60	49.61	2.84	15.34	11.40	1.01	79108.00
19	3.15	3.60	55.83	2.59	14.93	11.49	1.01	78851.00
20	6.26	3.99	52.86	2.79	14.63	11.46	1.02	79774.00
21	6.37	3.81	49.58	2.82	14.28	11.57	1.02	78102.00
22	5.09	6.05	48.06	2.38	15.07	11.42	1.04	78246.00
23	8.39	3.89	56.12	2.47	14.81	11.41	1.06	78576.00
24	9.66	4.14	49.61	1.94	16.70	11.05	1.08	79568.00
25	10.37	4.33	50.79	2.58	15.34	11.50	1.07	77379.00
26	9.21	3.92	50.17	2.63	15.14	11.58	1.04	78216.00
27	5.49	4.10	50.21	2.65	15.80	11.35	1.04	78820.00
28	5.60	4.50	49.38	2.84	15.76	11.41	1.04	77882.00
29	5.03	4.32	46.51	2.79	15.36	11.65	1.02	76405.00
30	6.67	3.23	51.81	2.41	15.34	11.64	1.03	76591.00
31	4.61	3.72	51.11	2.44	15.36	11.57	1.03	76924.00
平均值	6.74	4.14	50.91	2.61	15.36	11.46	1.04	78486.39
最大值	10.37	6.05	56.58	2.90	16.70	11.65	1.08	80115.00
最小值	3.15	3.23	46.51	1.94	14.28	11.05	1.01	76405.00

備註： 1.\*:儀器保養維護中。

2.\*\*:停爐中。

P003\_樹林焚化廠CEMS系統月報表

報表日期: 2024年3月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	7.41	4.56	56.68	1.93	15.05	10.81	1.11	78886.00
2	6.07	5.02	57.43	1.14	15.97	10.95	1.11	78795.00
3	6.36	5.69	55.37	1.43	15.94	10.91	1.14	78111.00
4	6.37	6.29	52.16	1.33	15.57	10.82	1.14	76069.00
5	4.12	3.54	43.65	1.18	15.96	10.49	1.15	76843.00
6	4.73	4.15	51.57	1.50	15.46	10.77	1.11	77125.00
7	6.34	4.23	53.74	1.73	14.96	10.83	1.07	77727.00
8	5.15	4.73	54.47	1.28	15.13	10.76	1.05	78626.00
9	4.39	5.10	56.37	1.07	15.28	10.88	1.05	77742.00
10	3.98	4.52	55.06	0.91	15.99	10.63	1.06	77456.00
11	3.57	4.35	52.73	1.13	15.38	10.68	1.08	76454.00
12	2.49	5.63	53.60	0.89	15.52	10.41	1.12	76963.00
13	2.85	4.69	53.31	0.83	15.64	10.68	1.13	77656.00
14	5.05	4.66	49.85	1.25	15.23	10.55	1.11	77336.00
15	4.85	4.61	52.38	1.25	15.67	10.35	1.11	77172.00
16	8.98	5.24	56.99	2.06	14.99	10.67	1.12	76419.00
17	9.06	5.73	52.05	1.51	16.40	10.69	1.10	78984.00
18	4.69	4.14	50.90	1.16	16.45	10.57	1.07	79427.00
19	2.83	5.02	48.74	1.07	15.78	10.73	1.06	79171.00
20	4.17	5.39	54.23	1.29	15.10	10.68	1.08	77623.00
21	4.14	4.17	52.32	0.80	15.86	10.52	1.10	77064.00
22	4.14	7.74	50.68	1.60	14.95	11.10	1.09	76251.00
23	4.79	4.79	55.28	1.65	15.16	10.89	1.06	75246.00
24	6.26	4.64	54.46	1.69	15.92	10.86	1.03	77443.00
25	6.67	3.28	54.59	1.15	15.83	10.57	1.02	75339.00
26	5.31	3.91	53.46	1.11	15.19	10.61	1.01	76156.00
27	5.30	4.38	52.94	0.91	16.11	10.49	1.03	78259.00
28	6.75	4.17	56.26	1.17	16.54	10.50	1.01	79189.00
29	5.40	4.18	54.56	1.48	15.56	10.57	1.01	76963.00
30	6.63	3.42	51.31	1.52	15.54	10.72	1.03	78400.00
31	4.96	4.54	55.68	1.63	15.70	10.69	1.03	78886.00
平均值	5.28	4.73	53.32	1.31	15.61	10.69	1.08	77541.32
最大值	9.06	7.74	57.43	2.06	16.54	11.10	1.15	79427.00
最小值	2.49	3.28	43.65	0.80	14.95	10.35	1.01	75246.00

備註： 1.\*:儀器保養維護中。

2.\*\*:停爐中。