

## P001\_樹林焚化廠CEMS系統月報表

報表日期: 2022年08月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	13.36	7.05	45.71	0.46	19.05	11.07	1.66	83347.00
2	12.94	4.92	45.23	0.27	19.07	11.11	1.67	83174.00
3	13.98	5.00	44.97	0.26	18.78	11.25	1.69	83079.00
4	14.22	4.19	49.30	0.78	19.12	11.09	1.67	84945.00
5	14.73	6.05	47.70	0.50	18.15	11.30	1.65	84073.00
6	13.75	4.99	54.15	0.45	18.26	11.27	1.65	83688.00
7	13.25	5.01	53.96	0.18	18.61	11.23	1.62	83707.00
8	12.90	4.85	53.22	0.36	17.85	11.39	1.62	82791.00
9	13.65	4.16	55.37	0.56	18.32	11.33	1.60	83808.00
10	13.49	6.56	51.81	0.73	19.58	10.92	1.64	85886.00
11	13.64	4.32	48.23	0.76	18.80	11.02	1.67	84621.00
12	12.77	5.01	51.89	0.68	18.53	11.14	1.70	83520.00
13	12.80	4.58	48.72	0.32	19.03	11.07	1.73	84840.00
14	10.84	6.07	50.86	0.54	18.00	11.16	1.72	85746.00
15	12.76	3.52	50.38	0.45	18.34	10.77	1.67	88671.00
16	13.56	5.55	53.54	0.78	18.85	10.78	1.65	88115.00
17	13.45	4.79	49.08	0.56	18.92	10.66	1.65	88405.00
18	12.85	5.74	45.91	0.39	18.59	11.33	1.67	83351.00
19	13.21	5.85	51.00	0.43	18.71	11.36	1.71	83721.00
20	12.08	5.68	50.94	0.57	18.39	11.42	1.70	70990.00
21	12.57	4.82	49.63	0.63	18.91	11.10	1.69	68516.00
22	12.43	3.76	49.47	0.87	18.79	11.30	1.55	66987.00
23	13.22	4.70	47.64	0.67	18.80	11.28	1.47	67403.00
24	12.11	4.36	46.42	0.49	19.00	11.39	1.55	66276.00
25	12.34	5.43	46.44	0.35	18.58	11.41	1.63	65150.00
26	12.17	3.34	48.44	0.24	18.80	11.36	1.68	66033.00
27	12.02	4.34	53.98	0.46	17.52	11.98	1.67	61966.00
28	12.17	3.11	51.61	0.21	19.49	11.38	1.66	65113.00
29	12.64	3.21	48.31	0.44	18.56	11.28	1.67	65564.00
30	12.16	3.44	55.49	0.27	18.43	11.69	1.67	64202.00
31	12.58	3.57	50.31	0.13	19.54	11.58	1.69	64786.00
平均值	12.92	4.77	49.99	0.48	18.69	11.24	1.65	77499.16
最大值	14.73	7.05	55.49	0.87	19.58	11.98	1.73	88671.00
最小值	10.84	3.11	44.97	0.13	17.52	10.66	1.47	61966.00

備註： 1.\*:儀器保養維護中。

2.\*\*:停爐中。

P002\_樹林焚化廠CEMS系統月報表

報表日期: 2022年08月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	13.40	5.23	54.15	0.30	18.02	10.82	1.52	60395.00
2	14.14	4.21	55.98	0.19	17.56	11.03	1.53	61595.00
3	14.03	4.09	58.48	0.13	17.41	11.21	1.54	59829.00
4	13.53	4.64	56.63	0.24	17.44	11.12	1.57	60095.00
5	14.11	4.33	58.08	0.31	17.57	10.99	1.55	61798.00
6	14.02	5.49	55.04	0.36	16.80	11.15	1.55	61230.00
7	13.65	5.07	56.00	0.20	17.67	11.04	1.51	60997.00
8	13.11	4.32	58.03	0.18	17.71	10.97	1.54	61045.00
9	12.74	4.00	57.40	0.39	17.58	10.99	1.52	61946.00
10	13.16	4.79	56.14	0.37	17.79	10.87	1.51	61061.00
11	12.95	2.54	59.97	0.25	17.58	10.97	1.51	61575.00
12	13.05	3.81	58.73	0.32	17.47	10.96	1.50	61216.00
13	12.18	5.08	58.51	0.27	17.43	11.14	1.48	60553.00
14	10.68	3.48	51.57	0.69	16.97	11.09	1.45	72670.00
15	11.41	4.73	56.10	0.46	16.91	11.07	1.44	84336.00
16	12.07	5.04	56.97	0.29	16.56	11.32	1.44	80744.00
17	**	**	**	**	**	**	**	**
18	11.97	5.56	57.25	0.53	16.50	11.31	1.44	82431.00
19	12.30	5.34	58.27	0.67	16.97	11.14	1.46	83498.00
20	12.53	5.63	53.51	0.63	17.01	11.04	1.48	84448.00
21	10.74	3.70	54.97	0.42	16.97	11.36	1.50	82143.00
22	12.68	3.12	59.29	0.64	16.97	10.99	1.47	85594.00
23	12.26	4.52	55.41	0.90	16.79	10.97	1.42	85528.00
24	11.41	2.46	57.48	0.40	16.94	11.29	1.43	81060.00
25	12.39	3.47	56.96	0.36	16.79	11.15	1.43	83029.00
26	12.64	3.55	57.40	0.36	16.84	11.32	1.48	82622.00
27	12.94	2.74	58.41	0.51	16.14	11.18	1.53	84081.00
28	11.93	2.80	54.50	0.15	18.18	11.22	1.59	81680.00
29	11.61	3.75	57.24	0.30	17.09	11.32	1.58	82928.00
30	12.44	4.09	52.57	0.15	16.75	11.47	1.63	81752.00
31	12.67	2.74	57.42	0.15	17.93	11.23	1.64	83773.00
平均值	12.62	4.14	56.62	0.37	17.21	11.12	1.51	73188.40
最大值	14.14	5.63	59.97	0.90	18.18	11.47	1.64	85594.00
最小值	10.68	2.46	51.57	0.13	16.14	10.82	1.42	59829.00

備註： 1.\*:儀器保養維護中。

2.\*\*:停爐中。

## P003\_樹林焚化廠CEMS系統月報表

報表日期: 2022年08月

項目	氟化氫	一氧化碳	氮氧化物	二氧化硫	水含量	氧氣	不透光率	流量
單位	ppm	ppm	ppm	ppm	%	%	%	Nm3/Hour
小時\限標	60.00	150.00	220.00	150.00	40.00	20.95	20.00	999999.00
1	12.32	7.58	48.11	1.37	17.23	10.12	1.48	73456.00
2	13.15	4.99	53.46	1.35	17.20	10.25	1.49	73000.00
3	13.68	5.45	50.14	1.22	17.15	10.12	1.51	72897.00
4	13.98	4.73	53.84	1.36	16.97	10.28	1.53	72026.00
5	13.62	4.20	54.60	1.42	16.79	10.32	1.54	73010.00
6	13.31	6.48	49.95	1.43	17.24	10.12	1.55	73744.00
7	12.49	5.42	52.65	1.26	17.38	10.04	1.59	72804.00
8	11.61	3.47	57.83	1.69	16.71	10.38	1.62	72244.00
9	12.78	6.22	56.16	2.19	17.02	10.22	1.63	72713.00
10	12.18	5.87	58.16	2.90	17.76	10.17	1.63	71048.00
11	12.87	4.12	55.93	2.62	17.33	10.11	1.67	73159.00
12	12.42	6.49	52.91	2.41	17.55	9.99	1.65	73788.00
13	12.80	5.53	54.19	2.47	17.72	9.86	1.62	73977.00
14	12.71	5.91	48.35	2.30	18.00	9.76	1.58	73148.00
15	**	**	**	**	**	**	**	**
16	11.80	6.82	56.62	4.29	16.85	10.39	1.45	70459.00
17	8.44	5.28	54.78	2.80	16.80	10.31	1.45	70969.00
18	6.26	7.16	54.11	1.76	16.75	10.58	1.52	68494.00
19	8.44	7.81	53.65	1.88	16.97	10.65	1.54	68124.00
20	12.68	6.57	58.92	2.35	16.32	10.86	1.53	67475.00
21	12.19	5.96	53.22	2.71	16.53	10.20	1.49	72272.00
22	12.52	5.85	53.41	5.05	16.19	10.26	1.44	71287.00
23	11.93	6.20	57.39	3.48	15.38	10.84	1.60	66203.00
24	12.37	6.72	46.16	2.58	16.87	10.08	1.74	74450.00
25	13.00	6.78	49.84	3.04	16.84	10.02	1.77	72568.00
26	12.65	3.69	49.02	2.47	17.19	10.15	1.83	73546.00
27	12.68	4.11	50.61	2.61	15.94	10.41	1.84	71792.00
28	12.24	3.86	51.09	2.19	17.89	10.18	1.82	72933.00
29	8.72	7.38	55.69	2.60	16.35	11.10	1.80	62459.00
30	12.90	5.67	49.07	2.77	15.92	10.51	1.81	71057.00
31	12.65	5.43	48.24	2.02	17.18	10.27	1.83	73456.00
平均值	12.05	5.73	52.94	2.35	16.93	10.29	1.62	71618.60
最大值	13.98	7.81	58.92	5.05	18.00	11.10	1.84	74450.00
最小值	6.26	3.47	46.16	1.22	15.38	9.76	1.44	62459.00

備註： 1.\*:儀器保養維護中。

2.\*\*:停爐中。