

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年05月31日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.67	1.82	41.03	4.73	18.91	9.90	1.36	74225.62
1	7.42	1.71	53.38	5.08	18.85	10.29	1.34	73119.77
2	9.62	2.86	61.97	5.88	17.14	10.74	1.37	72179.00
3	8.43	13.80	56.77	6.40	15.23	11.31	1.37	69769.83
4	9.39	17.70	66.97	5.94	16.38	11.25	1.38	72072.97
5	11.54	17.47	46.39	5.20	16.56	11.24	1.38	73751.95
6	8.40	17.99	55.15	4.35	16.83	11.07	1.38	72123.60
7	6.26	4.55	61.10	4.16	16.13	11.27	1.38	71466.85
8	6.03	6.33	56.86	3.86	18.16	10.93	1.37	72863.58
9	9.91	13.69	58.96	4.46	18.08	10.39	1.37	73715.29
10	6.18	6.25	60.73	3.84	17.72	11.32	1.38	66594.28
11	3.89	4.92	59.60	3.42	18.06	10.18	1.37	71315.06
12	3.56	7.16	41.98	3.95	16.06	11.38	1.38	66661.36
13	6.27	7.37	54.21	4.53	15.98	11.25	1.38	68593.40
14	7.27	6.80	56.09	4.81	15.39	11.49	1.38	67262.70
15	5.17	4.73	58.05	4.23	15.76	11.48	1.38	68488.68
16	1.48	2.17	67.55	3.33	18.51	11.18	1.39	69547.97
17	5.28	5.02	49.57	3.71	18.69	9.33	1.37	74553.74
18	9.71	3.12	52.54	4.91	15.34	11.34	1.38	66546.25
19	10.72	2.03	59.14	4.61	15.94	11.29	1.38	69964.81
20	9.80	6.48	53.88	5.16	14.31	11.68	1.38	68466.90
21	9.57	3.05	59.16	4.54	14.99	11.39	1.38	68879.83
22	6.37	2.60	62.27	4.16	15.86	11.59	1.40	66881.08
23	8.29	3.50	49.44	4.08	16.66	10.72	1.39	71705.57
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.34	6.80	55.95	4.56	16.73	11.00	1.38	70447.92
最大值	11.54	17.99	67.55	6.40	18.91	11.68	1.41	74553.74
發生時間	5	6	16	3	0	20		17
最小值	1.48	1.71	41.03	3.33	14.31	9.33	1.33	66546.25
發生時間	16	1	0	16	20	17		18
零點偏移(率)	-0.21 %	-0.01 %	-0.29 %	-0.02 %		0.04	0.00	0.00 %
全幅偏移(率)	0.41 %	0.04 %	0.08 %	0.22 %		-0.20	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年05月31日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.58	1.78	51.32	1.54	18.66	9.79	1.38	79076.46
1	0.34	2.04	52.14	1.38	19.44	9.48	1.37	81730.63
2	2.73	3.53	60.98	2.25	16.75	9.83	1.36	81709.87
3	4.01	1.88	51.61	2.69	16.80	9.52	1.37	80838.71
4	5.05	3.44	60.93	2.35	18.34	9.26	1.37	83408.19
5	6.87	1.43	60.56	3.08	16.37	9.93	1.38	81620.19
6	2.91	9.70	49.86	1.46	20.07	8.78	1.38	82871.06
7	2.79	2.29	47.12	2.02	16.37	9.90	1.38	79464.81
8	2.37	3.92	47.51	1.85	17.01	9.97	1.40	76748.51
9	4.97	2.58	57.55	1.65	18.58	9.75	1.40	78280.36
10	5.57	4.80	49.61	1.98	18.05	9.79	1.40	82457.29
11	3.24	3.23	50.55	1.89	16.83	10.04	1.39	80650.58
12	4.36	12.50	56.83	1.76	19.91	8.74	1.40	85312.20
13	8.91	6.22	53.27	3.70	17.00	9.33	1.38	79220.11
14	10.18	1.57	51.82	3.05	18.73	9.00	1.40	83600.42
15	9.01	4.05	57.23	2.59	18.54	9.12	1.41	79464.51
16	10.00	1.32	56.84	2.26	19.69	8.55	1.41	81486.94
17	9.41	1.75	56.07	2.28	18.25	8.98	1.40	77514.83
18	10.16	1.75	56.84	2.14	18.22	9.19	1.40	79220.36
19	11.32	1.80	54.26	2.11	18.41	9.11	1.39	82517.63
20	9.21	4.83	43.06	2.29	17.64	9.04	1.38	80998.13
21	9.13	4.13	37.61	1.97	17.80	9.31	1.39	79603.55
22	10.23	2.14	50.92	2.30	17.46	9.33	1.38	80292.60
23	7.39	4.23	39.27	1.92	18.16	9.53	1.38	76908.48
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.28	3.62	52.24	2.19	18.05	9.39	1.39	80624.85
最大值	11.32	12.50	60.98	3.70	20.07	10.04	1.41	85312.20
發生時間	19	12	2	13	6	11		12
最小值	0.34	1.32	37.61	1.38	16.37	8.55	1.35	76748.51
發生時間	1	16	21	1	5	16		8
零點偏移(率)	-0.02 %	-0.01 %	-0.21 %	-0.07 %		0.02	0.00	0.00 %
全幅偏移(率)	0.05 %	0.00 %	-0.32 %	0.00 %		-0.18	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年05月31日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.75	2.30	58.35	4.17	17.36	10.23	1.37	79734.44
1	2.62	7.81	57.15	4.46	16.74	10.28	1.38	79888.73
2	2.59	10.19	54.37	4.84	14.68	10.55	1.38	77354.15
3	2.97	1.90	65.75	4.49	16.58	10.42	1.39	80726.76
4	1.81	4.76	57.54	4.24	17.94	9.96	1.38	80890.44
5	3.62	6.37	59.25	4.61	16.78	10.09	1.39	80348.55
6	6.65	3.17	57.60	4.69	17.03	9.97	1.39	80749.76
7	5.71	9.51	52.95	3.28	18.30	9.62	1.37	75054.09
8	7.75	3.62	60.07	3.25	16.75	10.54	1.37	77423.99
9	6.91	2.82	58.50	3.08	18.74	10.09	1.38	82893.54
10	8.10	6.91	56.00	3.16	17.63	10.21	1.38	82077.29
11	10.99	5.70	56.88	3.65	17.11	10.05	1.37	86465.95
12	10.74	8.74	55.09	3.86	18.08	9.41	1.39	86045.82
13	10.45	4.46	55.81	4.44	15.32	10.32	1.38	77839.34
14	11.48	4.27	61.23	3.74	17.87	10.24	1.38	81618.18
15	10.36	3.13	68.34	4.11	18.16	9.87	1.38	83826.64
16	8.97	5.50	51.94	3.23	17.42	10.11	1.38	82211.71
17	9.75	3.67	50.06	3.24	17.14	10.09	1.37	77844.51
18	9.61	2.14	60.88	3.08	17.50	10.28	1.38	79559.68
19	10.69	7.28	52.40	3.79	16.70	9.85	1.37	80866.46
20	9.38	4.67	57.38	4.61	15.48	10.00	1.36	77680.71
21	11.30	3.45	55.62	3.71	16.03	9.96	1.38	80518.79
22	7.64	2.62	58.35	3.84	14.90	10.25	1.39	78359.17
23	7.73	5.16	49.57	3.62	14.89	10.50	1.40	77577.32
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.57	5.01	57.13	3.88	16.88	10.12	1.38	80314.83
最大值	11.48	10.19	68.34	4.84	18.74	10.55	1.41	86465.95
發生時間	14	2	15	2	9	2		11
最小值	1.81	1.90	49.57	3.08	14.68	9.41	1.33	75054.09
發生時間	4	3	23	9	2	12		7
零點偏移(率)	-0.03 %	-0.00 %	-0.30 %	-0.08 %		0.01	0.00	0.00 %
全幅偏移(率)	1.21 %	0.74 %	-0.02 %	0.16 %		0.26	0.02	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								