

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年05月23日

| 項目 | #1-HCl_C | #1-CO_C | #1-NOx_C | #1-SO2_C | #1-H2O | #1-O2_C | #1-OPAC | #1-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位 | ppm | ppm | ppm | ppm | % | % | % | m3/Hour |
| 小時\限標 | 60.00 | 150.00 | 220.00 | 150.00 | 100.00 | 25.00 | 10.00 | 999999.00 |
| 0 | 9.80 | 13.12 | 48.23 | 2.13 | 16.32 | 11.73 | 1.15 | 78626.73 |
| 1 | 8.27 | 13.61 | 53.13 | 2.08 | 16.93 | 12.02 | 1.15 | 76372.00 |
| 2 | 10.80 | 13.24 | 54.33 | 2.41 | 17.37 | 11.58 | 1.15 | 80002.00 |
| 3 | 9.89 | 13.22 | 53.97 | 2.71 | 16.08 | 11.73 | 1.13 | 80181.04 |
| 4 | 8.50 | 13.60 | 51.17 | 3.04 | 15.27 | 11.92 | 1.13 | 78687.83 |
| 5 | 10.51 | 15.71 | 59.01 | 3.84 | 15.59 | 11.87 | 1.20 | 69831.43 |
| 6 | 10.43 | 13.88 | 55.49 | 1.36 | 14.87 | 12.06 | 1.20 | 77294.15 |
| 7 | 10.71 | 14.46 | 47.12 | 1.34 | 14.51 | 12.50 | 1.21 | 73116.24 |
| 8 | 7.62 | 13.28 | 54.46 | 2.58 | 15.81 | 11.71 | 1.23 | 79638.43 |
| 9 | 9.90 | 13.16 | 52.23 | 3.40 | 15.42 | 11.75 | 1.21 | 78509.56 |
| 10 | 6.69 | 13.20 | 55.19 | 2.83 | 15.71 | 11.77 | 1.20 | 77743.14 |
| 11 | 10.96 | 13.39 | 55.55 | 2.99 | 14.96 | 12.09 | 1.21 | 76110.21 |
| 12 | 12.97 | 14.01 | 51.19 | 3.15 | 14.56 | 11.84 | 1.20 | 74922.88 |
| 13 | 12.90 | 13.77 | 49.44 | 2.77 | 14.41 | 12.11 | 1.19 | 74300.30 |
| 14 | 3.86 | 13.51 | 57.35 | 1.33 | 15.33 | 12.01 | 1.18 | 75858.53 |
| 15 | 10.56 | 13.52 | 55.69 | 2.95 | 14.70 | 12.19 | 1.19 | 74533.91 |
| 16 | 10.25 | 13.34 | 62.77 | 2.96 | 15.16 | 12.04 | 1.19 | 75902.13 |
| 17 | 10.48 | 13.20 | 63.84 | 2.51 | 16.44 | 11.78 | 1.20 | 79015.04 |
| 18 | 6.68 | 13.71 | 59.85 | 2.34 | 15.37 | 12.06 | 1.19 | 77035.91 |
| 19 | 10.42 | 12.94 | 59.87 | 2.26 | 16.61 | 11.53 | 1.20 | 80169.30 |
| 20 | 7.45 | 12.92 | 61.64 | 1.94 | 17.53 | 11.34 | 1.19 | 80751.19 |
| 21 | 10.38 | 12.92 | 62.57 | 1.76 | 17.05 | 11.53 | 1.20 | 79634.77 |
| 22 | 9.67 | 13.09 | 51.81 | 2.39 | 16.54 | 11.53 | 1.18 | 79251.40 |
| 23 | 9.17 | 13.12 | 57.91 | 2.30 | 16.24 | 11.73 | 1.19 | 78007.53 |
| 監測時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 超限次數 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 有效時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 平均值 | 9.54 | 13.50 | 55.58 | 2.47 | 15.78 | 11.85 | 1.19 | 77312.32 |
| 最大值 | 12.97 | 15.71 | 63.84 | 3.84 | 17.53 | 12.50 | 1.24 | 80751.19 |
| 發生時間 | 12 | 5 | 17 | 5 | 20 | 7 | | 20 |
| 最小值 | 3.86 | 12.92 | 47.12 | 1.33 | 14.41 | 11.34 | 1.13 | 69831.43 |
| 發生時間 | 14 | 20 | 7 | 14 | 13 | 20 | | 5 |
| 零點偏移(率) | -0.06 % | 0.00 % | -0.01 % | -0.00 % | | -0.18 | -0.01 | 0.20 % |
| 全幅偏移(率) | 1.23 % | 2.01 % | 0.81 % | 1.16 % | | -0.14 | -0.06 | 0.20 % |
| 有效比率 | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % |
| 備註 | | | | | | | | |

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年05月23日

| 項目 | #2-HCl_C | #2-CO_C | #2-NOx_C | #2-SO2_C | #2-H2O | #2-O2_C | #2-OPAC | #2-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位 | ppm | ppm | ppm | ppm | % | % | % | m3/Hour |
| 小時\限標 | 60.00 | 150.00 | 220.00 | 150.00 | 100.00 | 25.00 | 10.00 | 999999.00 |
| 0 | 5.47 | 12.28 | 53.01 | 1.16 | 16.73 | 11.15 | 1.02 | 79181.01 |
| 1 | 7.60 | 12.19 | 58.34 | 1.35 | 18.05 | 10.90 | 1.02 | 80375.00 |
| 2 | 8.42 | 12.36 | 52.83 | 2.17 | 16.07 | 11.29 | 1.02 | 79233.21 |
| 3 | 7.10 | 12.24 | 57.07 | 1.29 | 16.88 | 11.09 | 1.02 | 80367.65 |
| 4 | 13.91 | 12.82 | 49.34 | 2.19 | 16.47 | 11.21 | 1.01 | 79720.06 |
| 5 | 1.81 | 12.82 | 49.57 | 2.42 | 15.79 | 11.47 | 0.99 | 77145.89 |
| 6 | 2.03 | 12.72 | 59.29 | 2.24 | 15.34 | 11.23 | 0.96 | 77229.40 |
| 7 | 2.55 | 13.35 | 56.25 | 2.89 | 14.30 | 11.93 | 0.96 | 73794.41 |
| 8 | 6.94 | 12.93 | 58.59 | 2.43 | 15.67 | 11.53 | 0.98 | 74784.02 |
| 9 | 12.16 | 11.81 | 56.49 | 1.55 | 17.47 | 10.64 | 0.97 | 79555.15 |
| 10 | 5.69 | 11.87 | 46.99 | 1.89 | 16.29 | 10.82 | 0.97 | 78461.05 |
| 11 | 11.24 | 12.08 | 54.90 | 1.68 | 17.16 | 10.93 | 0.96 | 77925.91 |
| 12 | 10.70 | 12.10 | 58.71 | 1.68 | 16.33 | 10.93 | 0.94 | 78331.11 |
| 13 | 10.26 | 12.12 | 53.66 | 2.47 | 16.88 | 10.97 | 0.94 | 78265.42 |
| 14 | 11.16 | 12.20 | 51.76 | 2.18 | 15.84 | 11.08 | 0.94 | 76978.81 |
| 15 | 12.09 | 12.48 | 63.26 | 1.53 | 17.04 | 11.26 | 0.94 | 73265.59 |
| 16 | 6.88 | 12.38 | 62.40 | 0.48 | 17.48 | 11.11 | 0.94 | 75739.78 |
| 17 | 7.77 | 11.95 | 52.87 | 0.43 | 18.43 | 10.63 | 0.95 | 80174.45 |
| 18 | 4.63 | 11.65 | 57.48 | 0.63 | 18.45 | 10.25 | 0.96 | 83594.90 |
| 19 | 11.37 | 12.05 | 58.01 | 1.02 | 18.40 | 10.72 | 0.97 | 81468.84 |
| 20 | 6.58 | 11.74 | 62.10 | 0.53 | 18.93 | 10.38 | 0.94 | 80504.61 |
| 21 | 5.09 | 12.04 | 50.79 | 1.24 | 17.39 | 10.82 | 0.96 | 81446.06 |
| 22 | 9.40 | 12.28 | 59.06 | 1.17 | 16.88 | 11.11 | 0.96 | 78192.36 |
| 23 | 2.58 | 12.55 | 65.01 | 0.72 | 18.01 | 11.09 | 0.95 | 79050.12 |
| 監測時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 超限次數 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 有效時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 平均值 | 7.64 | 12.29 | 56.16 | 1.56 | 16.93 | 11.02 | 0.97 | 78532.70 |
| 最大值 | 13.91 | 13.35 | 65.01 | 2.89 | 18.93 | 11.93 | 1.03 | 83594.90 |
| 發生時間 | 4 | 7 | 23 | 7 | 20 | 7 | | 18 |
| 最小值 | 1.81 | 11.65 | 46.99 | 0.43 | 14.30 | 10.25 | 0.94 | 73265.59 |
| 發生時間 | 5 | 18 | 10 | 17 | 7 | 18 | | 15 |
| 零點偏移(率) | -0.09 % | 0.00 % | -0.04 % | 0.00 % | | -0.13 | -0.01 | -0.20 % |
| 全幅偏移(率) | 2.03 % | 2.12 % | 0.46 % | 2.60 % | | -0.38 | 0.00 | -0.20 % |
| 有效比率 | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % |
| 備註 | | | | | | | | |

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年05月23日

| 項目 | #3-HCl_C | #3-CO_C | #3-NOx_C | #3-SO2_C | #3-H2O | #3-O2_C | #3-OPAC | #3-FLOW_C |
|---------|----------|----------|----------|----------|----------|---------|----------|-----------|
| 單位 | ppm | ppm | ppm | ppm | % | % | % | m3/Hour |
| 小時\限標 | 60.00 | 150.00 | 220.00 | 150.00 | 100.00 | 25.00 | 10.00 | 999999.00 |
| 0 | 7.13 | 11.89 | 59.35 | 2.04 | 16.80 | 10.76 | 1.33 | 73208.95 |
| 1 | 4.86 | 11.97 | 59.97 | 1.97 | 18.21 | 10.65 | 1.31 | 73926.19 |
| 2 | 7.28 | 11.83 | 61.24 | 2.40 | 17.07 | 10.65 | 1.31 | 73520.05 |
| 3 | 9.20 | 12.36 | 51.71 | 3.49 | 14.98 | 10.67 | 1.36 | 71919.52 |
| 4 | 1.73 | 11.89 | 38.53 | 1.64 | 16.65 | 10.46 | 1.36 | 66001.60 |
| 5 | 2.50 | 11.67 | 37.79 | 1.80 | 17.15 | 9.74 | 1.36 | 68930.76 |
| 6 | 1.72 | 11.64 | 34.38 | 1.82 | 16.19 | 9.58 | 1.36 | 70369.31 |
| 7 | 2.08 | 10.75 | 43.83 | 1.83 | 16.68 | 無效 | 1.35 | 61590.23 |
| 8 | 1.82 | 12.91 | 48.99 | 1.92 | 18.19 | 無效 | 1.34 | 61636.22 |
| 9 | 2.16 | 14.00 | 44.33 | 1.93 | 18.78 | 無效 | 1.32 | 60464.32 |
| 10 | 4.26 | 13.59 | 51.93 | 2.14 | 20.19 | 無效 | 1.35 | 59086.08 |
| 11 | 3.51 | 11.36 | 46.37 | 2.16 | 17.92 | 8.81 | 1.31 | 66396.37 |
| 12 | 8.62 | 11.79 | 51.01 | 2.53 | 18.19 | 8.92 | 1.32 | 70155.95 |
| 13 | 6.72 | 10.93 | 51.19 | 1.87 | 18.36 | 9.26 | 1.31 | 68162.08 |
| 14 | 4.40 | 11.02 | 58.57 | 2.12 | 20.72 | 9.12 | 1.31 | 70648.42 |
| 15 | 6.76 | 11.01 | 47.26 | 1.93 | 18.19 | 9.47 | 1.31 | 72340.03 |
| 16 | 2.70 | 11.27 | 44.86 | 1.50 | 17.83 | 9.86 | 1.31 | 73777.72 |
| 17 | 2.17 | 11.28 | 49.93 | 1.54 | 16.85 | 10.18 | 1.30 | 72844.94 |
| 18 | 2.74 | 11.38 | 60.34 | 1.51 | 17.95 | 10.15 | 1.33 | 73017.20 |
| 19 | 1.17 | 11.65 | 55.90 | 1.45 | 18.13 | 10.27 | 1.36 | 71470.03 |
| 20 | 4.78 | 11.35 | 49.58 | 1.55 | 18.12 | 9.89 | 1.33 | 72650.59 |
| 21 | 4.23 | 11.16 | 57.23 | 1.92 | 19.59 | 9.19 | 1.31 | 78695.60 |
| 22 | 6.00 | 13.03 | 47.34 | 1.88 | 19.45 | 9.36 | 1.31 | 74135.74 |
| 23 | 0.83 | 13.51 | 55.30 | 2.57 | 19.10 | 9.20 | 1.35 | 73911.93 |
| 監測時數 | 24 | 24 | 24 | 24 | 24 | 24 | 24 | 24 |
| 超限次數 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 有效時數 | 24 | 24 | 24 | 24 | 24 | 20 | 24 | 24 |
| 平均值 | 4.14 | 11.89 | 50.29 | 1.98 | 17.97 | 9.81 | 1.33 | 69952.49 |
| 最大值 | 9.20 | 14.00 | 61.24 | 3.49 | 20.72 | 10.76 | 1.38 | 78695.60 |
| 發生時間 | 3 | 9 | 2 | 3 | 14 | 0 | | 21 |
| 最小值 | 0.83 | 10.75 | 34.38 | 1.45 | 14.98 | 8.81 | 1.29 | 59086.08 |
| 發生時間 | 23 | 7 | 6 | 19 | 3 | 11 | | 10 |
| 零點偏移(率) | -0.04 % | 0.00 % | -0.01 % | 0.00 % | | -0.03 | -0.01 | -0.10 % |
| 全幅偏移(率) | 1.27 % | 0.42 % | -0.56 % | 1.45 % | | 0.04 | 0.04 | -0.10 % |
| 有效比率 | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 83.33 % | 100.00 % | 100.00 % |
| 備註 | | | | | | | | |