

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月14日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.47	6.50	57.02	0.44	18.15	11.18	1.02	84227.64
1	1.57	8.66	43.66	0.27	19.08	10.73	1.03	86061.72
2	3.54	4.23	39.82	1.27	17.44	11.49	1.02	81940.34
3	3.89	7.99	30.29	1.56	15.44	12.43	1.02	76012.99
4	7.83	7.77	37.97	1.84	15.39	12.20	1.02	77994.28
5	8.02	11.81	56.65	1.90	15.48	12.13	1.02	77786.42
6	9.33	6.68	50.89	0.92	17.24	11.85	1.02	79481.17
7	10.59	3.36	34.25	0.87	18.43	10.97	1.02	85599.25
8	9.16	3.11	39.34	0.88	17.83	11.35	1.02	82834.72
9	8.37	6.53	41.98	0.40	20.58	10.43	1.03	87391.36
10	10.07	2.28	45.27	0.66	18.63	10.59	1.04	87551.94
11	3.31	4.03	65.52	0.41	17.28	12.55	1.04	73097.20
12	0.16	3.69	63.27	0.29	18.35	11.84	1.04	78298.82
13	1.05	3.79	65.49	0.23	19.51	10.99	1.02	83860.90
14	4.66	7.89	50.16	0.21	19.64	10.43	1.02	88635.95
15	4.41	7.80	50.89	0.41	17.86	11.62	1.03	80349.14
16	3.92	8.53	61.54	0.34	17.18	12.21	1.05	76101.43
17	0.15	11.96	69.70	1.11	15.04	13.66	1.40	65287.33
18	0.04	4.77	33.83	0.81	15.27	11.81	1.15	81777.39
19	0.17	2.94	52.68	0.26	18.05	10.97	1.03	85919.71
20	0.56	4.81	48.60	0.25	18.06	11.27	1.02	83249.01
21	7.17	10.07	41.31	0.47	18.21	10.64	1.03	88074.80
22	8.44	11.70	30.08	1.31	16.71	11.46	1.04	82692.03
23	8.16	8.24	56.41	0.94	17.82	11.53	1.03	81138.73
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.96	6.63	48.61	0.75	17.61	11.51	1.05	81473.51
最大值	10.59	11.96	69.70	1.90	20.58	13.66	1.81	88635.95
發生時間	7	17	17	5	9	17		14
最小值	0.04	2.28	30.08	0.21	15.04	10.43	1.02	65287.33
發生時間	18	10	22	14	17	9		17
零點偏移(率)	-0.01 %	0.01 %	-0.01 %	-0.02 %		-0.09		-0.10 %
全幅偏移(率)	0.00 %	-0.17 %	-0.43 %	0.45 %		-0.03		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月14日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.21	5.14	53.28	0.96	18.50	11.01	1.04	78164.45
1	7.35	8.31	38.30	1.64	19.35	10.21	1.02	84072.81
2	7.71	7.25	37.90	3.01	17.15	10.74	1.02	81873.74
3	6.96	0.33	63.23	2.75	16.28	11.42	1.03	77513.22
4	14.16	0.93	59.47	3.38	16.06	11.14	1.03	80318.91
5	8.37	4.90	57.75	3.43	17.36	10.81	1.03	81551.51
6	6.87	6.56	45.68	3.00	15.14	11.40	1.02	75015.22
7	11.02	3.61	54.20	2.63	16.89	11.43	1.02	76523.11
8	9.30	3.90	42.30	3.40	16.21	11.76	1.02	74729.48
9	8.00	3.22	35.96	1.82	17.81	10.76	1.04	81429.35
10	4.89	2.88	48.89	1.17	18.05	10.92	1.04	79110.51
11	9.30	3.36	56.41	1.37	18.35	10.83	1.06	79892.91
12	4.51	4.62	32.31	1.63	18.52	10.64	1.05	81096.74
13	2.79	3.78	37.28	0.77	19.14	10.62	1.05	80762.06
14	4.88	4.07	43.53	1.51	19.69	10.24	1.05	83468.36
15	6.42	4.59	37.15	1.09	19.10	10.48	1.05	81468.92
16	2.50	3.31	43.96	1.35	17.79	10.95	1.04	79359.85
17	8.32	1.10	49.72	2.19	17.65	10.85	1.03	80081.41
18	6.24	2.21	45.57	1.84	18.19	10.53	1.04	81851.24
19	8.60	1.99	46.55	1.83	17.89	10.71	1.04	81212.70
20	3.82	2.85	58.82	1.10	18.73	10.88	1.05	79423.41
21	0.81	4.98	50.50	1.57	18.33	10.81	1.04	79999.60
22	0.37	6.51	48.69	2.03	18.53	10.44	1.04	82699.14
23	1.95	2.50	55.18	1.84	18.54	10.98	1.04	78497.58
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.35	3.87	47.61	1.97	17.89	10.86	1.04	80004.84
最大值	14.16	8.31	63.23	3.43	19.69	11.76	1.07	84072.81
發生時間	4	1	3	5	14	8		1
最小值	0.37	0.33	32.31	0.77	15.14	10.21	1.02	74729.48
發生時間	22	3	12	13	6	1		8
零點偏移(率)	-0.08 %	0.01 %	-0.04 %	-0.01 %		-0.03		-0.10 %
全幅偏移(率)	0.14 %	0.41 %	-0.13 %	0.25 %		-0.18		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月14日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.29	5.32	56.37	0.24	17.95	10.18	1.02	83177.56
1	2.69	4.96	43.98	0.38	17.95	10.33	1.04	81829.27
2	2.28	4.54	46.00	0.42	17.82	10.28	1.03	78330.96
3	2.62	1.40	57.57	0.42	16.39	10.35	1.02	73857.17
4	3.17	2.49	56.75	0.50	16.12	10.28	1.02	76556.13
5	11.79	7.21	55.07	1.74	16.21	10.19	1.02	78048.21
6	6.60	12.99	47.00	0.76	17.79	10.00	1.03	79877.02
7	15.24	6.53	43.59	1.59	17.88	10.27	1.02	93767.46
8	7.33	7.08	40.80	0.76	18.29	10.23	1.03	81787.82
9	8.89	3.44	30.52	0.47	21.60	8.71	1.03	89748.74
10	7.05	7.42	35.18	0.30	20.31	9.53	1.02	84050.70
11	6.57	9.75	34.70	0.28	20.52	9.51	1.01	85477.33
12	0.69	3.79	34.49	0.16	20.34	9.57	1.02	84910.95
13	3.77	3.10	38.48	0.25	20.81	9.47	1.00	84429.78
14	2.62	6.63	50.21	0.24	19.43	9.82	0.99	82843.13
15	0.18	6.03	48.74	0.17	19.87	9.59	0.99	84764.75
16	0.04	5.77	52.98	0.21	18.67	9.93	1.00	82985.84
17	0.00	7.93	53.85	0.23	19.13	10.17	1.01	81397.67
18	0.24	6.32	51.23	0.20	18.84	9.96	1.02	82858.63
19	0.00	8.39	55.01	0.19	19.27	9.92	1.03	82495.35
20	2.03	3.77	43.73	0.18	20.33	9.25	1.02	85858.80
21	1.02	5.21	53.89	0.21	19.26	9.88	1.03	83603.30
22	1.67	8.26	59.36	0.52	18.50	10.33	1.03	79840.95
23	2.39	3.26	55.62	0.41	18.19	10.25	1.03	82097.81
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.80	5.90	47.71	0.45	18.81	9.92	1.02	82691.47
最大值	15.24	12.99	59.36	1.74	21.60	10.35	1.04	93767.46
發生時間	7	6	22	5	9	3		7
最小值	0.00	1.40	30.52	0.16	16.12	8.71	0.99	73857.17
發生時間	17	3	9	12	4	9		3
零點偏移(率)	-0.01 %	0.01 %	-0.02 %	-0.01 %		-0.07		0.20 %
全幅偏移(率)	0.02 %	-0.17 %	-0.23 %	0.56 %		-0.08		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								